



JDYX2.E156471 Fuses, Supplemental - Component

[Page Bottom](#)

Fuses, Supplemental - Component

[See General Information for Fuses, Supplemental - Component](#)

HOLLYLAND CO LTD
UNIT B, 31ST FL
BILLION CENTRE, TOWER A
1 WANG KWONG RD
KOWLOON BAY, KOWLOON HONG KONG

E156471

Supplemental fuses

Cat. No.	Size mm(in)	Amps (A)	Volts (V)	Interrupting Rating (A)
41NM	-	0.3 - 5	300Vac	50
		0.3 - 5	125Vac	500
		2.5 - 5	250Vac	100
		0.3 - 2.25	250Vac	50
		15	300Vac	100
41S	4.5 x 15 (0.18 x 0.59)	4 - 10	125Vac	100
		4 - 10	250Vac	100
50CF	5.2 x 20 x 2.2 (0.20 x 0.79 x 0.09)	0.25 - 16	250Vac	1500
		0.25 - 16	250Vdc	1000
50CT	5.2 x 20 (0.20 x 0.79)	0.2 - 15	250Vac	200
50F	5.2 x 20 (0.20 x 0.79)	0.2 - 0.8	250Vac	35
		0.2 - 0.8	250Vac	10x Ampere rating
		1.0 - 6.3	250Vac	35
		1.0 - 6.3	250Vac	10x Ampere rating
		8 - 16	250Vac	35
		8 - 16	250Vac	10x Ampere rating
50T	5.2 x 20 (0.20 x 0.79)	0.125 - 0.4	250Vac	35
		0.125 - 0.4	250Vac	10x Ampere rating
		0.5 - 6.3	250Vac	35
		0.5 - 6.3	250Vac	10x Ampere rating
		8 - 15	250Vac	63
51MS	-	2 - 8	250Vac	100
51NM	-	3 - 8	250Vac	100
51S	-	6 - 8	125Vac	200
		3 - 8	250Vac	100
65NM	6.35 x 31.8 (0.25 x 1.25)	20 - 30	125Vac	100
		20 - 30	250Vac	100

		20 - 30	125Vdc	400
65TS	-	20 - 25	125Vac	400
		20 - 25	250Vac	100
6FF	6.35 x 31.8 (0.25 x 1.25)	0.2 - 2	1000Vac	10000
		0.2 - 2	1000Vdc	10000
6FF-1	6.35 x 31.8 (0.25 x 1.25)	0.2 - 2	500Vac	10000
		0.2 - 2	500Vdc	10000
HC10aR	10.3 x 38 (0.41 x 1.50)	0.25 - 3.15	500Vac	120000
		0.25 - 3.15	500Vdc	120000
		0.25 - 3.15	690Vac	80000
		0.25 - 3.15	690Vdc	50000
		0.25 - 3.15	1000Vdc	30000
		0.25 - 3.15	1000Vac	50000
		4.0 - 6.3	500Vac	120000
		4.0 - 6.3	500Vdc	120000
		4.0 - 6.3	690Vac	80000
		4.0 - 6.3	690Vdc	50000
		4.0 - 6.3	1000Vdc	30000
		4.0 - 6.3	1000Vac	50000
		7.0 - 32	500Vac	120000
		7.0 - 32	500Vdc	120000
		7.0 - 32	690Vac	80000
		7.0 - 32	690Vdc	50000
		7.0 - 32	1000Vdc	30000
		7.0 - 32	1000Vac	50000
HC10aR-B	10.3 x 38 (0.41 x 1.50)	10	500Vac	120000
		10	500Vdc	120000
		10	690Vac	80000
		10	690Vdc	50000
		10	1000Vac	50000

Supplemental fuses: pigtail leads

Cat. No.	Size mm(in)	Amps (A)	Volts (V)	Interrupting Rating (A)
41NM(P)	-	0.3 - 5	300Vac	50
		0.3 - 5	125Vac	500
		2.5 - 5	250Vac	100
		0.3 - 2.25	250Vac	50
		15	300Vac	100
42S,41S(P)	4.5 x 15 (0.18 x 0.59)	4 - 10	125Vac	100
		4 - 10	250Vac	100
50CF(P)	5.2 x 20 x 2.2 (0.20 x 0.79 x 0.09)	0.25 - 16	250Vac	1500
		0.25 - 16	250Vdc	1000

50CT(P)	5.2 x 20 (0.20 x 0.79)	0.2 - 0.63	250Vac	200
		0.8 - 1.0	250Vac	200
		1.25 - 15	250Vac	200
50F(P)	5.2 x 20 (0.20 x 0.79)	0.2 - 0.8	250Vac	35
		0.2 - 0.8	250Vac	10x Ampere rating
		1.0 - 6.3	250Vac	35
		1.0 - 6.3	250Vac	10x Ampere rating
		8 - 16	250Vac	35
		8 - 16	250Vac	10x Ampere rating
51MS(P)	-	2 - 8	250Vac	100
51NM(P)	-	3 - 8	250Vac	100
51S(P)	-	6 - 8	125Vac	200
		3 - 8	250Vac	100
5GT	5.0 x 20 (0.20 x 0.79)	0.8 - 3.5	250Vac	35
		4 - 6.3	250Vac	63
		7 - 10	250Vac	100
65TS(P)	-	20 - 30	125Vac	400
		20 - 30	250Vac	100
6FF(P)	6.85 x 32.4 (0.27 x 1.28)	0.2 - 2	1000Vac	10000
		0.2 - 2	1000Vdc	10000
6FF(P)-1	6.85 x 32.4 (0.27 x 1.28)	0.2 - 2	500Vac	10000
		0.2 - 2	500Vdc	10000

Supplemental fuses: pigtail leads, filled-tube

Cat. No.	Size mm(in)	Amps (A)	Volts (V)	Interrupting Rating (A)
5CT	5.2 x 20 (0.20 x 0.79)	1 - 2	250Vac	1500
		2.5 - 3.15	250Vac	1500
		3.5 - 6.3	250Vac	1500
		7.0 - 10	250Vac	1500
65NM(P)	6.35 x 31.8 (0.25 x 1.25)	20	125Vac	100
		20	250Vac	100
		20	125Vdc	400
		25	125Vac	100
		25	250Vac	100
		25	125Vdc	400
		30	125Vac	100
		30	250Vac	100
		30	125Vdc	400

Supplemental fuses: cartridge enclosed

Cat. No.	Size mm(in)	Amps (A)	Volts (V)	Interrupting Rating (A)

53S, 54S	-	6 - 8	125Vac	200
		3 - 8	250Vac	100

Supplemental micro fuses

Cat. No.	Size mm(in)	Amps (A)	Volts (V)	Interrupting Rating (A)
06F	1.6 x 0.85 x 0.5 (0.06 x 0.03 x 0.02)	0.1 - 0.25	32Vac	50
		0.1 - 0.25	63Vdc	50
		0.3 - 1.0	32Vac	50
		0.3 - 1.0	32Vdc	50
		1.2 - 5.0	32Vdc	35
		1.2 - 5.0	32Vac	35
06T	1.6 x 0.85 x 0.5 (0.06 x 0.03 x 0.02)	0.1 - 0.25	32Vac	50
		0.1 - 0.25	63Vdc	50
		0.3 - 1.0	32Vac	50
		0.3 - 1.0	32Vdc	50
		1.2 - 5.0	32Vdc	35
		1.2 - 5.0	32Vac	35
12F	3.2 x 1.6 x 1.0 (0.13 x 0.06 x 0.04)	0.1 - 0.375	32Vac	50
		0.1 - 0.375	63Vdc	50
		0.4 - 3.0	63Vac	50
		0.4 - 3.0	63Vdc	50
		3.15 - 7	24Vac	35
		3.15 - 7	32Vdc	50
12T	3.2 x 1.6 x 1.0 (0.13 x 0.06 x 0.04)	0.1 - 0.375	63Vac	50
		0.1 - 0.375	63Vdc	50
		0.4 - 3.0	63Vac	50
		0.4 - 3.0	63Vdc	50
		3.15 - 7	24Vac	35
		3.15 - 7	32Vdc	50
20N	2.42 x 7.1 (0.10 x 0.28)	3.15 - 10	125Vac	30
		3.15 - 10	250Vac	30
		3.15 - 10	125Vdc	50
		0.1 - 0.315	250Vac	30
		0.1 - 0.315	125Vdc	50
		12 - 15	72Vac	30
		20	60Vdc	50
20T	2.42 x 7.1 (0.10 x 0.28)	0.1 - 7	125Vac	30
		0.1 - 7	250Vac	30
2N0100L	5.7 x 2.2 x 2.2 (0.22 x 0.09 x 0.09)	0.1	125Vac	50
2N010L	5.7 x 2.2 x 2.2 (0.22 x 0.09 x 0.09)	1	125Vac	50
2N0125L	5.7 x 2.2 x 2.2 (0.22 x 0.09 x 0.09)	0.125	125Vac	50

2N013L	5.7 x 2.2 x 2.2 (0.22 x 0.09 x 0.09)	1.25	125Vac	50
2N015L	5.7 x 2.2 x 2.2 (0.22 x 0.09 x 0.09)	1.5	125Vac	50
2N0160L	5.7 x 2.2 x 2.2 (0.22 x 0.09 x 0.09)	0.16	125Vac	50
2N016L	5.7 x 2.2 x 2.2 (0.22 x 0.09 x 0.09)	1.6	125Vac	50
2N0200L	5.7 x 2.2 x 2.2 (0.22 x 0.09 x 0.09)	0.2	125Vac	50
2N020L	5.7 x 2.2 x 2.2 (0.22 x 0.09 x 0.09)	2	125Vac	50
2N0250L	5.7 x 2.2 x 2.2 (0.22 x 0.09 x 0.09)	0.25	125Vac	50
2N025L	5.7 x 2.2 x 2.2 (0.22 x 0.09 x 0.09)	2.5	125Vac	50
2N030L	5.7 x 2.2 x 2.2 (0.22 x 0.09 x 0.09)	3	125Vac	50
2N0315L	5.7 x 2.2 x 2.2 (0.22 x 0.09 x 0.09)	0.315	125Vac	50
2N032L	5.7 x 2.2 x 2.2 (0.22 x 0.09 x 0.09)	3.15	125Vac	50
2N035L	5.7 x 2.2 x 2.2 (0.22 x 0.09 x 0.09)	3.5	125Vac	50
2N0375L	5.7 x 2.2 x 2.2 (0.22 x 0.09 x 0.09)	0.375	125Vac	50
2N0400L	5.7 x 2.2 x 2.2 (0.22 x 0.09 x 0.09)	0.4	125Vac	50
2N040L	5.7 x 2.2 x 2.2 (0.22 x 0.09 x 0.09)	4	125Vac	50
2N0500L	5.7 x 2.2 x 2.2 (0.22 x 0.09 x 0.09)	0.5	125Vac	50
2N050L	5.7 x 2.2 x 2.2 (0.22 x 0.09 x 0.09)	5	125Vac	50
2N0630L	5.7 x 2.2 x 2.2 (0.22 x 0.09 x 0.09)	0.63	125Vac	50
2N063L	5.7 x 2.2 x 2.2 (0.22 x 0.09 x 0.09)	6.3	125Vac	50
2N070L	5.7 x 2.2 x 2.2 (0.22 x 0.09 x 0.09)	7	125Vac	50
2N0750L	5.7 x 2.2 x 2.2 (0.22 x 0.09 x 0.09)	0.75	125Vac	50
2N0800L	5.7 x 2.2 x 2.2 (0.22 x 0.09 x 0.09)	0.8	125Vac	50
2N080L	5.7 x 2.2 x 2.2 (0.22 x 0.09 x 0.09)	8	125Vac	50
2N100L	5.7 x 2.2 x 2.2 (0.22 x 0.09 x 0.09)	10	125Vac	50
2N120L	5.7 x 2.2 x 2.2 (0.22 x 0.09 x 0.09)	12	65Vac	50
2N150L	5.7 x 2.2 x 2.2 (0.22 x 0.09 x 0.09)	15	65Vac	50
5ET	8.0 x 4.0 x 8.5 (0.31 x 0.16 x 0.33)	0.1 - 0.25	300Vac	50
		0.1 - 0.25	125Vdc	50
		0.315 - 5	125Vdc	50
		0.315 - 5	250Vac	63
		0.315 - 5	300Vac	50
		6.3	300Vac	50

		6.3	250Vac	63
		6.3	125Vdc	63
		0.315 - 10	250Vac	130
5RT	8.3 x 7.5 (0.33 x 0.30)	0.1 - 0.25	300Vac	50
		0.1 - 0.25	125Vdc	50
		0.315 - 5.0	300Vac	50
		0.315 - 5.0	250Vac	63
		0.315 - 5.0	125Vdc	50
		6.3	300Vac	50
		6.3	250Vac	63
		6.3	125Vdc	63

Supplemental micro fuses: pigtail leads

Cat. No.	Size mm(in)	Amps (A)	Volts (V)	Interrupting Rating (A)
25S	3.6 x 10.0 (0.14 x 0.39)	1 - 2	125Vac	50
		1 - 2	250Vac	50
30TS	4.0 x 9.0 (0.16 x 0.35)	0.2 - 1.6	350Vac	30
5EF	8.5 x 8.3 x 4 (0.33 x 0.33 x 0.16)	0.315 - 2.5	250Vac	35
		3.15	250Vac	35
		4	250Vac	40
		5	250Vac	50
		6.3	250Vac	63
5RF	8.3 x 7.8 x 2.2 (0.33 x 0.31 x 0.09)	0.315 - 2.5	250Vac	35
		3.15	250Vac	35
		4	250Vac	40
		5	250Vac	50
		6.3	250Vac	63

(P) - Pigtail leads.

Note - The following models are identical to each other except for the model numbers: 41NM(P) and 42NM; 51NM(P) and 52NM; 51MS(P) and 52MS.

Marking: Company name or tradename "H in a circle", "HOLLY" and model designation.

Last Updated on 2013-01-31

[Questions?](#)

[Print this page](#)

[Terms of Use](#)

[Page Top](#)

© 2013 UL LLC

When the UL Leaf Mark is on the product, or when the word "Environment" is included in the UL Mark, please search the [UL Environment database](#) for additional information regarding this product's certification.

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Listed and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Designs and/or Listings (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2013 UL LLC".