



Strojírenský zkušební ústav, s. p., autorizovaná osoba 202
(Engineering Test Institute, Public Enterprise, Authorized Body 202)
Hudcova 56b, 621 00 Brno, Czech Republic
Authorization Decision No. 9/2003 dated 2003-03-19

TYPE CERTIFICATE

Number: **B-30-00570-09**

Manufacturer: ČERVINKA - CZECH REPUBLIC s.r.o.
Rostislavova 1265, 686 01 Uherské Hradiště
Czech Republic

Identification No.: 25510622

Product: Portable Powder Fire-Extinguisher
Type designation: P 2 Če, under constant pressure
Extinguishing capacity: 8 A, 55 B, C
Range of functional temperatures: -30 °C up to +60 °C
Extinguishing medium: 2 kg - Extinguishing powder HJ ABC
Super Powder

This product has been certified within the meaning of Art. 10 of Act 22/1997 Coll., concerning technical requirements for products and amendment to certain acts, as amended. The above stated Authorized Body hereby certifies that the characteristics of the product sample concerned have been found to be in conformity with applicable requirements pursuant to § 1, Art. 2 of Government Regulation No. 173/1997 Coll., as amended.

During assessment of conformity were applied relevant requirements of the following technical standards:

ČSN EN 3-6:1997, ČSN EN 3-8:2007, ČSN EN 3-7+A1:2008.


An integral part of this Certificate is the Final Report No. 30-10308 of 2009-06-22. The Certificate is valid till 2014-06-30.

This certificate has been issued for the purpose of edition of producer's declaration on conformity of the product with the essential requirements in the meaning of § 1, Art. 2 of Government Regulation No. 173/1997 Coll., as amended.

The rules for handling the certificate are stated on page 2.

Brno 2009-06-22




.....
Petr Mašek
Director

B-30-00570-09, Page 1 (2)

Strojírenský zkušební ústav, s. p., Hudcova 56b, 621 00 Brno, Česká republika
Engineering Test Institute, public enterprise, Hudcova 56b, 621 00 Brno, Czech Republic

www.szutest.cz