



**SPECIFICATION OF THE CERTIFIED PRODUCT**

**Product data**

product : plugs, (2-pole)  
trade name : WERNER LANGER  
type : 270  
rated current : 2,5 A  
rated voltage : 250 V~  
design : non-rewirable  
standard sheet : I  
applied flexible cords : H03VVH2-F 2x0,75 mm<sup>2</sup>  
H05VVH2-F 2x0,75 mm<sup>2</sup>  
H03VV-F 2x0,75 mm<sup>2</sup>  
certification mark : HAR certified  
cord termination : crimped connection  
description : body of thermoplastic material as part of an incomplete  
cord set for class II appliances  
markings : are shown on the body

**TESTS**

**Test requirements**

EN 50075:1990

**Test result**

The test results are laid down in KEMA test file 2090094.01.

**Remarks**

Any appliance fitted with a Euro plug and intended for use in the UK shall carry a warning label with the following text at the plug end of the supply cable: WARNING. Within the UK this appliance may only be used when supplied from a shaver supply unit in accordance with EN 61558-2-4 and must not be connected to a UK mains socket.

**Conclusion**

The examination proved that all test requirements were met.

Tested by : T. Overkluft Vaupel Kleyn

Checked by : H.R.M. Barends

**Factory-Locations**

Werner Langer GmbH & Co KG,  
Auf dem Lohnsberg 6, 59872, MESCHEDE-BERGE, Germany

# CERTIFICATE

KEMA No.: 2090094.01

Issued to:  
Applicant:

**Werner Langer GmbH & Co KG**  
Auf dem Lohnsberg 6  
59872, MESCHEDE-BERGE, Germany

Manufacturer/Licensee:

**Werner Langer GmbH & Co KG**  
Auf dem Lohnsberg 6  
59872, MESCHEDE-BERGE, Germany

Product(s) : plugs, (2-pole)  
Trade name(s) : WERNER LANGER  
Type(s)/model(s) : 270



The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

KEMA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard EN 50075: 1990
- an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 2090094

KEMA hereby grants the right to use the ENEC KEMA-KEUR certification mark.


The ENEC KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration of the ENEC KEMA-KEUR certification agreement and under the conditions of the ENEC KEMA-KEUR certification agreement.

This certificate is issued on: March 1, 2006 and expires upon withdrawal of one of the above mentioned standards.

KEMA Quality B.V.



P. Nabuurs  
Managing director



H.R.M. Barends  
Certification Manager

ACCREDITED BY  
THE DUTCH COUNCIL  
FOR ACCREDITATION



© Integral publication of this certificate is allowed