



中国国家强制性产品认证证书

证书编号: 2004010305127663

委托人名称、地址

ABB France
3 Rue Jean Perrin CS 90009 69687 Chassieu Cedex, France

生产者(制造商)名称、地址

ABB France
3 Rue Jean Perrin CS 90009 69687 Chassieu Cedex, France

生产企业名称、地址

COMEPI s.r.l
Via Novarino, 9/L - Robbiate - Italy

产品名称和系列、规格、型号

行程开关

LS-□ □ □ □ □; Ith:10A;AC-15:Ue/Ie:AC240V/3A;DC-13:Ue/Ie:DC250V/0.27A,
DC24V/2.8A;具体型号解释见附件

产品标准和技术要求

GB 14048.5-2008

上述产品符合强制性产品认证实施规则
CNCA-C03-02:2014的要求,特发此证。

发证日期: 2016年03月22日

有效期至: 2021年03月22日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书,证书首次颁发日期: 2004年08月19日

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询



主任:

中国质量认证中心

中国·北京·南四环西路188号9区 100070

<http://www.cqc.com.cn>



Q 1388721



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2004010305127663

NAME AND ADDRESS OF THE APPLICANT

ABB France
3 Rue Jean Perrin CS 90009 69687 Chassieu Cedex, France

NAME AND ADDRESS OF THE MANUFACTURER

ABB France
3 Rue Jean Perrin CS 90009 69687 Chassieu Cedex, France

NAME AND ADDRESS OF THE FACTORY

COMEPI s.r.l
Via Novarino, 9/L - Robbiate - Italy

NAME, MODEL AND SPECIFICATION

Limit Switch

LS-□ □ □ □ □; Ith:10A;AC-15:Ue/Ie:AC240V/3A;DC-13:Ue/Ie:DC250V/0.27A,
DC24V/2.8A;

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB 14048.5-2008

This is to certify that the above mentioned products have met the requirements of implementation rules for compulsory certification (REF NO. CNCA-C03-02:2014).

Date of issue: Mar. 22, 2016 Date of expiry: Mar. 22, 2021

Validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original certification: Aug. 19, 2004

This certificate can be verified through CNCA's website: www.cnca.gov.cn



President:

Wang Kejiao



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188, Nansihuan Xilu, Beijing 100070 P.R. China

<http://www.cqc.com.cn>

Q 1388721



中国国家强制性产品认证证书

附录:

第 1 页 共 1 页

证书编号: 2004010305127663

纸号: 1388721

型号的解释(Explanation of model/ type):

<u>LS</u>	-	<u>30</u>	<u>P</u>	<u>31</u>	<u>C</u>	<u>11</u>
1		2	3	4	5	6

- 1- Basic type
- 2- Casing width
 - 30= 30 mm width +1 cable inlet for Pg 13.5 cable gland
 - 31= 30 mm width +1 cable inlet for Pg 11 cable gland
 - 40= 40 mm width +1 cable inlet for Pg 13.5 cable gland
- 3- Plastic casing
- 4- Operating heads codes
 - 11=Plain plunger
 - 13= Roller plunger
 - 31=Roller lever
 - 41=Roller lever
 - 51=Adjustable roller lever
- 5- Action type
 - B: zb Snap action
 - L: zb Slow action (contact dependent)
 - D: zb Slow action non-overlapping late make
 - C: zb Slow action overlapping early make
- 6- Contact block
 - 11: 1NO contact + 1NC contact
 - 20: 2NO contacts
 - 02: 2NC contacts

注: 此附录与证书同时使用时有效。



主任:

中国质量认证中心

中国 · 北京 · 南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>

