

Certificate

No. **z4698a-17-E**

Customer:

Assmann Electronic GmbH
Auf dem Schüffel 3
58513 Lüdenscheid, Germany

Class E

Test sample(s):

Data Cable:
Digitus Professional Cat 6, Class E, U-UTP Twisted Pair Installationcable
Part no.: DK-1613-VH-

Patchcord:
Digitus Professional Cat 6; Class E, U-UTP, Patch Cord
Part no.: DK-1617-

Connector:
Digitus Professional Cat 6; Class EA, UTP, Keystone Modul
Part no.: DN-93603

Applied standard(s):
ISO/IEC 11801 Ed.2.2 (2011-06)

Result(s):
The sample meets the limits of the specified standards and regulations with respect to the parameters indicated above.

2 Connector Channel, Copper, Class E

GHMT Type Approval

The test results which were determined in the course of the measurement refer to the submitted specimen. Any future technical modifications of the verified products are subject to the responsibility of the manufacturer.

This Certificate refers to the comprehensive test report no. **P4698a-17-E** and shall only be applicable in conjunction with the test report. This certificate is valid 24 months after date of issue.

Bexbach, 28. June 2017



Dirk Wilhelm, engineer
(Chairman of the Managing Board)



Test laboratory accredited by DAKKS in accordance with DIN EN ISO/IEC 17025.
The accreditation is valid for the test methods listed in certificate **D-PL-17559-01-00**.

GHMT AG
In der Kolling 13
66450 Bexbach / Germany

P0 box 11 16
66442 Bexbach / Germany

T: +49 6826 92 28-0
F: +49 6826 92 28-290

info@ghmt.de
www.ghmt.de

**RELIABILITY IN TOTAL
REQUIRES ACCURACY IN DETAIL.**