



Declaration of Conformity

For the following equipment :

Product Name: Switching Power Supplies

Model Designation: HLx-80H-yz (x=G,N,P ; y=12,15,20,24,30,36,42,48,54 ; z=A or B or D or Blank)
HLG-80H-xBL(x=12,15,20,24,30,36,42,48,54)

is herewith confirmed to comply with the requirements set out in the Council Directive, the following standards were applied :

RoHS Directive (2011/65/EU)

Energy-Related Products Directive (2009/125/EC)
Implementing measure COMMISSION REGULATION(EC) No 1194/2012

Low Voltage Directive (2014/35/EU) :

TUV certificate No : R50202561(HLG/HLN-80H)

EN61347-1:2008+A1+A2/EN61347-2-13:2006 TUV certificate No : R50201138(HLP-80H)

Electromagnetic Compatibility Directive (2014/30/EU) :

EMI (Electro-Magnetic Interference)

Conducted emission / Radiated emission
EN55015:2013

Harmonic current EN61000-3-2:2014 class C ($\geq 60\%$ load)

Voltage flicker EN61000-3-3:2013

EMS (Electro-Magnetic Susceptibility)

EN61547:2009

ESD air EN61000-4-2: 2009 Level 3 8KV

ESD contact EN61000-4-2: 2009 Level 2 4KV

RF field susceptibility EN61000-4-3:2006+A1:2008+A2:2010 Level 2 3V/m

EFT bursts EN61000-4-4:2012 Level 2 1KV/5KHz

Surge susceptibility EN61000-4-5:2006 Level 3 2KV/Line-Line

Surge susceptibility EN61000-4-5:2006 Level 4 4KV/Line-Earth

Conducted susceptibility EN61000-4-6:2014 Level 2 3V

Magnetic field immunity EN61000-4-8:2010 Level 2 3A/m

Voltage dip, interruption EN61000-4-11:2004 >95% dip 0.5 periods 30% dip 25 periods >95% interruptions 250 periods

Note:

Component power supply will be operated with a final equipment. Since EMC performance will be affected by the complete installation, the final equipment manufacturers must re-qualify EMC Directive on the complete installation again.

Tests above are only to be performed with LEDs.

For guidance on how to perform these EMC tests, please refer to TDF (Technical Documentation File).

To fulfill requirements of the latest ErP regulation for lighting fixtures, this LED power supply can only be used behind a switch without permanently connected to the mains.

This Declaration is effective from serial number HB6xxxxxxx

Person responsible for marking this declaration :

MEAN WELL Enterprises Co., Ltd.

(Manufacturer Name)

No.28, Wuquan 3rd Rd., Wugu Dist., New Taipei City 248, Taiwan

(Manufacturer Address)

Johnny Huang/Manager, Certification center :

(Name / Position)

(Signature)

Ted Cheng/Director, Sales Dept. :

(Name / Position)

(Signature)

Taiwan

(Place)

Apr. 20th, 2016

(Date)