## **DATASHEET - AE/I43E**



### MCB enclosure, 3x9space units, HxWxD=250x375x150mm

Powering Business Worldwide\*

1/3

Part no. AE/143E Catalog No. 000239

EL-Nummer (Norway) 0002502009

## **Delivery program**

Dimensions	mm	\$25 \$25 \$25 \$25 \$25 \$25 \$25 \$25 \$25 \$25
Product range		xEnergy Safety Ci
Basic function		Prepared enclosures
Product function		MCB individual enclosures
Accessories		MCB individual enclosures
Single unit/Complete unit		Stand-alone device
Standards		EN 62208 EN 61439-2
Description		Metric cable entry knockouts in all sides Housings for e.g. built-in devices MCB, RCD, RCBO, AFDD Transparent cover with quick-release fasteners Metal mounting rail for snapping on devices 1 x Blanking strip for unused mounting locations Protective shroud with inscription label PE/N combi-plug-in terminals Fixing straps for wall fixing Sealable cover fasteners
Degree of Protection		IP65
Width	mm	250
Height	mm	375
Depth	mm	150
Modular spacing (space units)	Number	27
PE and N terminals, quantity x cross-section	$mm^2$	On each 3 x (2.5 - 25) On each 21 x (0.5 - 4)
Model		
Type cover		Transparent
Notes C	2 x M50/32 6 x M25/16 8 x M20	

# Design verification as per IEC/EN 61439

D

Technical data for design verification			
Heat dissipation, at an ambient temperature of 35°C, delta T: 20 degrees in top of the enclosure, calculated as per IEC 60890			
Individual enclosure for wall mounting	$P_{V}$	W	19
Starting enclosure for wall mounting	$P_{V}$	W	17
Middle enclosure for wall mounting	$P_{V}$	W	16

1 x M50/32 6 x M25/16

Heat dissipation, at an ambient temperature of 35°C, delta T: 35 degrees in top of the enclosure, calculated as per IEC 60890  Individual enclosure for wall mounting Pv W 35  Starting enclosure for wall mounting Pv W 35  Middle enclosure for wall mounting Pv W 32  IEC/EN 61439 design verification  10.2 Strength of materials and parts 10.2.2 Corrosion resistance 10.2.3.1 Verification of thermal stability of enclosures 10.2.3.2 Verification of resistance of insulating materials to normal heat and fire due to internal electric effects 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting 10.2.6 Mechanical impact 10.2.7 Inscriptions 10.3.0 Degree of protection of ASSEMBLIES 10.4 Clearances and creepage distances 10.5 Protection against electric shock  Nor relevant to indoor installations. 10.5 Is the panel builder's responsibility. 10.5 Protection against electric shock  Protection class 2, therefore not applicable.
Starting enclosure for wall mounting  Py W 35  Middle enclosure for wall mounting  Py W 32  IEC/EN 61439 design verification  10.2 Strength of materials and parts  10.2.2 Corrosion resistance  10.2.3.1 Verification of thermal stability of enclosures  10.2.3.2 Verification of resistance of insulating materials to normal heat and fire due to internal electric effects  10.2.4 Resistance to ultra-violet (UV) radiation  10.2.5 Lifting  10.2.6 Mechanical impact  10.2.7 Inscriptions  10.3 Degree of protection of ASSEMBLIES  10.4 Clearances and creepage distances  Py W 32  Meets the product standard's requirements.  Meets the product standard's requirements.  Lower part: 960 °C / cover: 850 °C; meets the product standard's requirement as a per the latest applicable instruction leaflet.  IK10  Meets the product standard's requirements.  IK10  Meets the product standard's requirements.  IK10  Meets the product standard's requirements.  IK10  IK10  Meets the product standard's requirements.
Middle enclosure for wall mounting  Py W 32  IEC/EN 61439 design verification  10.2 Strength of materials and parts  10.2.2 Corrosion resistance  10.2.3.1 Verification of thermal stability of enclosures  10.2.3.2 Verification of resistance of insulating materials to normal heat  10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects  10.2.4 Resistance to ultra-violet (UV) radiation  10.2.5 Lifting  10.2.6 Mechanical impact  10.2.7 Inscriptions  10.3 Degree of protection of ASSEMBLIES  10.4 Clearances and creepage distances  Py W 32  Meets the product standard's requirements.  Meets the product standard's requirements.  Lower part: 960 °C / cover: 850 °C; meets the product standard's requirement as a per the latest applicable instruction leaflet.  IK10  Meets the product standard's requirements.  10 kg per enclosure with support frame and lifting aid met; assembled and se as per the latest applicable instruction leaflet.  IK10  Meets the product standard's requirements.  10 kg per enclosure with support frame and lifting aid met; assembled and se as per the latest applicable instruction leaflet.  IK10  Meets the product standard's requirements.  10 kg per enclosure with support frame and lifting aid met; assembled and se as per the latest applicable instruction leaflet.  IK10  Meets the product standard's requirements.
IEC/EN 61439 design verification  10.2 Strength of materials and parts  10.2.2 Corrosion resistance  10.2.3.1 Verification of thermal stability of enclosures  10.2.3.2 Verification of resistance of insulating materials to normal heat  10.2.3.2 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects  10.2.4 Resistance to ultra-violet (UV) radiation  10.2.5 Lifting  10 kg per enclosure with support frame and lifting aid met; assembled and se as per the latest applicable instruction leaflet.  10.2.7 Inscriptions  10.3 Degree of protection of ASSEMBLIES  10.4 Clearances and creepage distances  Meets the product standard's requirements.  Lower part: 960 °C / cover: 850 °C; meets the product standard's requirement and lifting aid met; assembled and se as per the latest applicable instruction leaflet.  IK10  Meets the product standard's requirements.  IK10  IP65  Is the panel builder's responsibility.
10.2 Strength of materials and parts  10.2.2 Corrosion resistance  10.2.3.1 Verification of thermal stability of enclosures  10.2.3.2 Verification of resistance of insulating materials to normal heat  10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects  10.2.4 Resistance to ultra-violet (UV) radiation  10.2.5 Lifting  10.2.6 Mechanical impact  10.2.7 Inscriptions  10.3 Degree of protection of ASSEMBLIES  10.4 Clearances and creepage distances  Meets the product standard's requirements.  Meets the product standard's requirements.  Lower part: 960 °C / cover: 850 °C; meets the product standard's requirement and fire due to internal electric effects  Not relevant to indoor installations.  10 kg per enclosure with support frame and lifting aid met; assembled and season per the latest applicable instruction leaflet.  IK10  Meets the product standard's requirements.  IR10  I
10.2.2 Corrosion resistance  10.2.3.1 Verification of thermal stability of enclosures  Meets the product standard's requirements.  10.2.3.2 Verification of resistance of insulating materials to normal heat  10.2.3.3 Verification of resistance of insulating materials to abnormal heat  10.2.3.3 Verification of resistance of insulating materials to abnormal heat  and fire due to internal electric effects  10.2.4 Resistance to ultra-violet (UV) radiation  Not relevant to indoor installations.  10.2.5 Lifting  10 kg per enclosure with support frame and lifting aid met; assembled and se as per the latest applicable instruction leaflet.  10.2.6 Mechanical impact  IK10  10.2.7 Inscriptions  Meets the product standard's requirements.  10.3 Degree of protection of ASSEMBLIES  10.4 Clearances and creepage distances  Is the panel builder's responsibility.
10.2.3.1 Verification of thermal stability of enclosures  10.2.3.2 Verification of resistance of insulating materials to normal heat  10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects  10.2.4 Resistance to ultra-violet (UV) radiation  10.2.5 Lifting  10 kg per enclosure with support frame and lifting aid met; assembled and se as per the latest applicable instruction leaflet.  10.2.6 Mechanical impact  10.2.7 Inscriptions  10.3 Degree of protection of ASSEMBLIES  10.4 Clearances and creepage distances  Meets the product standard's requirements.  IK 10  IK 10  IS 10 be the product standard's requirements.  IN 10 be the product standard's requirements.
10.2.3.2 Verification of resistance of insulating materials to normal heat 10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects  10.2.4 Resistance to ultra-violet (UV) radiation  10.2.5 Lifting  10 kg per enclosure with support frame and lifting aid met; assembled and seas per the latest applicable instruction leaflet.  10.2.6 Mechanical impact  10.2.7 Inscriptions  Meets the product standard's requirements.  10.3 Degree of protection of ASSEMBLIES  10.4 Clearances and creepage distances  Meets the product standard's requirements.  Is the panel builder's responsibility.
10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects  10.2.4 Resistance to ultra-violet (UV) radiation  10.2.5 Lifting  10.2.6 Mechanical impact  10.2.7 Inscriptions  10.3 Degree of protection of ASSEMBLIES  10.4 Clearances and creepage distances  Lower part: 960 °C / cover: 850 °C; meets the product standard's requirement and lifting aid met; assembled and sea as per the latest applicable instruction leaflet.  IK10  Meets the product standard's requirements.  IP65  Is the panel builder's responsibility.
and fire due to internal electric effects  10.2.4 Resistance to ultra-violet (UV) radiation  Not relevant to indoor installations.  10.2.5 Lifting  10 kg per enclosure with support frame and lifting aid met; assembled and se as per the latest applicable instruction leaflet.  10.2.6 Mechanical impact  IK10  10.2.7 Inscriptions  Meets the product standard's requirements.  10.3 Degree of protection of ASSEMBLIES  10.4 Clearances and creepage distances  Is the panel builder's responsibility.
10.2.5 Lifting  10 kg per enclosure with support frame and lifting aid met; assembled and se as per the latest applicable instruction leaflet.  10.2.6 Mechanical impact  10.2.7 Inscriptions  Meets the product standard's requirements.  10.3 Degree of protection of ASSEMBLIES  10.4 Clearances and creepage distances  Is the panel builder's responsibility.
as per the latest applicable instruction leaflet.  10.2.6 Mechanical impact  10.2.7 Inscriptions  Meets the product standard's requirements.  10.3 Degree of protection of ASSEMBLIES  10.4 Clearances and creepage distances  Is the panel builder's responsibility.
10.2.7 Inscriptions  Meets the product standard's requirements.  10.3 Degree of protection of ASSEMBLIES  10.4 Clearances and creepage distances  Is the panel builder's responsibility.
10.3 Degree of protection of ASSEMBLIES  10.4 Clearances and creepage distances  Is the panel builder's responsibility.
10.4 Clearances and creepage distances  Is the panel builder's responsibility.
10.5 Protection against electric shock
1 Total against a south of the one of the original against a south of the appropriate of the appropriate of the original against a south of the appropriate of the original against a south original against a south of the original against a south of the original against a south original ag
10.6 Incorporation of switching devices and components Is the panel builder's responsibility.
10.7 Internal electrical circuits and connections Is the panel builder's responsibility.
10.8 Connections for external conductors  Is the panel builder's responsibility.
10.9 Insulation properties
10.9.2 Power-frequency electric strength $U_i = 1000 \text{ V AC}$
10.9.3 Impulse withstand voltage 8 kV
10.9.4 Testing of enclosures made of insulating material Meets the product standard's requirements.
10.10 Temperature rise  The panel builder is responsible for the temperature rise calculation. Eaton v provide heat dissipation data for the devices.
10.11 Short-circuit rating Is the panel builder's responsibility.
10.12 Electromagnetic compatibility Is the panel builder's responsibility.
10.13 Mechanical function Meets the product standard's requirements.

### **Technical data ETIM 7.0**

Distribution boards (EG000023) / Small distribution board (EC000214)

Electric engineering, automation, process control engineering / Electrical installation, device / Electrical distribution system (incl. small distribution board) / Small distribution board (ecl@ss10.0.1-27-14-24-09 [ACN387011])

(ect@ss10.0.1-27-14-24-05 [ACN307011])		
Mounting method		Surface mounted (plaster)
Number of rows		3
Width in number of modular spacings		9
Type of cover		Door
Cover model		Closed
Transparent cover/door		Yes
Material housing		Plastic
Height	mm	375
Width	mm	250
Depth	mm	150
Built-in depth	mm	100
Internal depth	mm	150
DIN-rail		Yes
With mounting plate		No
Extension possible		No
EMC-version		No
Colour		Grey
RAL-number		7035
Degree of protection (IP)		IP65
With lock		No

### **Dimensions**

