Panasonic

PROGRAMMABLE DISPLAY

GT series User's Manual

[Applicable Models]
• GT01 / GT11 / GT21

- GT02 / GT02L / GT05 / GT12 / GT32
- GT03-E / GT32-R / GT32-E

Safety Precautions

Observe the following notices to ensure personal safety or to prevent accidents.

To ensure that you use this product correctly, read this User's Manual thoroughly before use.

Make sure that you fully understand the product and information on safety.

This manual uses two safety flags to indicate different levels of danger.

WARNING

If critical situations that could lead to user's death or serious injury is assumed by mishandling of the product:

- Always take precautions to ensure the overall safety of your system, so that the whole system remains safe in the event of failure of this product or other external factor.
- DO NOT USE THE PROGRAMMABLE DISPLAY TO CONTROL SAFETY FEATURES OR OTHER CRITICAL OPERATIONS OF EQUIPMENT OR SYSTEMS. A COMMUNICATION ERROR (FOR ANY REASON) MIGHT PREVENT SUCH SAFETY FEATURES OR CRITICAL OPERATIONS FROM FUNCTIONING PROPERLY.
- Do not use this product in areas with inflammable gas. It could lead to an explosion.
- Exposing this product to excessive heat or open flames could cause damage to the lithium battery or other electronic parts.
- Battery may explode if mistreated. Do not recharge, disassemble or dispose of fire.

CAUTION

If critical situations that could lead to user's injury or only property damage is assumed by mishandling of the product.

- To prevent excessive exothermic heat or smoke generation, use this product at the values less than the maximum of the characteristics and performance that are assured in these specifications.
- Do not dismantle or remodel the product. It could cause excessive exothermic heat or smoke generation.
- Do not touch the terminal while turning on electricity. It could lead to an electric shock.
- Use the external devices to function the emergency stop and interlock circuit.
- Connect the wires or connectors securely.
 - The loose connection could cause excessive exothermic heat or smoke generation.
- Do not allow foreign matters such as liquid, flammable materials, metals to go into the inside of the product. It could cause excessive exothermic heat or smoke generation.
- Do not undertake construction (such as connection and disconnection) while the power supply is on. It could lead to an electric shock.
- The control force of the touch switches should be less than the specification of the product. Failure to do so could lead to a damage to the product or a personal injury.
- These touch switches operate using analog resistance membrane. Do not press more than one point on the screen at a time. Doing so might operate a switch located in the middle of the points pressed if one exists, and could lead to a damage to the facility or an accident.

Copyright / Trademarks

- This manual and its contents are copyrighted.
- You may not copy this manual in whole or part, without written consent of Panasonic Industrial Devices SUNX Co., Ltd.
- Windows is a registered trademark of Microsoft Corporation in the United States and other countries.
- Ethernet is a registered trademark of Fuji Xerox Co., Ltd. and Xerox Corp.
- SDHC logo and SD logo are trademarks.
- All other company names and product names are trademarks or registered trademarks of their respective owners.

Table of Contents

Before You Start Manual to be Used Available Functions and GT Versions

Chapter 1 Features and Functions	1-1
1.1 Features and Functions of GT Series	1-2
1.2 List of Models	
1.2.1 GT Series Main Unit	
1.2.2 GT Series Main Unit (Discontinued Models)	
1.2.3 Options and Repair Parts	1-11
1.3 Screen Creation Tool	1-13
1.3.1 Tools Required for Screen Creation	1-13
1.3.2 Software Usage Environment and Applicable Cables	1-13
Chapter 2 Names and Functions of Parts	2-1
2.1 Part Names	2-2
2.1.1 GT01 / GT11 / GT21	
2.1.2 GT02 / GT02L	
2.1.3 GT03-E	
2.1.4 GT05 / GT12 / GT32 / GT32-R / GT32-E	2-8
2.2 Terminal Layouts of COM Port	
2.2.1 GT01	2-11
2.2.2 GT02	
2.2.3 GT02L	
2.2.4 GT11 / GT12	
2.2.5 GT03-E / GT21 2.2.6 GT05 / GT32 / GT32-R / GT32-E	
2.2.6 G105 / G132 / G132-R / G132-E	∠-10
2.3 Connecting to Screen Creation Tool GTWIN	
2.3.1 TOOL Port	
2.3.2 USB Port	
2.3.3 Ethernet Port	2-18
Chapter 3 Installation and Wiring	3-1
3.1 Installation	3-2
3.1.1 Installation Environment	
3.1.2 Restriction According to Mounting Directions	
3.1.3 Installation Space	
3.1.4 UL/c-UL Qualification	
3.1.5 Mounting Screws	
3.1.6 GT01 and GT11 Installation Method	3-6

3.1.7 GT21 Installation Method	3-6
3.1.8 GT05 / GT32 / GT32-R / GT32-E Installation Method	3-7
3.1.9 GT02 / GT02L / GT03-E / GT12 Installation Method	3-8
3.1.10 Installing in Vertical Orientation	3-9
3.1.11 Precaution When reinstalling GT	3-9
3.2 Wiring the Power Supply	3-10
3.2.1 Wiring the Power supply	
3.2.2 Grounding	
3.3 Wiring the COM Port	3-12
3.4 Precautions when Wiring COM Port	3-14
3.4.1 GT01 (5 V DC)	
3.4.2 GT02 / GT02L (5 V DC)	
3.4.3 RS232C Communication	
3.4.4 RS422 (RS485) Communication	3-17
3.5 Precautions when Wiring Ethernet Port (GT32T1)	3-18
3.6 Options	
3.6.1 Backup Battery	
3.6.2 How to Install the Battery (Lithium Button Battery)	
3.6.3 How to Install the Battery (Backup Battery)	
3.6.4 Dead Battery Mark	
3.6.5 Time for Replacement of Battery	
3.6.6 Replacement of Front Panel Protective Sheet	
Chapter 4 Connecting with PLC	4-1
4.1 Connection with PLC	
4.1.1 PLC Multiple Connection	
4.1.2 GT Link Connection	
4.1.3 Connecting to the PLCs made by Other Companies	
4.1.4 Connecting to a Serial Device	4-3
4.1.5 Electric Supply from PLC (5 V DC-type)	4-3
4.2 RS232C Connection	
4.2.1 Difference of Terminal blocks Between GT Models	
4.2.2 RS232C Connection with PLC Tool Port	
4.2.3 RS232C Connection with FP-X COM Port	
4.2.4 RS232C Connection with FPΣ COM Port	
4.2.5 RS232C Connection with FP0/FP0R COM Port4.2.6 RS232C Connection with FP-e COM Port	
4.2.7 RS232C Connection with FP-e COM Port	
4.3 RS422 Connection	A-1A
4.3.1 Difference of Terminal blocks Between GT Models	
4.3.2 RS422 Connection with FP-X COM Port	
4.3.3 RS422 Connection with FP2/FP2SH COM Port	
4.3.4 RS422 Connection with C-NET Adapter	

4.4 RS485 Connection	4-18
4.4.1 Difference of Terminal blocks Between GT Models	
4.4.2 RS485 Connection with FP0R COM Port	
4.4.3 RS485 Connection with FP-X COM Port	
4.4.4 RS485 Connection with FPΣ COM Port	
4.4.5 RS485 Connection with FP-e COM Port	
4.4.6 RS485Connection with FP2/FP2SH	
4.4.7 Precautions When Communicating With RS485	
4.5 Connection With a PLC	4-28
4.5.1 Automatic Communication Settings Function	
4.5.2 Through Function	4-29
4.5.3 Communication Settings of PLC using FPWIN GR	4-34
4.5.4 Communication Settings of PLC using FPWIN GR7	4-35
Chapter 5 Troubleshooting	5-1
5.1 What to DO If Something Unusual Occurs (GT01/GT11/ GT21)	
	5-2
5.2 What to DO If Something Unusual Occurs (GT02/GT02L/GT03- E/GT05/GT12/GT32/GT32-R/GT32-E)	5-5
•	
5.3 Error Codes and How to Handle Them	
5.3.1 About Error Codes	
5.3.2 GT Series Error Codes	
5.3.3 When Connected to a FP Series PLC	
5.3.4 When Connected to a PLC (FX Series) Made by Mitsubishi Electric Corporation	
5.3.5 When Connected to a PLC Made by Omron Corporation	
5.3.6 When Connected to Modbus	
5.3.7 When Connected to a PLC Made by Toshiba Machine Co., Ltd	
Chapter 6 Specifications	6-1
6.1 GT01	
6.1.1 General Specifications	
6.1.2 Performance Specifications (GT01)	6-3
6.1.3 Function Specifications (GT01)	6-4
6.1.4 Interface Specifications (GT01)	6-5
6.2 GT02	6-6
6.2.1 General Specifications (GT02)	6-6
6.2.2 Performance Specifications (GT02)	
6.2.3 Function Specifications (GT02)	
6.2.4 Interface Specifications (GT02)	6-9
6.3 GT02L	
6.3.1 General Specifications (GT02L)	
6.3.2 Performance Specifications (GT02L)	
6.3.3 Function Specifications (GT02L)	6-12 6-13
6.3.4 Interface Specifications (GTUZE)	() = 1.5

6.4 GT03-E	6-14
6.4.1 General Specifications (GT03-E)	
6.4.2 Performance Specifications (GT03-E)	6-15
6.4.3 Function Specifications (GT03-E)	
6.4.4 Interface Specifications (GT03-E)	6-17
6.5 GT05	
6.5.1 General Specifications	
6.5.2 Performance Specifications (GT05)	
6.5.3 Function Specifications (GT05)	
6.5.4 Interface Specifications (G105)	0-21
6.6 GT11	
6.6.1 General Specifications (GT11)	
6.6.3 Function Specifications (GT11)	
6.6.4 Interface Specifications (GT11)	
6.7 GT12	6-26
6.7.1 General Specifications (GT12)	
6.7.2 Performance Specifications (GT12)	
6.7.3 Function Specifications (GT12)	
6.7.4 Interface Specifications (GT12)	6-29
6.8 GT21	
6.8.1 General Specifications (GT21)	
6.8.2 Performance Specifications (GT21)	
6.8.3 Function Specifications (GT21)	
6.9 GT32	6-24
6.9.1 General Specifications (GT32)	
6.9.2 Performance Specifications (GT32)	
6.9.3 Function Specifications (GT32)	
6.9.4 Interface Specifications (GT32)	
6.9.5 Sound Output Specifications (GT32T1 Only)	
6.10 GT32-R	6-39
6.10.1 General Specifications (GT32-R)	6-39
6.10.2 Performance Specifications (GT32-R)	6-40
6.10.3 Function Specifications (GT32-R)	
6.10.4 Interface Specifications (GT32-R)	6-42
6.11 GT32-E	
6.11.1 General Specifications (GT32-E)	6-43
6.11.2 Performance Specifications (GT32-E)	
6.11.3 Function Specifications (GT32-E)	
Chapter 7 Dimensions and Other Documentation	7-1
7.1 Dimensions	7-2

7.1.1 GT01/GT01R	7-2
7.1.2 GT02	
7.1.3 GT02L	7-4
7.1.4 GT03M-E	7-5
7.1.5 GT03T-E	7-6
7.1.6 GT05	7-7
7.1.7 GT11	7-8
7.1.8 GT12	7-9
7.1.9 GT21	
7.1.10 GT32	7-11
7.1.11 GT32-R / GT32-E	
7.2 Cable Specifications	7-13
7.2.1 AIGT8142	7-13
7.2.2 AIGT8152	7-13
7.2.3 AIGT8160/AIGT8162/AIGT8165/AIGT8192	7-13
7.2.4 AIGT8175	7-14
7.2.5 AIP81842	7-14
7.3 BIN/HEX/BCD Code Correspondence Table	7-15
7.4 ASCII Code Table	7-16

Record of changes

Before You Start

Usage conditions

Operating environment (Use the unit within the range of the general specifications when installing)

- Ambient temperatures: 0 to +50 °C
 (It varies according to models when installing the unit in a horizontal orientation or using a C-NET adapter and FP programmer II.)
- Ambient humidity should be 20 to 85% RH (at 25 °C) and non-condensing.
- Usable altitude: Altitude 2,000 m or less
- For use in pollution Degree 2 environment
- Do not use it in the following environments.
 - Direct sunlight, wind and rain. (This product is not designed for outdoor use.)
 - Sudden temperature changes causing condensation.
 - Inflammable or corrosive gas.
 - Excessive airborne dust, metal particles or saline matter.
 - Benzine, paint thinner, alcohol or other organic solvents or strong alkaline solutions such as ammonia or caustic soda.
 - Direct vibration, shock or places always exposed to drop of water.
 (This unit is warranted by IP65/IP67 (depending on models) for panel mounting, however, this applies to initial values.)
 - Influence from power transmission lines, high voltage equipment, power cables, power equipment, radio transmitters, or any other equipment that would generate high switching surges. (100 mm or more)

The usage conditions for Tough series (GT03-E/GT32-E) are as follows.

- Ambient temperatures: -20 to +60 °C (In horizontal orientation, when sitting upright in vertical orientation or when using a battery: -20 to +55 °C)
- Ambient humidity should be 10 to 90% RH (at 25 °C) and non-condensing.
 - The upper limit of the humidity at each temperature is as below. (Below 40 °C; 90%RH, 50 °C; 55%RH, 60 °C; 35%RH)
 - If the product is exposed to heavy rain, condensation might be caused by sudden temperature changes.
- Usable altitude: Altitude 2,000 m or less
- For use in pollution Degree 2 environment
- Overvoltage category: II
- Do not use it in the following environments.
- Direct sunlight for a long time
- (Exposing the product to direct sunlight increases the surface temperature of the display higher than ambient temperature, and causes deterioration of LDC panel.)
- Inflammable or corrosive gas.
- Excessive airborne dust, metal particles or saline matter.
- Benzine, paint thinner, alcohol or other organic solvents or strong alkaline solutions such as ammonia or caustic soda.
- Direct vibration, shock or places always exposed to drop of water.
 (This unit is warranted by IP67 for panel mounting, however, this applies to initial values.)
- Influence from power transmission lines, high voltage equipment, power cables, power equipment, radio transmitters, or any other equipment that would generate high switching surges. (100 mm or more)

Static electricity

- Do not touch connector pins directly to prevent static electricity from causing damage.
- Always rid yourself of any static electricity before handling this product.
- If excessive static electricity is applied to the panel surface, the LCD panel unit may be damaged.

Power supply

- Twist the wires of the power supply.
- The unit has sufficient noise immunity against the noise generated on the power line. However, it is recommended to take measures for reducing noise such as using an isolating transformer before supplying the power. And it is recommended to take measures such as installing a ferrite core.
- Allocate an independent wiring for each power supplying line, PLC etc and operating device.
- If using a power supply without a protective circuit, power should be supplied through a protective element such as fuse. Directly applying an abnormal voltage to the unit may cause the damage to the internal circuit.

Touch switches

- Always operate the touch switch with fingers. As the touch switch may be damaged due to the excessive load or shock (caused when being operated with any tools), the touch switch should be operated within the specified control force. Also, if the touch switch is pressed like kneading, the electrode may be worn out exceptionally, and cause the malfunction. Operate with a single touch of the switch.
- The touch position may shift due to aging variation. If the touch position has shifted, please adjust it.

LCD panel

- Do not drop or have a strong impact on the programmable display unit as glass is used for the LCD panel.
- The liquid in the LCD panel is a hazardous substance. If the LCD panel is broken, do not put the leaked crystalline liquid into your mouth. Should it get into your mouth, immediately gargle, and consult a doctor. If it adheres to your skin or clothes, wash it away with soap.
- On the LCD panel, bright spots (points always lit) or black spots (points always unlit) may appear, or the uneven brightness, flickers or crosstalk (appearance of unintended shades in the area no graphic or part is arranged) may occur depending on the operating conditions. Note that these phenomena are resulted from the basic characteristics of LCD panel not defects or failures of the product.

Battery

Do not leave the battery in the unit when it is not used. There is a possibility of leak if it is left being discharged.

Scratch protection sheet

A sheet is affixed to the touch panel to protect it from scratches when shipping. Please remove it before using the GT.

Manuals to be Used

- The manuals to be used for GT series are common to all the models.

GT series User's Manual ARCT1F511E

- It is this manual. This manual describes the characteristics, specifications, installation and connections of each GT models.

GT series Reference Manual ACGM0357V**EN

- This manual describes the screen creation of GT series and the settings of various functions.

General-purpose Serial Communication Manual ARCT1F356E

- It is required when communication is carried out with devices you developed such as a board and PC.

Connection with Other Companies' PLCs Manual ARCT1F449E

It is a manual describing the connection methods with PLCs manufactured by other companies. The connection methods with Panasonic PLCs are described in this manual.



Key Point: - The PDF versions are provided at our website.

http://industrial.panasonic.com/ac/e/dl_center/manual/ (User registration is required. Free of charge)

Available Functions and GT Versions

We recommend to keep GT-series products up to date for use as usable functions will increase according to the upgrade.

The latest version of GT can be installed by the tool.

The upgrade of GTWIN is also necessary according to the upgrade of GT.

Version of GT01 and available functions

Function			GT01	GTWIN
Parts	Switch		1.00 or later	2.30 or later
library	Lamp		1.00 or later	2.30 or later
	Message		1.00 or later	2.30 or later
	Data		1.00 or later	2.30 or later
	Bar graph		1.00 or later	2.30 or later
	Clock		1.00 or later Note1)	2.30 or later
	Line graph		1.00 or later	2.30 or later
	Alarm	History	Not available	Not available
	Alami	List	Not available	Not available
	Keyboard		1.00 or later	2.30 or later
	Custom		1.00 or later 2.30 or late	
Other	Recipe	Recipe	1.00 or later	2.30 or later
functions		SD recipe	Not available	Not available
	Flow display		1.00 or later	2.30 or later
	Write device	9	1.00 or later	2.30 or later
	Sound		Not available	Not available
	Password	Password	1.00 or later	2.30 or later
		Operation security	Not available	Not available
	Multi language exchange		1.20 or later	2.50 or later
	Logging fun	ction	Not available	Not available
	Display pan	el sideways setting	1.10 or later	2.40 or later
	Conv	Cable between GTs	1.30 or later	-
	Сору	SD memory card	Not available	Not available
	GT link		Not available	Not available
	PLC multipl	e connection	Not available	Not available
	Countdown	timer	Not available	Not available
	180 degrees	s rotation	Not available	Not available

Note1) Only referring to PLC can be set.

Version of GT02 and available functions

Function			GT02M2 GT02G2	GT02M0 GT02M1 GT02G0 GT02G1	GTWIN
Parts	Switch		1.00 or later	1.00 or later	2.A0 or later
library	Lamp		1.00 or later	1.00 or later	2.A0 or later
	Message		1.00 or later	1.00 or later	2.A0 or later
	Data		1.00 or later	1.00 or later	2.A0 or later
	Bar graph		1.00 or later	1.00 or later	2.A0 or later
	Clock		1.00 or later	1.00 or later Note1)	2.A0 or later
	Line graph		1.00 or later	1.00 or later	2.A0 or later
	Alarm	History	1.00 or later	Not available	2.A0 or later
	Alailii	List	1.00 or later	1.00 or later	2.A0 or later
	Keyboard		1.00 or later	1.00 or later	1.00 or later
	Custom		1.00 or later	1.00 or later	1.00 or later
Other	Recipe	Recipe	1.00 or later	1.00 or later	2.A0 or later
functions	Recipe	SD recipe	1.00 or later	Not available	2.A0 or later
	Flow display	у	1.00 or later	1.00 or later	2.A0 or later
	Write device	е	1.00 or later	1.00 or later	2.A0 or later
	Sound		Not available	Not available	Not available
	Password	Password	1.00 or later	1.00 or later	2.A0 or later
	Password	Operation security	1.00 or later	1.00 or later	2.A0 or later
	Multi langua	age exchange	1.00 or later	1.00 or later	2.A0 or later
	Logging fun	ction	1.00 or later	Not available	2.A0 or later
	FP monitor	function	1.30 or later	1.30 or later	2.C0 or later
	Display pan	el sideways setting	1.00 or later	1.00 or later	2.A0 or later
	Conv	Cable between GTs	Not available	Not available	Not available
	Copy SD memory card		1.00 or later	Not available	2.A0 or later
	GT link PLC multiple connection		1.00 or later	1.00 or later	2.A0 or later
			1.00 or later	1.00 or later	2.A0 or later
	Countdown	timer	1.70 or later	1.70 or later	2.F0 or later
	180 degrees rotation		Not available	Not available	Not available

Note1) Only referring to PLC can be set.

Version of GT02L and available functions

Function			GT02L	GTWIN
Parts	Switch		1.00 or later	2.B0 or later
library	Lamp		1.00 or later	2.B0 or later
	Message		1.00 or later	2.B0 or later
	Data		1.00 or later	2.B0 or later
	Bar graph		1.00 or later	2.B0 or later
	Clock		1.00 or later Note1)	2.B0 or later
	Line graph		1.00 or later	2.B0 or later
	A.1 =	History	Not available	2.B0 or later
	Alarm	List	1.00 or later	2.B0 or later
	Keyboard	•	1.00 or later	1.00 or later
	Custom		1.00 or later	1.00 or later
Other	Desire	Recipe	1.00 or later	2.B0 or later
functions	Recipe	SD recipe	Not available	2.B0 or later
	Flow display		1.00 or later	2.B0 or later
	Write device		1.00 or later	2.B0 or later
	Sound		Not available	Not available
	Password	Password	1.00 or later	2.B0 or later
		Operation security	1.00 or later	2.B0 or later
	Multi language exchange		1.00 or later	2.B0 or later
	Logging fur	nction	Not available	Not available
	FP monitor	function	1.20 or later	2.C0 or later
	Display par	nel sideways setting	1.00 or later	2.B0 or later
	Comit	Cable between GTs	Not available	Not available
	Сору	SD memory card	Not available	Not available
	GT link		1.00 or later	2.B0 or later
	PLC multipl	le connection	1.00 or later	2.B0 or later
	Countdown	timer	1.60 or later	2.F0 or later
	180 degrees rotation		Not available	Not available

Note1) Only referring to PLC can be set.



The buzzer function is not available for GT02L. All the functions related to the buzzer are unsupported.

Version of GT03-E and available functions

Function		GT03M-E	GT03T-E	GTWIN	
Parts	Switch		1.00 or later	1.10 or later	2.E1 or later
library	Lamp		1.00 or later	1.10 or later	2.E1 or later
	Message		1.00 or later	1.10 or later	2.E1 or later
	Data		1.00 or later	1.10 or later	2.E1 or later
	Bar graph		1.00 or later	1.10 or later	2.E1 or later
	Clock		1.00 or later Note1)	1.10 or later	2.E1 or later
	Line graph		1.00 or later	1.10 or later	2.E1 or later
	A La was	History	Not available	1.10 or later	2.E1 or later
	Alarm	List	1.00 or later	1.10 or later	2.E1 or later
	Keyboard		1.00 or later	1.10 or later	2.E1 or later
	Custom		1.00 or later	1.10 or later	2.E1 or later
Other	Recipe	Recipe	1.00 or later	1.10 or later	2.E1 or later
functions		SD recipe	Not available	1.10 or later	2.E1 or later
	Flow display		1.00 or later	1.10 or later	2.E1 or later
	Write device		1.00 or later	1.10 or later	2.E1 or later
	Sound		Not available	Not available	Not available
	Password	Password	1.00 or later	1.10 or later	2.E1 or later
	Password	Operation security	1.00 or later	1.10 or later	2.E1 or later
	Multi language exchange		1.00 or later	1.10 or later	2.E1 or later
	Logging function	on	Not available	1.10 or later	2.E1 or later
	FP monitor fur	ction	1.00 or later	1.10 or later	2.E1 or later
	Display panel sideways setting		1.00 or later	1.10 or later	2.E1 or later
	Conv	Cable between GTs	Not available	Not available	Not available
	Сору	SD memory card	Not available	1.10 or later	2.E1 or later
	GT link		1.00 or later	1.10 or later	2.E1 or later
	PLC multiple of	onnection	1.00 or later	1.10 or later	2.E1 or later
	Countdown tim	ner	1.10 or later	1.10 or later	2.F0 or later
i	180 degrees rotation		1.10 or later	1.10 or later	2.F0 or later

Note1) Only referring to PLC can be set.

Version of GT05 and available functions

Function			GT05	GTWIN
Parts	Switch		1.00 or later	2.90 or later
library	Lamp		1.00 or later	2.90 or later
	Message		1.00 or later	2.90 or later
	Data		1.00 or later	2.90 or later
	Bar graph		1.00 or later	2.90 or later
	Clock		1.00 or later	2.90 or later
	Line graph		1.00 or later	2.90 or later
	Alexan	History	1.00 or later	2.90 or later
	Alarm	List	1.00 or later	2.90 or later
	Keyboard		1.00 or later	2.90 or later
	Custom		1.00 or later	2.90 or later
Other	Dooing	Recipe	1.00 or later	2.90 or later
functions	Recipe	SD recipe	1.60 or later	2.A0 or later
	Flow display		1.00 or later	2.90 or later
	Write device		1.00 or later	2.90 or later
	Sound		Not available	Not available
	Password	Password	1.00 or later	2.90 or later
		Operation security	1.10 or later	2.94 or later
	Multi language	e exchange	1.00 or later	2.90 or later
	Logging functi	on	1.40 or later	2.98 or later
	FP monitor fu	nction	1.90 or later	2.C0 or later
	Display panel	sideways setting	2.00 or later	2.C1 or later
	Conv	Cable between GTs	Not available	Not available
	Сору	SD memory card	1.00 or later	2.90 or later
	GT link		1.10 or later	2.94 or later
	PLC multiple	connection	1.30 or later	2.97 or later
	Countdown tir	ner	2.30 or later	2.F0 or later
	180 degrees r	otation	Not available	Not available

Version of GT11 and available functions

Function			GT11	GTWIN
Parts	Switch		1.00 or later	2.60 or later
library	Lamp		1.00 or later	2.60 or later
	Message		1.00 or later	2.60 or later
	Data		1.00 or later	2.60 or later
	Bar graph		1.00 or later	2.60 or later
	Clock		1.00 or later Note1)	2.60 or later
	Line graph		1.00 or later	2.60 or later
	Alarm	History	1.00 or later	2.60 or later
	Alaim	List	1.00 or later	2.60 or later
	Keyboard		1.00 or later	2.60 or later
	Custom		1.00 or later	2.60 or later
Other	Paging	Recipe	1.00 or later	2.60 or later
functions	Recipe	SD recipe	Not available	Not available
	Flow display	,	1.00 or later	2.60 or later
	Write device		1.00 or later	2.60 or later
	Sound		Not available	Not available
	Password	Password	1.00 or later	2.60 or later
		Operation security	Not available	Not available
	Multi langua	ge exchange	1.00 or later	2.60 or later
	Logging fund	ction	Not available	Not available
	Display pane	el sideways setting	1.00 or later	2.60 or later
	Conv	Cable between GTs	1.20 or later	•
	Сору	SD memory card	Not available	Not available
	GT link		Not available	Not available
	PLC multiple	econnection	Not available	Not available
	Countdown timer		Not available	Not available
	180 degrees	rotation	Not available	Not available

Note1) Summer time cannot be set.

Version of GT12 and available functions

Function			GT12M1	GT12M0	GTWIN
			GT12G1	GT12G0	
Parts	Switch		1.00 or later	1.00 or later	2.97 or later
library	Lamp		1.00 or later	1.00 or later	2.97 or later
	Message		1.00 or later	1.00 or later	2.97 or later
	Data		1.00 or later	1.00 or later	2.97 or later
	Bar graph		1.00 or later	1.00 or later	2.97 or later
	Clock		1.00 or later	1.00 or later	2.97 or later
	Line graph		1.00 or later	1.00 or later	2.97 or later
	Alarm	History	1.00 or later	1.00 or later	2.97 or later
	Alami	List	1.00 or later	1.00 or later	2.97 or later
	Keyboard		1.00 or later	1.00 or later	2.97 or later
	Custom		1.00 or later	1.00 or later	2.97 or later
Other	Paging	Recipe	1.00 or later	1.00 or later	2.97 or later
functions	Recipe	SD recipe	1.20 or later	Not available	2.A0 or later
	Flow display		1.00 or later	1.00 or later	2.97 or later
	Write device	e	1.00 or later	1.00 or later	2.97 or later
	Sound		Not available	Not available	Not available
	Password	Password	1.00 or later	1.00 or later	2.97 or later
	Fassword	Operation security	1.00 or later	1.00 or later	2.97 or later
	Multi langu	age exchange	1.00 or later	1.00 or later	2.97 or later
	Logging fur	nction	1.10 or later	Not available	2.98 or later
	FP monitor	function	1.60 or later	1.60 or later	2.C0 or later
	Display par	nel sideways setting	1.00 or later	1.00 or later	2.97 or later
	Conv	Cable between GTs	Not available	Not available	Not available
	Сору	SD memory card	1.00 or later	Not available	2.97 or later
	GT link		1.00 or later	1.00 or later	2.97 or later
	PLC multip	le connection	1.00 or later	1.00 or later	2.97 or later
	Countdown	n timer	1.A0 or later	1.A0 or later	2.F0 or later
	180 degree	180 degrees rotation		Not available	Not available

Version of GT21 and available functions

Function			GT21	GTWIN
Parts	Switch		1.00 or later	2.70 or later
library	Lamp		1.00 or later	2.70 or later
	Message		1.00 or later	2.70 or later
	Data		1.00 or later	2.70 or later
	Bar graph		1.00 or later	2.70 or later
	Clock		1.00 or later Note1)	2.70 or later
	Line graph		1.00 or later	2.70 or later
	Alarm	History	1.00 or later	2.70 or later
	Alaim	List	1.00 or later	2.70 or later
	Keyboard		1.00 or later	2.70 or later
	Custom		1.00 or later	2.70 or later
Other	Recipe	Recipe	1.00 or later	2.70 or later
functions		SD recipe	Not available	Not available
	Flow display	,	1.00 or later	2.70 or later
	Write device	r	1.00 or later	2.70 or later
	Sound		Not available	Not available
	Password	Password	1.00 or later	2.70 or later
	Password	Operation security	Not available	Not available
	Multi langua	ge exchange	1.00 or later	2.70 or later
	Logging fund	ction	Not available	Not available
	Display pane	el sideways setting	1.10 or later	2.71 or later
	Conv	Cable between GTs	1.10 or later	•
	Сору	SD memory card	Not available	Not available
	GT link		Not available	Not available
	PLC multiple	connection	Not available	Not available
	Countdown	timer	Not available	Not available
	180 degrees	rotation	Not available	Not available

Note1) Summer time cannot be set.

Version of GT32 and available functions

Function			GT32M	GT32T1	GTWIN
			GT32T0		
Parts	Switch		1.00 or later	1.00 or later	2.80 or later
library	Lamp		1.00 or later	1.00 or later	2.80 or later
	Message		1.00 or later	1.00 or later	2.80 or later
	Data		1.00 or later	1.00 or later	2.80 or later
	Bar graph		1.00 or later	1.00 or later	2.80 or later
	Clock		1.00 or later	1.00 or later	2.80 or later
	Line graph		1.00 or later	1.00 or later	2.80 or later
	Alarm	History	1.00 or later	1.00 or later	2.80 or later
	Alaim	List	1.00 or later	1.00 or later	2.80 or later
	Keyboard		1.00 or later	1.00 or later	2.80 or later
	Custom		1.00 or later	1.00 or later	2.80 or later
Other	Recipe	Recipe	1.00 or later	1.00 or later	2.80 or later
functions		SD recipe	1.60 or later	1.60 or later	2.A0 or later
	Flow display	1	1.00 or later	1.00 or later	2.80 or later
	Write device)	1.00 or later	1.00 or later	2.80 or later
	Sound		Not available	1.00 or later	2.80 or later
	Password	Password	1.00 or later	1.00 or later	2.80 or later
	Password	Operation security	1.20 or later	1.20 or later	2.94 or later
	Multi langua	ge exchange	1.00 or later	1.00 or later	2.80 or later
	Logging fund	ction	1.50 or later	1.50 or later	2.98 or later
	FP monitor f	unction	2.00 or later	2.00 or later	2.C0 or later
	Display pan	el sideways setting	2.10 or later	2.10 or later	2.C1 or later
	Conv	Cable between GTs	Not available	Not available	Not available
	Сору	SD memory card	1.00 or later	1.00 or later	2.80 or later
	GT link		1.20 or later	1.20 or later	2.94 or later
	PLC multiple	e connection	1.40 or later	1.40 or later	2.97 or later
	Countdown	timer	2.40 or later	2.40 or later	2.F0 or later
	180 degrees	rotation	Not available	Not available	Not available

Version of GT32-R and available functions

Function			GT32M-R	GT32T-R	GTWIN
Parts	Switch		1.40 or later	1.40 or later	2.F0 or later
library	Lamp		1.40 or later	1.40 or later	2.F0 or later
	Message		1.40 or later	1.40 or later	2.F0 or later
	Data		1.40 or later	1.40 or later	2.F0 or later
	Bar graph		1.40 or later	1.40 or later	2.F0 or later
	Clock		1.40 or later	1.40 or later	2.F0 or later
	Line graph		1.40 or later	1.40 or later	2.F0 or later
	Alarm	History	1.40 or later	1.40 or later	2.F0 or later
	Alaim	List	1.40 or later	1.40 or later	2.F0 or later
	Keyboard		1.40 or later	1.40 or later	2.F0 or later
	Custom		1.40 or later	1.40 or later	2.F0 or later
Other	Recipe	Recipe	1.40 or later	1.40 or later	2.F0 or later
functions		SD recipe	1.40 or later	1.40 or later	2.F0 or later
	Flow display	1	1.40 or later	1.40 or later	2.F0 or later
	Write device	•	1.40 or later	1.40 or later	2.F0 or later
	Sound		Not available	Not available	Not available
	Password	Password	1.40 or later	1.40 or later	2.F0 or later
	Password	Operation security	1.40 or later	1.40 or later	2.F0 or later
	Multi langua	ge exchange	1.40 or later	1.40 or later	2.F0 or later
	Logging fund	ction	1.40 or later	1.40 or later	2.F0 or later
	FP monitor f	unction	1.40 or later	1.40 or later	2.F0 or later
	Display pan	el sideways setting	1.40 or later	1.40 or later	2.F0 or later
	Conv	Cable between GTs	Not available	Not available	Not available
	Сору	SD memory card	1.40 or later	1.40 or later	2.F0 or later
	GT link		1.40 or later	1.40 or later	2.F0 or later
	PLC multiple	e connection	1.40 or later	1.40 or later	2.F0 or later
	Countdown	timer	1.40 or later	1.40 or later	2.F0 or later
	180 degrees	rotation	1.40 or later	1.40 or later	2.F0 or later

Version of GT32-E and available functions

Function			GT32M-E	GT32T1-E	GTWIN
Parts	Switch		1.00 or later	1.00 or later	2.C0 or later
library	Lamp	Lamp		1.00 or later	2.C0 or later
	Message		1.00 or later	1.00 or later	2.C0 or later
	Data		1.00 or later	1.00 or later	2.C0 or later
	Bar graph		1.00 or later	1.00 or later	2.C0 or later
	Clock		1.00 or later	1.00 or later	2.C0 or later
	Line graph		1.00 or later	1.00 or later	2.C0 or later
	A I a was	History	1.00 or later	1.00 or later	2.C0 or later
	Alarm	List	1.00 or later	1.00 or later	2.C0 or later
	Keyboard		1.00 or later	1.00 or later	2.C0 or later
	Custom		1.00 or later	1.00 or later	2.C0 or later
Other	Desine	Recipe	1.00 or later	1.00 or later	2.C0 or later
functions	Recipe	SD recipe	1.00 or later	1.60 or later	2.C0 or later
	Flow display	1	1.00 or later	1.00 or later	2.C0 or later
	Write device)	1.00 or later	1.00 or later	2.C0 or later
	Sound		Not available	Not available	Not available
	Deserverd	Password	1.00 or later	1.00 or later	2.C0 or later
	Password	1.00 or later	1.00 or later	1.20 or later	2.C0 or later
	Multi langua	ige exchange	1.00 or later	1.00 or later	2.C0 or later
	Logging fun	ction	1.00 or later	1.00 or later	2.C0 or later
	FP monitor	function	1.00 or later	1.00 or later	2.C0 or later
	Display pan	el sideways setting	1.10 or later	1.10 or later	2.C1 or later
	Conv	Cable between GTs	Not available	Not available	Not available
	Сору	1.00 or later	1.00 or later	1.00 or later	2.C0 or later
	GT link		1.00 or later	1.00 or later	2.C0 or later
	PLC multiple	e connection	1.00 or later	1.00 or later	2.C0 or later
	Countdown	timer	1.40 or later	1.40 or later	2.F0 or later
	180 degrees	s rotation	1.40 or later	1.40 or later	2.F0 or later

Change history							
GTWIN	GT-series version	Additional functions					
Ver. 2.80	GT32 Ver. 1.00	- New model					
ver. 2.60	(New release)	- New Model - Equipped a SD memory card slot.					
	(New Telease)	- Sound function					
Ver. 2.90	GT05 Ver. 1.00	- New model					
	(New release)						
Ver. 2.94	GT05 Ver. 1.10	- Operation security function					
Ver. 2.96	GT32 Ver. 1.20 GT01 Ver. 1.35	- GT link function					
ver. 2.96	GT01 Ver. 1.35 GT05 Ver. 1.20	Touch sound disable flag in Basic communication area (Bit area)					
	GT11 Ver. 1.25	(Bit area)					
	GT21 Ver. 1.15						
	GT32 Ver. 1.30						
Ver. 2.97	GT05 Ver. 1.30	- New model					
	GT12 Ver. 1.00 (New release)	- "Multi Function" function - PLC multiple connection					
	GT32 Ver. 1.40	- PLC multiple connection - Display/Hide of data parts					
		- Modbus slave function					
		- Added 4096-color parts library.					
	GT01 Ver.1.35	- Modbus slave function					
	GT11 Ver.1.25						
Ver. 2.98	GT21 Ver.1.15 GT05 Ver. 1.40	- Logging function					
Ver. 2.30	GT12 Ver. 1.10	- Index modifier of data parts					
	GT32 Ver. 1.50	- Display/Hide of switch parts					
		- Display of data parts in kana and Chinese character,					
		- kana input of keyboard parts Unit number setting on GT					
		when using General-purpose serial - SD memory card copy to password-protected GT					
		- Connection between multiple units with Modbus(RTU) master					
		- Output to Panasonic FP series "X" device.					
		- Jump to the previous screen from "Screen No. Error" screen					
		- Reverse display function					
	GT01 Ver. 1.37 GT11 Ver. 1.27	- Jump to the previous screen from "Screen No. Error" screen - Reverse display function					
Ver.2.983	GT05 Ver.1.42	Bug fixing					
V 01.2.000	GT12 Ver.1.12	Bug lixing					
	GT32 Ver.1.52						
Ver.2.99	GT05 Ver.1.50	- Functions for devices such as Temperature control device of					
	GT12 Ver.1.20	MODBUS (RTU mode)					
	GT32 Ver.1.60	- Display of data parts in Chinese and Korean - Graph display of logging device data for logging function					
		- Bar graph of line graph parts					
		- Fixed line of line graph parts					
		- Supports SDHC memory card					
Var 0 40	- OT00 \/- = 4.00	- Display/Hide of keyboard parts in GTWIN					
Ver.2.A0	GT02 Ver.1.00 (New release)	- New model					
	GT05 Ver.1.60	- SD recipe function					
	GT12 Ver.1.30	- Function for communication errors in case of PLC multiple					
	GT32 Ver.1.70	connection					
		- Alarm history data save in SD memory card					
	GT05 Ver.1.40	- Multiplication and division of write device data					
	GT05 Ver.1.40 GT12 Ver.1.30	- Multiplication and division of write device data					
	GT32 Ver.1.20						
Ver.2.B0	GT02L Ver.1.00	- New model (GT02L)					
	(New release)	, , ,					
	GT02 Ver.1.10	- True Type font for data parts					
	GT05 Ver.1.70 GT12 Ver.1.40						
	GT12 Ver.1.40 GT32 Ver.1.80						
	0102 VGI.1.00						

GTWIN version	GT-series version	Additional functions
Ver.2.B1	GT01 Ver.1.39 GT02 Ver.1.11 GT02L Ver.1.01 GT05 Ver.1.71 GT11 Ver.1.29 GT12 Ver.1.41 GT21 Ver.1.19 GT32 Ver.1.81	-Bug fixing
Ver.2.C0	GT02 Ver.1.30 GT02L Ver.1.20 GT05 Ver.1.90 GT12 Ver.1.60 GT32 Ver.2.00 GT32-E Ver.1.00	 New model (GT32-E) FP monitor function Added the mode to ignore CS/RS when using general-purpose serial communication. Fixed font conversion function
Ver.2.C1	GT02 Ver.1.40 GT02L Ver.1.30 GT05 Ver.2.00 GT12 Ver.1.70 GT32 Ver.2.10 GT32-E Ver.1.10	 Vertical type display (GT05/GT32/GT32-E) Supports TFT LCD (GT05 color) Device change function Added the SD memory card installation flag in Basic Communication Area. Added parts library.
Ver. 2.C2	GT02 Ver.1.41 GT02L Ver.1.31 GT05 Ver.2.01 GT12 Ver.1.71 GT32 Ver.2.11 GT32-E Ver.1.11	Contrast adjustment function in GT Configuration settings (GT02/GT02L/GT12) Bug fixing
Ver. 2.D0	GT02 Ver.1.50 GT02L Ver.1.40 GT05 Ver.2.10 GT12 Ver.1.80 GT32 Ver.2.20 GT32-E Ver.1.20	- Supports FP7 Supports the 64-bit Windows 7.
Ver. 2.E0	GT02 Ver.1.60 GT02L Ver.1.50 GT03-E Ver.1.00 (New release) GT05 Ver.2.20 GT12 Ver.1.90 GT32 Ver.2.30 GT32-E Ver.1.30	- New model (GT03M-E)
Ver. 2.E1	GT02 Ver.1.70 GT02L Ver.1.60 GT03-E Ver.1.10 GT05 Ver.2.30 GT12 Ver.2.00 GT32 Ver.2.40 GT32-E Ver.1.40	 New model (GT03T-E) Added the function to upload data in a SD card of GT. Added the CSV output for GT Usage Device. Supports Russian and Vietnamese displays.

GTWIN version	GT-series version	Additional functions
Ver.2.E2	GT02 Ver.1.64	- Disabling data trasmission function
	GT02L Ver.1.54	
	GT03-E Ver.1.04	
	GT05 Ver.2.24	
	GT12 Ver.1.94	
	GT32 Ver.2.34	
	GT32-E Ver.1.34	
Ver.2.E3	GT02 Ver.1.65	- Supports Windows8.
	GT02L Ver.1.55	
	GT03-E Ver.1.05	
	GT05 Ver.2.25	
	GT12 Ver.1.95	
	GT32 Ver.2.35	
	GT32-E Ver.1.35	
Ver.2.F0	GT02 Ver.1.70	- New model (GT32-R)
	GT02L Ver.1.60	- Countdown timer function
	GT03-E Ver.1.10	- 180 degrees rotation display (GT03-E/GT32-R/GT32-E)
	GT05 Ver.2.30	
	GT12 Ver.1.A0	
	GT32 Ver.2.40	
	GT32-R Ver.1.40	
	GT32-E Ver.1.40	
Ver.2.F1	GT05 Ver.2.40	- Supports TFT LCD (GT05 monochrome)
	(Monochrome type	- A USB driver is automatically installed when installing GTWIN
	only)	- Bug fixing


Chapter 1

Features and Functions

1.1 Features and Functions of GT Series

Can be installed in a small space.

As the GT series is a small and thin-shaped body, it can be installed in a small space. Also, as the projecting part from a wall surface is 4 mm, it looks neat after installation. It can be also installed upright.



Number of colors can be selected as usage.

GT series	Number of colors
GT21C	256 colors
GT03T-E/GT05S/GT32T0/GT32T1/GT32T-R/GT32T-E	4096 colors


Monochrome 8-gradation (GT12)/16-gradation (GT32-R/GT32-E/GT03-E) display function is available.

The monochrome 8-gradation and 16-gradation displays can be selected as well as the existing monochrome 2-gradation display, so that the screen can be displayed finely.

Easily shows a current state changing the backlight on the monochrome type.

For the monochrome type (3-color LED backlight type), changing in the backlight color makes it easy to grasp a current state at a glance.

"Green, orange, red" type and "White, red, pink" type is available for the 3-color LED backlight type.



Analog touch panel provided

As an analog touch panel is provided, it allows maximum flexibility in the switch layout and size.

Screens can be created easily, using a special screen creation tool Terminal GTWIN.

Screen contents can be easily created using the dedicated Terminal GTWIN tool. Screens are put together simply by selecting parts from libraries and positioning them in place. Various parts for numerous applications are provided such as 256-color 3D parts.

Screen data of the other models can be used with the model conversion function.

Screen data can be converted from the low-resolution model to high-resolution model, e.g. from GT01 to GT11, from GT21 to GT32.

The communication methods support RS232C/RS422 (RS485)

The communication methods to PLCs support RS232C/RS422(RS485). Also it can be connected to PLCs manufactured by other companies.

Structure adapted to surrounding environments


IP67: GT02 / GT03-E / GT12 / GT32-R / GT32-E IP65: GT01 / GT02L / GT05 / GT11 / GT21 / GT32

High-intensity LED provided (LED backlight type)

As the high-intensity LED is provided, the screen is bright, and the backlight does not need to be replaced.

Saving various data with a SD memory card (Model equipped with SD memory card slot)

Various data can be saved and read out with a SD memory card.



Power can be supplied to the 5 V DC type with only one communication cable.

The power is supplied from the TOOL port of a PLC, therefore, the wiring man-hours can be significantly reduced.



Applicable models:

Panasonic FP series

Mitsubishi Electric Corporation FX series

Three methods are available to switch the screen.


Switching by the instruction from PLC

The screens can be switched by writing to the "basic communication area" from the PLC ladder program.




Switching with the touch-screen operation

The screens can be switched on the GT by using the "function switching parts" provided in the parts library of the GTWIN that has a function to switch the screens.



Switching automatically


The GT man unit has an "Auto-paging" function in the configuration setting that automatically switches the screen to a specified screen number when a certain period of time has elapsed. This function can be used to switch screens automatically.




Through function is convenient for debugging

A convenient "through" function makes it possible to transfer data from the GT and carry out PLC debugging at the same time that communication is going on between the GT and the FP series PLC. This significantly boosts efficiency in the workplace.

For TOOL port models





New functions can be available by upgrading the GT.

The GT can be easily upgraded by downloading the latest firmware from our website or using the GT Ver_UP tool.

Security Function

- Password protection function

A password (max. 8 characters) is specified for transferring the screen data to GT from GTWIN. This function prevents the outflow of screen data if anyone except the administrator tries to read out the screen data.

- Operation security function (GT02/GT02L/GT03-E/GT05/GT12/GT32/GT32-R/GT32-E)

This function is used to limit the contents of displays and operations by setting the security level of users for each part.


The level of operators are managed with the security password.

GT link function (GT02/GT02L/GT03-E/GT05/GT12/GT32/GT32-R/GT32-E)

This function is used to connect multiple GT units (up to 32 units) to a single PLC (Panasonic FP series/FP7 series).

RS485 communication is used.


Note) Station numbers should be set to the connected GT units. The both settings for GT and PLC are necessary.



^{*} It is communicated using token passing method.

PLC Multiple Connection (GT02/GT02L/GT03-E/GT05/GT12/GT32/GT32-R/GT32-E)

This is a function that enables multiple Panasonic PLCs (FP series/FP7 series) (up to 31 units) to be connected with one GT. Communication is performed via RS485.




Logging function (Model equipped with SD memory card slot)

It is a function to collect and log arbitrary device values into a PLC at a constant period or when conditions are met.

Logged data is saved in a SD memory card inserted in this unit in CSV format.

This function is useful for obtaining the history of data.



FP monitor function (GT02/GT02L/GT03-E/GT05/GT12/GT32/GT32-R/GT32-E)

This function is used to monitor or change the settings and data of FP-series PLC on the GT screen. Without creating screens in advance or connecting to a PC, the operational check of equipment in the actual environment, the start-up of equipment and daily maintenance work can be performed efficiently.

1.2 List of Models

1.2.1 GT Series Main Unit

Item name	Model	Display	Interface specifications	Backlight	Power supply	COM port commu- nication specifi- cation	Front panel color	Model No.
						RS232C	Pure black	AIG02MQ02D
	GT02M0				5 V DC	K3232C	Silver	AIG02MQ03D
	GTOZINIO		COM port		3 4 00	RS422	Pure black	AIG02MQ04D
			USB port			(RS485)	Silver	AIG02MQ05D
			(USB1.1			RS232C	Pure black	AIG02MQ12D
	GT02M1		compliant)	3-color		1102320	Silver	AIG02MQ13D
	GTOZINIT			LED		RS422	Pure black	AIG02MQ14D
				(white,		(RS485)	Silver	AIG02MQ15D
			COM port	red, pink)	24 V	RS232C	Pure black	AIG02MQ22D
			USB port		DC	N3232C	Silver	AIG02MQ23D
	GT02M2	STN	(USB1.1 compliant)			RS422	Pure black	AIG02MQ24D
GT02		mono- chrome	with SD memory card slot			(RS485)	Silver	AIG02MQ25D
G102		LCD				RS232C	Pure black	AIG02GQ02D
	GT02G0	(240x96		3-color LED (green, red, orange)	5 V DC	K3232C	Silver	AIG02GQ03D
	010200	dots)	COM port		3 V DC	RS422	Pure black	AIG02GQ04D
			USB port (USB1.1 compliant)			(RS485)	Silver	AIG02GQ05D
	GT02G1				24 V DC	RS232C	Pure black	AIG02GQ12D
						K3232C	Silver	AIG02GQ13D
						RS422	Pure black	AIG02GQ14D
						(RS485)	Silver	AIG02GQ15D
			COM port USB port (USB1.1 compliant) with SD memory card slot			RS232C	Pure black	AIG02GQ22D
						1102320	Silver	AIG02GQ23D
	GT02G2					RS422	Pure black	AIG02GQ24D
						(RS485)	Silver	AIG02GQ25D
		STN mono-	COM port	1-color		RS232C		AIG02LQ02D
GT02L	GT02L	chrome LCD (160x64 dots)	USB port (USB1.1 compliant)	LED (white)	5 V DC	RS422 (RS485)	Black	AIG02LQ04D
		TFT mono- chrome	COM port USB port	1-color	24 V	RS232C	Silver	AIG03MQ03DE
GT03-E	GT03M-E	LCD (320x240 dots)	(USB1.1 compliant)	LED (white)	DC DC	RS422 (RS485)	(Front sheet color)	AIG03MQ05DE
G103-E	GT03T-E	4096- color TFT	COM port USB port (USB1.1	1-color LED	24 V	RS232C	Silver (Front sheet	AIG03TQ13DE
	GT03T-E		compliant) with SD memory card slot		I DC	RS422 (RS485)	color)	AIG03TQ15DE

Item name	Model	Display	Interface specifications	Backlight	Power supply	COM port commu- nication specifi- cation	Body color	Model No.
				3-color		RS232C	Pure black	AIG05MQ02D
	GT05M	TFT		LED			Silver	AIG05MQ03D
		mono-		(white,		RS422	Pure black	AIG05MQ04D
		chrome	0014	red, pink)		(RS485)	Silver	AIG05MQ05D
		LCD	COM port	3-color		RS232C	Pure black	AIG05GQ02D
	07050	(320x240	USB port (USB1.1	LED	24 V		Silver	AIG05GQ03D
GT05	GT05G	dots)	compliant)	(green, red,	DC	RS422	Pure black	AIG05GQ04D
			with SD memory	orange)		(RS485)	Silver	AIG05GQ05D
		4096-	card slot			RS232C	Pure black	AIG05SQ02D
		color TFT		1-color LED (white)		K3232C	Silver	AIG05SQ03D
	GT05S	color LCD				RS422	Pure black	AIG05SQ04D
		(320x240 dots)				(RS485)	Silver	AIG05SQ05D
			COM port	3-color LED	24 V	DOOOO	Pure black	AIG12MQ02D
	GT12M0		COM port USB port			RS232C	Silver	AIG12MQ03D
						RS422	Pure black	AIG12MQ04D
						(RS485)	Silver	AIG12MQ05D
						RS232C	Pure black	AIG12MQ12D
				(white,		K3232C	Silver	AIG12MQ13D
	GT12M1			red, pink)			Pure black	AIG12MQ14D
		STN mono- chrome	compliant) with SD memory card slot	,		RS422 (RS485)	Silver	AIG12MQ15D
GT12		LCD	COM port		DC	RS232C	Pure black	AIG12GQ02D
	GT12G0	(320x120	USB port			K5232C	Silver	AIG12GQ03D
	G112G0	dots)	(USB1.1			RS422	Pure black	AIG12GQ04D
			compliant)	3-color		(RS485)	Silver	AIG12GQ05D
			COM port	LED		RS232C	Pure black	AIG12GQ12D
			USB port	(green,		K3232C	Silver	AIG12GQ13D
	GT12G1	(USB1.1 compliant) with SD memory card slot	compliant)	red, orange)		RS422	Pure black	AIG12GQ14D
			,			(RS485)	Silver	AIG12GQ15D

Item name	Model	Display	Interface specifications	Backlight	Power supply	COM port commu- nication specifi- cation	Body color	Model No.
		TFT mono-				RS232C	Pure black Silver	AIG32MQ02DR AIG32MQ03DR
	GT32M-R	chrome	COM port				Pure black	AIG32MQ03DR AIG32MQ04DR
GT32-R	0132W-K	LCD (320x240 dots)	USB port (USB1.1	1-color LED	24 V DC	-	Silver	AIG32MQ05DR
	GT32T-R	4096-	compliant) with SD memory	(white)	DC	RS232C	Pure black	AIG32TQ02DR
		color TFT	card slot			1102320	Silver	AIG32TQ03DR
		color LCD				RS422 (RS485)	Pure black	AIG32TQ04DR
		(320x240 dots)					Silver	AIG32TQ05DR
	GT32M-E	TFT mono- chrome	COM port USB port (USB1.1 compliant) with SD memory card slot	1-color LED (white)	24 V DC	RS232C		AIG32MQ03DE
GT32-E	G132W-E	LCD (320x240 dots)				RS422 (RS485)	- Silver	AIG32MQ05DE
G132-E	GТ32T-E	4096- color TFT color LCD				RS232C	Silvei	AIG32TQ03DE
		(320x240 dots)				RS422 (RS485)		AIG32TQ05DE

1.2.2 GT Series Main Unit (Discontinued Models)

Item name	Model	Display	Interface specifications	Backlight	Power supply	COM port commu- nication specifi- cation	Front panel color	Model No.
						RS232C	Black	AIGT0030B1
					5 V DC		Ashgray	AIGT0030H1
				3-color LED	3 4 00	RS422	Black	AIGT0032B1
				(green,		(RS485)	Ashgray	AIGT0032H1
				red, orange)		RS232C	Black	AIGT0030B
				,	24 V		Ashgray	AIGT0030H
					DC	RS422	Black	AIGT0032B
	GT01					(RS485)	Ashgray	AIGT0032H
						RS232C	Black	AIGT0130B1
					5 V DC		Ashgray	AIGT0130H1
		STN	COM port			RS422	Black	AIGT0132B1
GT01		monochrome	TOOL port	1-color LED		(RS485)	Ashgray	AIGT0132H1
		LCD	(RS232C	(white)		RS232C	Black	AIGT0130B
		(128x64 dots)	compliant)		24 V	50.400	Ashgray	AIGT0130H
					DC	RS422	Black	AIGT0132B
						(RS485)	Ashgray	AIGT0132H
						RS232C	Pure black	AIGT0230B1
					5 V DC	D0 400	Silver	AIGT0230H1
	GT01R			3-color LED (white,		RS422	Pure black	AIGT0232B1
						(RS485)	Silver	AIGT0232H1
				red, pink)	041/	RS232C	Pure black	AIGT0230B
					24 V DC	DC 400	Silver Pure black	AIGT0230H
					DC	RS422 (RS485)	Silver	AIGT0232B AIGT0232H
-						(13400)	1	
		STN monochrome LCD (240x96 dots)	COM port TOOL port (RS232C compliant)	3-color LED (green,red, orange)	24 V DC	RS232C	Black	AIGT2030B
							Ashgray	AIGT2030H
						RS422	Black	AIGT2032B
GT11	GT11			1-color LED (white)		(RS485)	Ashgray	AIGT2032H
						RS232C	Black	AIGT2130B
							Ashgray	AIGT2130H
						RS422	Black	AIGT2132B
						(RS485)	Ashgray	AIGT2132H
		256-color	COM port			RS232C	Pure black	AIGT2230B
GT21	GT21	STN color	TOOL port	1-color LED	5 V		Silver	AIGT2230H
	3.2.	LCD	(RS232C	(white)	DC	RS422	Pure black	AIGT2232B
<u> </u>		(320x240 dots)	compliant)			(RS485)	Silver	AIGT2232H
		STN mono-	COM port			RS232C	Pure black	AIG32MQ02D
	GT32M	chrome LCD	USB port				Silver	AIG32MQ03D
		(320x240 dots)	(USB1.1			RS422	Pure black	AIG32MQ04D
			compliant)			(RS485)	Silver	AIG32MQ05D
			with SD			RS232C	Pure black	AIG32TQ02D
	GT32T0		memory card			RS422	Silver Pure black	AIG32TQ03D
			slot		041/	(RS485)	Pure black Silver	AIG32TQ04D AIG32TQ05D
GT32			COM port	CFL	24 V DC		Pure black	AIG32TQ05D
		4096-color	USB port		DC	RS232C	Silver	AIG32TQ12D
	GT32T1	TFT color LCD (320x240 dots)	(USB1.1 compliant) Ethernet port with SD			RS422	Pure black	AIG32TQ14D
			memory card slot with sound output jack			(RS485)	Silver	AIG32TQ15D

1.2.3 Options and Repair Parts

PLC connecting cables

Item name	Contents		Product No.
	For connection between GT01/GT02/GT02L (5V DC type (RS232C)) and our FP-series TOOL port Mini-DIN 5-pin loose-wire cable * A ferrite core is supplied with the main unit.	2 m	AIGT8142
	For connection between GT01/GT02/GT02L (5V DC type (RS422)) and MITSUBISHI FX-series TOOL port Mini-DIN 8-pin loose-wire cable * A ferrite core is supplied with the main unit.	2 m	AIGT8152
3 III - 2	For connection between 24V DC type (RS232C) and our FP-series TOOL port Mini-DIN 5-pin loose-wire cable	2 m 5 m 10 m	AIGT8162 AIGT8165 AIGT8160
E	For connection between 24V DC type (RS422) and MITSUBISHI FX-series TOOL port Mini-DIN 8-pin loose-wire cable	5 m	AIGT8175
	For connection to COM port of FP2/FP2SH and FP2 computer communication unit D-SUB 9-pin loose-wire cable	2 m	AIP81842

Maintenance parts

Item name		Co	Product No.		
Waterproof packing		For GT01 For GT02/GT02L Note) For GT03-E For GT05 For GT11 For GT12 For GT21 For GT32	For repair	10 in set	AIGT081 AIG02810 AIG03810E AIG05810 AIGT181 AIG2810 AIGT28121 AIG32810
Attachment fittings		For GT32-R/GT32-E GT01/GT11 repair (4 pc/set)	5 sets	AIG32810E AIGT083	
		For GT05/GT21 repair	5 sets	AIGT28321	
		For GT32/GT32-R/T32- (2 pc/set)	5 sets	AIG32830	
Attachment fittings (with dedicated screws)		For GT02/GT02L/GT12 (4 pc each/set)	5 sets	AIG12830	
Connector		COM port connector for repair (8-pin)	5 in set	AIGT084	

Note) The waterproof packing AIG02810 can be used for GT02L, however, it is different from the packing attached to the GT02L unit.

Options

Item name		Contents				Product No.
		GT01	For GT01			AIGT080
		F 0T	For GT01R			AIGT080R
Front panel		For GT02/GT02L		Sold separately	10 in set	AIG02800
protective		For GT05				AIG05800
sheet		For GT11				AIGT280
		For GT12				AIG12800
		For GT21				AIGT28021
		For GT	32/GT32-R	Sold separately		AIGT32800
Backup battery		Backup battery for GT02M2,GT02G2/GT03T-E/ GT05/GT12/GT32/GT32-R/GT32-E			1 pc	AFPX-BATT

Commercial product

Ite:	m name	Contents	Model No.	
Backup battery	+	Backup battery for GT11/GT21	1 pc	CR2032

Item	Printed		GT version (Ver.)						Usable SD memory card	
name	logo on GT	GT02M2 GT02G2	GТ03Т-E	GT05	GT12	GT32	GT32-R	GT32-E	Card type	Capacity
SD memory card		-	-	1.39 or older	1.09 or older	1.49 or older	-	-	SD memory card	32M to 1GB
	52	52		1.40	1.10	1.50			SD memory card	32M to 2GB
		-	-	or later	or later	or later	-	-	SDHC memory card CLASS2, 4	4GB to 16GB
		1.00 or later	1.10 or later	1.39 or older	1.09 or older	1.49 or older	1.40 or later	1.00 or later	SD memory card	32M to 1GB
		1.00 or	1.10 or	1.40 or	1.10 or	1.50 or	1.40 or	1.00 or	SD memory card	32M to 2GB
		later	later	later	later	later	later	later	SDHC memory card	4GB to 32GB

Note) Select the capacity of a SD memory card according to the logo printed on the GT and the version of GT firmware.

1.3 Screen Creation Tool

1.3.1 Tools Required for Screen Creation

1. Tool software


It can be used for all the models in the GT series.

Screen transfer cable (Cable for connecting a PC) For GT01/GT11/GT21:

A cable between a PC (D-sub 9-pin) and GT (TOOL port) is available.

For GT02/GT02L/GT03-E/GT05/GT12/GT32/GT32-R/GT32-E:

Prepare a commercial USB cable or LAN cable (for GT32T1 only).



1.3.2 Software Usage Environment and Applicable Cables

Screen creation tool software Terminal GTWIN Ver. 2

Software type		Required OS	Hard disk capacity	Product No.
Terminal GTWIN Ver. 2	English- language version	Windows® 8 Windows® 7 Windows Vista®	800 MB or more	AIGT8001V2
Terminal GTWIN Ver. 2 Upgrade model	English- language version	Windows® 2000 Windows® XP	OUT IND OF MOTE	AIGT8001V2R

Note1) The latest version is provided free of charge via our website

(http://industrial.panasonic.com/ac/e/dl_center/software/). (User registration is required. Free of charge)

Note2) The upgrade model is required for upgrading Ver.1 to Ver.2.

Note 3) As for 64-bit Windows, only Windows®7 and Windows®8 are supported. Except for Windows®7 and Windows®8, use 32-bit windows.

Related software (Freeware)

Item name	Contents	
Configurator WD IP address search tool	Address setting for the GT in Ethernet communication	

Note) It can be downloaded from our website (http://industrial.panasonic.com/ac/e/dl_center/software/). (User registration is required. Free of charge)

Screen transfer cable

For connection between PC (USB) and Programmable Display (GT02/GT02L/GT03-E/GT05/GT12/GT32/GT32-R/GT32-E)

USB cable (Commercial product)	Applicable model	Cable type	Length
	GT05/GT32/ GT32-R/GT32-E	USB2.0 (or 1.1) AB type	Max. 5 m
		USB2.0 (or 1.1) cable A type (Male): miniB type male	Max. 5 m

Note) Windows® 2000 or later OS is required for the communication with a USB.

For connection between PC (RS232C) and Programmable Display (GT01/GT11/GT21)

D-sub connector cable	PC side connector	GT side connector	Specification	Product No.
		Mini DIN round 5-pin	L type (3 m)	AFC8503
		, , , , , , , , , , , , , , , , , , ,	Straight type (3 m)	AFC8503S

Note) A USB/RS232C conversion cable is necessary to connect with a personal computer without a serial port using a PC connection cable.

LAN cable (Ethernet port) (GT32T1)


Either straight cable or crossing cable can be used. (MDI/MDI-X Automatic crossover function)

Chapter 2

Names and Functions of Parts

2.1 Part Names

2.1.1 GT01 / GT11 / GT21



1) Touch screen

Various screens are displayed here. Switches can be operated and data entered simply by touching the touch screen.

(A sheet is affixed to the touch panel to protect it from scratches when shipping. Please remove it before using the GT.)

Optional protective sheets are available to protect the touch screen surface and keep it clean.



Reference: <1.4.2 Options and Repair Parts>

② COM port and power supply terminal

This is a communication port (RS232C or RS422) for connecting to a PLC, host PC, or microcomputer board, and a power supply terminal for operation.

3 TOOL port (GTWIN connection port)

This port is used to connect the screen creation tool.

④ Operation mode setting switches

Setting the operation mode setting switches as follows when turning on the power supply enables the setting to inhibit to move to the system menu or enables to clear F-ROM.

Setting	Normal use (Factory default)	Inhibit system menu shift	Clear F-ROM
Switch setting	ON 0FF 1 2 3 4	ON 0FF 1 2 3 4	ON OFF



Note: Do not use any settings other than the above settings.

⑤ Waterproof packing

This assures that the front panel is waterproof.

6 Battery cover (for GT11 and GT21)

When using a backup battery to be separately purchased, open this battery cover to install it. The clock, PLC device hold data, alarm history and GT internal device hold data functions can be used with the backup battery.



Reference: <3.6.2 How to Install the Battery (Lithium Button Battery)>

2.1.2 GT02 / GT02L

GT02M2, GT02G2 7 6 4 1 GT02M0, GT02M1, GT02G0, GT02G1 9 6 1 GT02L 8 1 3 6

①Touch screen

Various screens are displayed here. A touch panel is provided on the liquid crystal display panel, and switches can be operated and data entered simply by touching the panel.

Optional protective sheets are also available to protect the touch panel and keep it clean.

(A sheet is affixed to the touch panel to protect it from scratches when shipping. Please remove it before using the GT.)

② SD memory card slot

A SD memory card is inserted in this slot.

- Saving from GTWIN: Operate on the GTWIN screen using a SD memory card read/writer.
- Saving from GT main unit: Operate on the SD memory card setting screen under the system menu.

3 USB port

This is a connector for connecting the screen creation tool. The commercial USB cable can be used.

4 SD memory access lamp

The lamp turns on while accessing a SD memory card.

5 Battery cover

When using a backup battery to be separately purchased, open this battery cover to install it. The clock, PLC device hold data, alarm history and GT internal device hold data functions can be used with the backup battery.

6 Operation mode setting switches

Setting the operation mode setting switches as follows when turning on the power supply enables the setting to inhibit to move to the system menu or enables to clear F-ROM.

Setting	Normal use (Factory default)	Inhibit system menu shift	Clear F-ROM
Switch setting	ON 1 2 3 4	ON 1 2 3 4	ON OFF

The screen (backlight) flashes for a while when the F-ROM clear is executed.

Once the F-ROM clear is complete, the buzzer sounds and "Memory is cleared" is displayed on the screen. Set the operation mode setting switches to the state in the normal use after confirming this message, and turn on the power again.

Do not use any settings other than the above settings.

Mounting location of connector for battery


® COM port (PLC/external device connection port) and power supply terminal

This is a communication port (RS232C or RS422) for connecting to a PLC, host PC, or microcomputer board, and a power supply terminal for operation.

Waterproof packing

This assures that the front panel is waterproof.

2.1.3 GT03-E



① Touch screen

Various screens are displayed here. A touch panel is provided on the liquid crystal display panel, and switches can be operated and data entered simply by touching the panel.

2 USB port

This is a connector for connecting the screen creation tool. The commercial USB cable can be used.

3 Operation mode setting switches

Setting the operation mode setting switches as follows when turning on the power supply enables the setting to inhibit to move to the system menu or enables to clear F-ROM.

Setting	Normal use (Factory default)	Inhibit system menu shift	Clear F-ROM
Switch setting	ON 0FF 1 2 3 4	ON 0FF 1 2 3 4	ON OFF

The screen (backlight) flashes for a while when the F-ROM clear is executed.

Once the F-ROM clear is complete, the buzzer sounds and "Memory is cleared" is displayed on the screen. Set the operation mode setting switches to the state in the normal use after confirming this message, and turn on the power again.

Do not use any settings other than the above settings.

4 COM port (PLC/external device connection port) and power supply terminal

This is a communication port (RS232C or RS422) for connecting to a PLC, host PC, or microcomputer board, and a power supply terminal for operation.

5 Waterproof packing

This assures that the front panel is waterproof.

6 Battery cover

When using a backup battery to be separately purchased, open this battery cover to install it. The clock, PLC device hold data, alarm history and GT internal device hold data functions can be used with the backup battery.

7 Mounting location of connector for battery


® SD memory access lamp (Except GT03M-E)

The lamp turns on while accessing a SD memory card. Do not remove the SD memory card when the lamp is lit.

A SD memory card is inserted in this slot.

- Saving from GTWIN: Operate on the GTWIN screen using a SD memory card read/writer.
- Saving from GT main unit: Operate on the SD memory card setting screen of the system menu.

2.1.4 GT05 / GT12 / GT32 / GT32-R / GT32-E



1) Touch screen

Various screens are displayed here. A touch panel is provided on the liquid crystal display panel, and switches can be operated and data entered simply by touching the panel.

Optional protective sheets are also available to protect the touch panel and keep it clean.

(A sheet is affixed to the touch panel to protect it from scratches when shipping. Please remove it before using the GT.)

② SD memory card slot (Except GT12M0 and GT12G0)

A SD memory card is inserted in this slot.

- Saving from GTWIN: Operate on the GTWIN screen using a SD memory card read/writer.
- Saving from GT main unit: Operate on the SD memory card setting screen under the system menu.

3 USB port

This is a connector for connecting the screen creation tool. The commercial USB cable can be used.

4 Ethernet port (RJ45) (GT32T1)

This is a connector for connecting the screen creation tool. The maximum baud rate is 115200 bps when using Ethernet.

⑤ SPEED lamp (GT32T1)

It shows the baud rate when using Ethernet. Light on: During 100Base communication Blinking: During 10Base communication

©LINK/ACT lamp (GT32T1)

it shows the state of communication with Ethernet.

Light on: When linked

Blinking: While data reception

Sound output jack (GT32T1)

Insert the speaker with a ϕ 3.5-mini plug amplifier for using the audio output function.

®SD memory access lamp (Except GT12M0 and GT12G0)

The lamp turns on while accessing a SD memory card.

When using a backup battery to be separately purchased, open this battery cover to install it. The clock, PLC device hold data, alarm history and GT internal device hold data functions can be used with the backup battery.

Operation mode setting switches

Setting the operation mode setting switches as follows when turning on the power supply enables the setting to inhibit to move to the system menu or enables to clear F-ROM.

Setting	Normal use (Factory default)	Inhibit system menu shift	Clear F-ROM
Switch setting	ON OFF 1 2 3 4	ON OFF	ON OFF

The screen (backlight) flashes for a while when the F-ROM clear is executed.

Once the F-ROM clear is complete, the buzzer sounds and "Memory is cleared" is displayed on the screen. Set the operation mode setting switches to the state in the normal use after confirming this message, and turn on the power again.

Do not use any settings other than the above settings.

10 Mounting location of connector for battery

@ COM port (PLC/external device connection port) and power supply terminal

This is a communication port (RS232C or RS422) for connecting to a PLC, host PC, or microcomputer board, and a power supply terminal for operation.


Waterproof packing

This assures that the front panel is waterproof.

2.2 Terminal Layouts of COM Port

2.2.1 GT01

5 V/RS232C type




Pin name	Name	Signal direction	Product No.
+	+5 V	-	
_	0 V	-	AIGT0030B1
NC	Not connected	-	AIGT0030H1
SD	Send data	GT→External device	AIGT0130B1
RD	Receive data	GT←External device	AIGT0130H1
NC	Not connected	-	AIGT0230B1
NC	Not connected	-	AIGT0230H1
SG	Signal ground	-	




Note: There is no RS and CS (control lines).

5 V/RS422(RS485) type



Pin name	Name	Signal direction	Product No.
+	+5 V	-	
_	0 V	-	AIGT0032B1
NC	Not connected	-	AIGT0032H1
+SD	Send data	GT→External device(+)	AIGT0132B1
-SD	Send data	GT→External device(-)	AIGT0132H1
+RD	Receive data	GT←External device(+)	AIGT0232B1
-RD	Receive data	GT←External device(-)	AIGT0232H1
Е	Terminal resistance	-	


24 V/RS232C type



Pin name	Name	Signal direction	Product No.
+	+24 V	-	
_	0 V	-	AIGT0030B
FG	Functional ground	-	AIGT0030H
SD	Send data	GT→External device	AIGT0130B
RD	Receive data	GT←External device	AIGT0130H
NC	Not connected	-	AIGT0230B
NC	Not connected	-	AIGT0230H
SG	Signal ground	-	




Note: There is no RS and CS (control lines).



Pin name	Name	Signal direction	Product No.
+	+24 V	-	
_	0 V	-	AIGT0032B
FG	Functional ground	-	AIGT0032H
+SD	Send data	GT→External device(+)	AIGT0132B
-SD	Send data	GT→External device(-)	AIGT0132H
+RD	Receive data	GT←External device(+)	AIGT0232B
-RD	Receive data	GT←External device(-)	AIGT0232H
E	Terminal resistance	-	


2.2.2 GT02

5 V/RS232C type



Pin name	Name	Signal direction	Product No.
+	+5 V	-	
_	0 V	-	
FG	Functional ground	-	AIG02MQ02D
SD	Send data	GT→External device	AIG02MQ03D
RD	Receive data	GT←External device	AIG02GQ02D
RS	Request to send	GT→External device	AIG02GQ03D
CS	Clear to send	GT←External device	
SG	Signal ground	-	


5 V/RS422(RS485) type



m 2 + 2 + 4 m 2 d d c c c 6 COM. 5V:::

Pin name	Name	Signal direction	Product No.
+	+5 V	-	
-	0 V	-	
FG	Functional ground	-	AIG02MQ04D
+SD	Send data	GT→External device(+)	AIG02MQ05D
-SD	Send data	GT→External device(-)	AIG02GQ04D
+RD	Receive data	GT←External device(+)	AIG02GQ05D
-RD	Receive data	GT←External device(-)	
Е	Terminal resistance	-	


24 V/RS232C type



SS SS G G G ⊕ + + COM. 24V:::

	Pin name	Name	Signal direction	Product No.
-	+	+24 V	1	AIG02MQ12D
	_	0 V	1	AIG02MQ13D
	FG	Functional ground	-	AIG02MQ22D
	SD	Send data	GT→External device	AIG02MQ23D
	RD	Receive data	GT←External device	AIG02GQ12D
_	RS	Request to send	GT→External device	AIG02GQ13D
	CS	Clear to send	GT←External device	AIG02GQ22D
	SG	Signal ground	-	AIG02GQ23D

24 V/RS422(RS485) type



a 24V = 1 COM. 24V = 1


y	pe			
	Pin name	Name	Signal direction	Product No.
-	+	+24 V	-	AIG02MQ14D
	_	0 V	-	AIG02MQ15D
	FG	Functional ground	-	AIG02MQ24D
	+SD	Send data	GT→External device(+)	AIG02MQ25D
	-SD	Send data	GT→External device(-)	AIG02GQ14D
_	+RD	Receive data	GT←External device(+)	AIG02GQ15D
	-RD	Receive data	GT←External device(-)	AIG02GQ24D
	Е	Terminal resistance	=	AIG02GQ25D

2.2.3 GT02L

5 V/RS232C type




Pin name	Name	Signal direction	Product No.
+	+5 V	-	
_	0 V	-	
FG	Functional ground	-	
SD	Send data	GT→External device	
RD	Receive data	GT←External device	AIG02LQ02D
RS	Request to send	GT→External device	
CS	Clear to send	GT←External device	
SG	Signal ground	-	




Pin name	Name	Signal direction	Product No.
+	+5 V	-	
_	0 V	-	
FG	Functional ground	-	
+SD	Send data	GT→External device(+)	AIG02LQ04D
-SD	Send data	GT→External device(-)	AIGUZLQU4D
+RD	Receive data	GT←External device(+)	
-RD	Receive data	GT←External device(-)	
E	Terminal resistance	-	

2.2.4 GT11 / GT12

24 V/RS232C type




Pin name	Name	Signal direction	Product No.
+	+24 V	-	AIGT2030B
_	0 V	-	AIGT2030H
FG	Functional ground	-	AIGT2130B
SD	Send data	GT→External device	AIGT2130H
RD	Receive data	GT←External device	AIG12MQ02D
RS	Request to send	GT→External device	AIG12MQ03D
CS	Clear to send	GT←External device	AIG12MQ12D
			AIG12MQ13D
			AIG12GQ02D
SG	Signal ground	-	AIG12GQ03D
			AIG12GQ12D
			AIG12GQ13D




Pin name	Name	Signal direction	Product No.
+	+24 V	-	AIGT2032B
_	0 V	-	AIGT2032H
FG	Functional ground	-	AIGT2132B
+SD	Send data	GT→External device(+)	AIGT2132H
-SD	Send data	GT→External device(-)	AIG12MQ04D
+RD	Receive data	GT←External device(+)	AIG12MQ05D
-RD	Receive data	GT←External device(–)	AIG12MQ14D
			AIG12MQ15D
			AIG12GQ04D
E	Terminal resistance	-	AIG12GQ05D
			AIG12GQ14D
			AIG12GQ15D

2.2.5 GT03-E / GT21

24 V/RS232C type




Pin name	Name	Signal direction	Product No.
+	+24 V	-	
_	0 V	-	
FG	Functional ground	-	AIGT2230B
SD	Send data	GT→External device	AIGT2230H
RD	Receive data	GT←External device	AIG03MQ03DE
RS	Request to send	GT→External device	AIG03TQ13DE
CS	Clear to send	GT←External device	
SG	Signal ground	-	




е			
Pin name	Name	Signal direction	Product No.
+	+24 V	-	
_	0 V	-	
FG	Functional	_	
10	ground		AIGT2232B
+SD	Send data	GT→External device(+)	AIGT2232H
-SD	Send data	GT→External device(-)	AIG03MQ05DE
+RD	Receive data	GT←External device(+)	AIG03TQ15DE
–RD	Receive data	GT←External device(-)	
F	Terminal	_	
	resistance	-	

2.2.6 GT05 / GT32 / GT32-R / GT32-E

24 V/RS232C type



+24 V 0 V Functional ground	-	AIG05MQ02D AIG05MQ03D
· ·	-	AIG05MQ03D
Functional ground		
	-	AIG05GQ02D
Send data	GT→External device	AIG05GQ03D
Receive data	GT←External device	AIG05SQ02D
Request to send	GT→External device	AIG05SQ03D
Clear to send	GT←External device	AIG32MQ02D
		AIG32MQ03D AIG32TQ02D AIG32TQ03D
Signal ground	-	AIG32TQ12D AIG32TQ13D AIG32MQ02DR AIG32MQ03DR AIG32TQ02DR AIG32TQ03DR AIG32MQ03DE AIG32TQ03DE
	Receive data Request to send Clear to send	Receive data GT←External device Request to send GT→External device Clear to send GT←External device



Pin name	Name	Signal direction	Product No.
+	+24 V	-	AIG05MQ04D
_	0 V	-	AIG05MQ05D
FG	Functional ground	-	AIG05GQ04D
+SD	Send data	GT→External device(+)	AIG05GQ05D
-SD	Send data	GT→External device(-)	AIG05SQ04D
+RD	Receive data	GT←External device(+)	AIG05SQ05D
-RD	Receive data	GT←External device(-)	AIG32MQ04D
	Terminal resistance		AIG32MQ05D AIG32TQ04D
			AIG32TQ05D
			AIG32TQ14D
			AIG32TQ15D
l E		_	AIG32MQ04DR
			AIG32MQ05DR
			AIG32TQ04DR
			AIG32TQ05DR
			AIG32MQ05DE
			AIG32TQ05DE

2.3 Connecting to Screen Creation Tool GTWIN

2.3.1 TOOL Port



Pin No.	Name	Abbre.	Signal direction		
1	Signal ground	SG	-		
2	Send data	SD	GT→External device		
3	Receive data	RD	GT←External device		
4	Not connected	N.C.	-		
5	+5 V	(+5V)	-		



• The +5V of Pin 5 is reserved for the FP Programmer II. It should not be used for any other application. If using it, there is a restriction on the ambient temperature. The pin 5 of GT01 is N.C.


2.3.2 USB Port

USB connection

Communication with our software such as GTWIN becomes available by connecting to a PC with a USB cable.

Functions enabled by USB connection

- Through function using our PLCs
- Screen transfer



Note: If more than one programmable display unit or AE20 are connected to a PC using the USB port, the communication is not available.


2.3.3 Ethernet Port

Ethernet connection


GT32T1 has an Ethernet port. Communication with our software such as GTWIN becomes available by connecting to a PC with a LAN cable.

Ethernet communication function


- Screen transfer (Baud rate: fixed at 115200 bps. It takes at least 3 times longer than the transfer using USB.)



- Communication with our PLCs using the through function



* Specifying the destinations to connect enables the communication with multiple units using a HUB.



Required items for connection

• LAN cable

Either straight cable or crossing cable can be used.

(MDI/MDI-X Automatic crossover function)

Settings for Ethernet connection

Follow the procedure below to communicate with the Ethernet connection.


- 1. Connect the GT to a PC with an Ethernet cable.
- 2. Specify the settings such as IP address for the GT.
- 3. Startup the GTWIN and specify the communication condition.

The factory settings are as follows.

IP Address	192.168.1.5		
Subnetmask	255.255.255.0		
Default Gateway	192.168.1.1		
Port No	9094		

Note) Setting items such as IP address for the GT can be specified in the System Menu.

GTWIN setting



Network type: Ethernet

Title: Input an arbitrary title (Up to 38 one-byte

characters) Computer:

Check "Acquire IP address automatically".

The default setting is to use the IP address currently being used in the computer.

Click [OK] to finish the setting.

Note) When sing multiple Ethernet cards, specify manually.

IP address: When it is not displayed, set the property of the TCP/IP in the items such as Network of the control panel. IP address can be input or changed.

Note) The setting procedure varies depending on the OS used. For the details, refer to the manual/help of the OS.

Port No.: Set to 0 or within the range of 1025 to 32767 in decimal. For using it in the GTWIN, set it to 0.




• Setting of destination (PLC side)

IP address: Specify the IP address of the GT to be connected in decimal.

Port No.: Set it within the range of 1 to 32767 in decimal. (Default: 9094)

Specify the same setting as the one of GT.



• Communication time out: Set the time-out period after connection establishment for every

communication within the range of 1 to 950 seconds. (Default: 15) (it is not

linked to this setting until a connection is established)

• Connection time out: Set the time-out period until connection establishment within the range of 1 to 180 seconds. (Default: 60)



Setting with IP search tool (Config WD. exe)

The settings of the GT can be specified with the IP address search tool of Configurator WD (Ver.1.11 or later).

The IP search tool (Config WD. exe) can be downloaded for free from our website

URL: http://industrial.panasonic.com/ac/e/dl_center/software/

(User registration is required.: Free of charge)

Chapter 3

Installation and Wiring

3.1 Installation

3.1.1 Installation Environment

When installing and using the GT series, always make sure the following conditions are observed.

Usage conditions

Operating environment (Use the unit within the range of the general specifications when installing)

- Ambient temperatures: 0 to +50 °C
 - (It varies according to models when installing the unit in a horizontal orientation or using a C-NET adapter and FP programmer II.)
- Ambient humidity should be 20 to 85% RH (at 25 °C) and non-condensing.
- Usable altitude: Altitude 2,000 m or less
- For use in pollution Degree 2 environment
- Do not use it in the following environments.
 - Direct sunlight, wind and rain. (This product is not designed for outdoor use.)
 - Sudden temperature changes causing condensation.
 - Inflammable or corrosive gas.
 - Excessive airborne dust, metal particles or saline matter.
 - Benzine, paint thinner, alcohol or other organic solvents or strong alkaline solutions such as ammonia or caustic soda.
 - Direct vibration, shock or places always exposed to drop of water. (This unit is warranted by IP65/IP67 (depending on models) for panel mounting, however, this applies to initial values.)
 - Influence from power transmission lines, high voltage equipment, power cables, power equipment, radio transmitters, or any other equipment that would generate high switching surges. (100 mm or more)

The usage conditions for Tough series (GT03-E/GT32-E) are as follows.

- Ambient temperatures: -20 to +60 °C (In horizontal orientation, when sitting upright in vertical orientation or when using a battery: -20 to +55 °C)
- Ambient humidity should be 10 to 90% RH (at 25°C) and non-condensing.
 - The upper limit of the humidity at each temperature is as below.
 - (Below 40 °C; 90%RH, 50 °C; 55%RH, 60 °C; 35%RH)
 - If the product is exposed to heavy rain, condensation might be caused by sudden temperature changes.
- Usable altitude: Altitude 2,000 m or less
- For use in pollution Degree 2 environment
- Overvoltage category: II
- Do not use it in the following environments.
- Direct sunlight for a long time
- (Exposing the product to direct sunlight increases the surface temperature of the display higher than ambient temperature, and causes deterioration of LDC panel.)
- Inflammable or corrosive gas.
- Excessive airborne dust, metal particles or saline matter.
- Benzine, paint thinner, alcohol or other organic solvents or strong alkaline solutions such as ammonia or caustic soda.
- Direct vibration, shock or places always exposed to drop of water.
 (This unit is warranted by IP67 for panel mounting, however, this applies to initial values.)
- Influence from power transmission lines, high voltage equipment, power cables, power equipment, radio transmitters, or any other equipment that would generate high switching surges. (100 mm or more)

Static electricity

- Do not touch connector pins directly to prevent static electricity from causing damage.
- Always rid yourself of any static electricity before handling this product.
- If excessive static electricity is applied to the panel surface, the LCD panel may be damaged.

Power supply

- Twist the wires of the power supply.
- The unit has sufficient noise immunity against the noise generated on the power line. However, it is recommended to take measures for reducing noise such as using an isolating transformer before supplying the power. And it is recommended to take measures such as installing a ferrite core.
- Allocate an independent wiring for each power supplying line, PLC etc and operating device.
- If using a power supply without a protective circuit, power should be supplied through a protective element such as fuse. Directly applying an abnormal voltage to the unit may cause the damage to the internal circuit.

3.1.2 Restriction According to Mounting Directions

If the unit is being installed in a horizontal orientation, or our Programmer II and C-NET adaptor are being connected to the TOOL port, note that the ambient usage temperature should be as below.

Model name	Condition	Ambient temperature	Liquid display panel side
GT11	Vertically installed Programmer II		Installation panel
	C-NET adapter	0 to 45 °C	
	Horizontally installed	010400	(Horizontal installation)
GT21	Programmer II		(Total Modulation)
	C-NET adapter		
GT32	Horizontally installed	0 to 40 °C	
GT03-E	Horizontally installed	-20 to 55 °C	
GT32-E	Vertically installed	-20 10 55 °C	

Note) When installing the unit aslant, the restriction is the same as the one when installing horizontally.

3.1.3 Installation Space

Applicable panel thickness

A panel with a thickness of 1.0 to 5.0 mm should be used.

Use a panel that is strong enough not to be warped.

Clearance when the GT is installed

When installing the GT unit, if other parts are being installed to the panel or cables are being wired to it, we recommend providing a clearance around the GT unit. This prevents cables from being damaged, and facilitates the installation work. Also, make sure that the slits in the main unit are never obstructed.

Model name	Clearance	Clearance on the surface to connect the screen transfer cable	Clearance on the mounting surface when using a SD memory card
GT01 GT11 GT21	- 30 mm or more (50 mm or more recommended)	20 mm	-
GT02L GT03M-E		60 mm	-
GT02 GT05 GT03T-E GT12 GT32 GT32-R GT32-E		60 mm	40 mm or more

^{*} It should be 40 mm or more when using a SD memory card.

3.1.4 UL/c-UL Qualification

Be aware of the following when applying for UL standard for the equipment that the GT has been built in.

- When the GT built in equipment, the GT should meet the standard as a part of the enclosure.
- As the rear of the GT is not qualified as an enclosure, provide a fire enclosure (metal barrier) that entirely covers the rear and lateral sides of the GT.

3.1.5 Mounting Screws

Secure the GT to a mounting plate using the fitting and screws provided with the unit.

Recommended screws

Recommended product	GT unit	Size	Others	Quantity
	GT01/GT11	M3 – 20	Material: SW pane-head (+)	
Mounting screw	GT05/GT21/GT32/ GT32-R/GT32-E	M3 – 25	Galvanization,	4 pcs/unit
			trivalent chromate	

GT02/GT02L/GT03-E/GT12 dedicated screw


The GT02/GT02L/GT03-E/GT12 dedicated screw is not sold on the open market. Using screws other than the dedicated screw will cause failures such as decrease of water-proof property.

Name	Content	Model No.
Attachment fitting (with dedicated screws)	5 sets for GT02/GT02L/GT03-E/GT12 4 pcs of attachment fittings and 4 pcs of dedicated screws/set	AIG12830

3.1.6 GT01 and GT11 Installation Method

Secure the GT to the installation panel using the four fittings and four screws provided with the unit.

- 1. Place the GT in the installation panel.
- 2. Insert the fittings into the grooves provided in the GT, and tighten the screws to secure the GT to the installation panel.




The screw tightening torque should be 0.1 to 0.25 N· m, and tighten them uniformly.

Tightening the screws too hard can cause deformation of the front panel, so that the touch switches will not function properly. Install the GT within the above range.

3.1.7 GT21 Installation Method

Secure the GT21 to the installation panel using the two fittings and four screws provided with the unit.

- 1. Place the GT21 main unit in the installation panel.
- 2. Insert the fittings into the grooves provided in the GT21 main unit, and tighten the screws to secure the GT21 main unit to the installation panel.




The screw tightening torque should be 0.1 to 0.25 N⋅ m, and tighten them uniformly.

Tightening the screws too hard can cause deformation of the front panel, so that the touch switches will not function properly. Install the GT within the above range.

3.1.8 GT05 / GT32 / GT32-R / GT32-E Installation Method

Secure the GT32 to the installation panel using the two fittings and four screws provided with the unit.

- 1. Place the GT main unit in the installation panel.
- 2. Insert the fittings into the grooves provided in the GT main unit, and tighten the screws to secure the GT main unit to the installation panel.



GT05 / GT32

The screw tightening torque should be 0.1 to 0.25 N⋅ m, and tighten them uniformly.

GT32-R / GT32-E


The screw tightening torque should be 0.2 to 0.3 N·m, and tighten them uniformly.


Tightening the screws too hard can cause deformation of the front panel, so that the touch switches will not function properly. Install the GT within the above range.

3.1.9 GT02 / GT02L / GT03-E / GT12 Installation Method

Secure the GT12 or GT02 to the installation panel using the two fittings and four dedicated screws provided with the unit.

- 1. Place the GT main unit in the installation panel.
- 2. Insert the fittings into the grooves provided in the GT main unit, and tighten the screws to secure the GT main unit to the installation panel.








Note: - The cross slot screwdriver No. 1 must be used.


- Tightening torque: 0.2 to 0.3 N m
- Tightening the screws too hard can cause deformation of the front panel, so that the touch switches will not function properly.

3.1.10 Installing in Vertical Orientation

The normal orientation of GT series is horizontally long, however, they can be installed upright.



Key Point: Select the vertical type when selecting a GT model in GTWIN.



3.1.11 Precaution When reinstalling GT

When the GT is reinstalled after being removed from the panel, the water-proof packing should be replaced.

3.2 Wiring the Power Supply

3.2.1 Wiring the Power supply

The power supply should be wired by securely connecting the terminal on the rear of the main unit to the terminal.

Use twisted wiring for the power supply

In order to minimize influence from noise, the wiring for the power supply should be twisted.

Insulate the power supply inside a protective circuit


- In order to protect the unit against abnormal voltage from the power supply line, the power supply should be an insulated type, and should be enclosed within a protective circuit.
- If a power supply device without an internal protective circuit is being used, power should always be supplied to the GT series through a fuse or a similar protective device.

Keep the power supply voltage within the operating voltage range

Rated voltage	Operating voltage range		
5 V DC	4.5 to 5.5 V DC		
24 V DC	21.6 to 26.4 V DC		

Keep the power supply wiring separate

• Wiring to the GT series, PLC, and other power equipment should have separate wiring systems.




3.2.2 Grounding

Be sure to ground when the influence of noise is great

The unit is tolerant against noise in normal environments, but if the environment is particularly susceptible to noise, please ground.

Use dedicated grounding

- Make the grounding point as close as possible to the GT and keep the distance of the grounding wire short
- Sharing the ground with another device may have an adverse effect. Therefore, be sure that grounding is dedicated.






Note:

Conversely, depending on your environment, grounding may cause a problem.


Example:

Since the power line of the GT unit is connected to a functional earth via electronic parts, the electronic parts may become damaged if there is an abnormal potential between the power line and the physical ground.



Do not ground the function earth when grounding a plus (+) terminal of the power. (GT01, GT11, GT21)


In some computers, the SG terminal of RS232C port and connector shielding are connected. Also the tool port shielding is connected with the function earth terminal. Therefore, the GND terminal and the function earth terminal are connected if the computer is connected. Especially when the GT is connected to a computer with a plus (+) terminal grounded, therefore, an GT's minus (-) terminal is connected with the function earth terminal. As a result, short circuit occurs which may lead to the breakage of GT and its neighboring parts.



3.3 Wiring the COM Port

Accessory communication connector/applicable wiring

The communication connector used for the COM port (provided as an accessory with the main unit) has a screw-tightening type of terminal block. The wiring shown below should be used.



Applicable wiring (twisted wiring)

Size	Conductor cross-section surface area	
AWG 28 to 16	0.08 to 1.25 mm ²	16

Use a special tool to tighten the terminal block of the communication connector.

Use a screwdriver made by us. (Product number: AFP0806). The tightening torque should be 0.22 to 0.3 N· m or less.

When doing RS485 communication using RS422 type

Please use the following cables or equivalent.

Appropriate electrical cables (twisted cables)

Туре	Cross-sectional view	Conductor		Insulator			Sample
		Size	Resist- ance (at 20°C)	Material	Thick- ness	Cable diam.	appropriate cable
Shielded	isted Con- Insu-	1.25 mm ² (AWG16) or greater	Max. 16.8 Ω/km	Polye- thylene	Max. 0.5 mm	Approx. 8.5 mm	Belden 9860 Hitachi Cable, Ltd. KPEV- S1.25 mm² x 1P
twisted pair		0.5 mm ² (AWG20) or greater	Max. 33.4 Ω/km	Polye- thylene	Max. 0.5 mm	Approx. 7.8 mm	Belden 9207 Hitachi Cable, Ltd. KPEV- S0.5 mm² x 1P




- Use shielded twisted pair cables.
- Use only one type of transmission cable. Do not mix more than 1 type.
- When using shielded cable with crossover wiring for the RS485 transmission line, grounded one end.

Wiring method

(1) Remove the sheath from the wire.




(2) Insert the wire all the way into the terminal block, and tighten the screw in the clockwise direction to secure it.



Precautions concerning wiring

The following precautions should be observed, to avoid broken or disconnected wires.

- When removing the sheath, be careful not to scratch the core wire.
- Wire the terminal without twisting the core wire.
- The core wire should be connected without soldering it. Vibration can sometimes cause soldered connections to break loose.
- After connecting the wiring, avoid subjecting the cable to stress.
- Because of the construction of the terminal, tightening the wire in the counterclockwise direction will cause a faulty connection. If this happens, disconnect the wire, check the terminal hole, and connect the wire again.





Reference:

For information on connecting the COM port of the GT series with various PLC units, refer to <Chapter 4 Connecting with the PLC>.


3.4 Precautions when Wiring COM Port

Precautions are different depending on communication conditions. Arrange wirings according to the following instructions.

3.4.1 GT01 (5 V DC)


RS232C type

- Perform wiring and placement of the cable so that there is no impression of external noise on the cable and no induction.
- Use shielded wires for distribution cables.
 - (Recommended cable: AIGT8142 with one ferrite core)
- It conforms to CE marking. As conditions, the following wiring is required.
 - Make the cable do three turns around a ferrite core.
 (Recommended ferrite core: Seiwa Electric's E04RA190120080 or equivalent)
 - 2. Perform grounding of the cable shield.
 - * Packaged with AIGT8142.



RS422 (RS485) type

- There is no RS and CS (control lines).
- Perform wiring and placement of the cable so that there is no impression of external noise on the cable and no induction.
- Use shielded wires for distribution cables.
 - (Recommended cable: AIGT8152 with one ferrite core(Seiwa Electric's E04RA190120080))
- When using shielded cable with crossover wiring for the RS485 transmission line, grounded one end.
- "E" is used to set the terminating station.
- It does not conform to European EMC directive.





Kev Point:


The CE marking standards that the GT01 conforms to (excluding the RS422 (RS485) type) European EMC directive 2004/108/EC

European EMC standards (EN61000-6-4 and EN61000-6-2)

3.4.2 GT02 / GT02L (5 V DC)


RS232C type

- Perform wiring and placement of the cable so that there is no impression of external noise on the cable and no induction.
- Use shielded wires for distribution cables. (Recommended cable: AIGT8142)
- It conforms to CE marking. As conditions, the following wiring is required.
 - 1. Perform grounding of the cable shield.
 - 2. Perform grounding of the GT.



RS422 (RS485) type

- There is no RS and CS (control lines).
- Perform wiring and placement of the cable so that there is no impression of external noise on the cable and no induction.
- Use shielded wires for distribution cables.
- When using shielded cable with crossover wiring for the RS485 transmission line, grounded one end.
- "E" is used to set the terminating station.
- It conforms to CE marking. As conditions, the following wiring is required.
 - 1. Perform grounding of the cable shield.
 - 2. Perform grounding of the GT.






The CE marking standards that the GT02/GT02L conforms to European EMC directive 2004/108/EC European EMC standards (EN61131-2)


3.4.3 RS232C Communication

- There is no RS and CS (control lines) for GT01.
- Perform wiring and placement of the cable so that there is no impression of external noise on the cable and no induction.
- Use shielded wires for distribution cables. (Recommended cable: AIGT8162)
- It conforms to CE marking. As conditions, the following wiring is required.
 - 1. Install a ferrite core to the cable. (For GT11 only)
 (Recommended ferrite core: Seiwa Electric's E04SR170730A or equivalent)
 - 2. Perform grounding of the cable shield.
 - 3. Perform grounding of the GT.

GT01 / GT02 / GT12




GT11




Installing Ferrite core

GT03-E / GT21



GT05 / GT32 / GT32-R / GT32-E






The CE marking standards that the GT series conforms to European EMC directive 2004/108/EC

European EMC standards For GT01/GT11/GT21 (EN61000-6-4 and EN61000-6-2) For GT02/GT03-E/GT05/GT12/GT32/GT32-R/GT32-E (EN61131-2)


3.4.4 RS422 (RS485) Communication

- There is no RS and CS (control lines).
- Perform wiring and placement of the cable so that there is no impression of external noise on the cable and no induction.
- Use shielded wires for distribution cables. (Recommended cable: AIGT8175 (for Mitsubishi FX series)
- When using shielded cable with crossover wiring for the RS485 transmission line, grounded one end.
- "E" is used to set the terminal unit.
- It conforms to CE marking. As conditions, the following wiring is required.
 - Fit a ferrite core to the cable. (For GT11 only)
 (Recommended ferrite core: Seiwa Electric's E04SR170730A or equivalent)
 - 2. Perform grounding of the cable shield.
 - 3. Perform grounding of the GT.

GT01 / GT02 / GT12




GT11




Installing Ferrite core

GT03-E / GT21



GT05 / GT32 / GT32-R / GT32-E






The CE marking standards that the GT series conforms to European EMC directive 2004/108/EC

European EMC standards For GT01/GT11/GT21 (EN61000-6-4 and EN61000-6-2) For GT02/GT03-E/GT05/GT12/GT32/GT32-R/GT32-E (EN61131-2)

3.5 Precautions when Wiring Ethernet Port (GT32T1)

- Although more than one GT32T1 can be connected using a hub, communication is performed with one unit each. Specify each destination to communicate.
- Use a UTP cable (unshielded cable) for the Ethernet cable, and take measures for noises such as installing a ferrite core if necessary.
- It conforms to CE marking. As conditions, the following wiring is required.
 - 1. Do not use a shield wire for the Ethernet cable.
 - Install a ferrite core to the Ethernet cable and make one turn.(Recommended ferrite core: Kitagawa Industries SFC-10 or equivalent)

GT32T1





The CE marking standards that the GT32 conforms to European EMC directive 2004/108/EC European EMC standards (EN61131-2)

3.6 Options

3.6.1 Backup Battery

Backup battery

The internal data in the GT can be backed up using the backup battery. Use the following backup batteries.

GT model	Battery type	Product No.	
GT11	Putton type lithium betteny	CR2032 (commercial item)	
GT21	Button type lithium battery		
GT02M2/GT02G2			
GT03T-E			
GT05	Dooleyn hotton	AFPX-BATT	
GT12	Backup battery	(The backup battery for the FP-X is used.)	
GT32			
GT32-R/GT32-E			

Battery life

Battery life, when operating at a normal temperature (25°C), a normal humidity (65% RH), is as follows.

GT model	life	
GT11	Approx 2 years	
GT21	Approx. 2 years	
GT03T-E		
GT05S		
GT32T0/GT32T1	Approx. 3 years	
GT32M-R/GT32T-R		
GT32M-E/GT32T-E		
GT02M2/GT02G2		
GT05M		
GT05G	Approx. 5 years	
GT12		
GT32M		

Backup

The internal data of the GT is backed up in the following ways.


Internal data to be backed up	Stored in	Backup battery
Screen data (base, keyboard, login)		
Flow display data		
Recipe data	Stored in the F-ROM.	Not required
Write device		
FP monitor screen data		
Alarm history + Line graph sampling		
Logging data of Logging function	Stored in the SRAM.	Poguired
Hold GT device	Stored in the SKAWI.	Required
Hold PLC device		



When using a backup battery, attach the battery before the power supply is turned on.


3.6.2 How to Install the Battery (Lithium Button Battery)

(The figures below is explained using the GT11.



When installing the battery

- 1) Insert the head of the battery in the battery holder, and push it into the back.
- 2 Press the battery down pushing it into the back of the battery holder.



When removing the battery

- ① Push the battery into the back of the holder.
- 2 Pull up the battery pushing it into the back of the battery holder.




Note: Do not touch the electronic parts when removing and installing the battery.


3.6.3 How to Install the Battery (Backup Battery)

The figures below is explained using the GT32.


1. Remove the battery cover.




2. Connect the connector to make the red line be the (+) side, and place a battery in the circular frame.



Overhead view




3. Fit the battery cover.



3.6.4 Dead Battery Mark

If the battery voltage drops too low, the battery mark is displayed at the bottom right of the GT screen.



It can be specified in the GTWIN configuration settings, whether or not the dead battery mark is displayed .



Note:

If the battery voltage drops too low, the BAT LOW flag of the basic communication area map goes on. If the battery has run down completely, the BAT flag of the basic communication area map goes on. Please be aware that the BAT flag goes on the first time that the power supply is turned on after the unit is purchased.

* The BAT and BAT LOW flags in the basic communication area map activate in the both cases that the battery error display is set to "On" and "Off".

3.6.5 Time for Replacement of Battery

When replacing the backup battery, turn on electricity for the time for energization, and replace the battery with a new one within one minute after turning off the power supply.

If the battery is not replaced within the time for replacement, the saved data will be lost.

Time for energization	Time for replacement	
1 min. or more (10 min. or more for GT32)	Within 1 min.	

3.6.6 Replacement of Front Panel Protective Sheet

About the front panel protective sheet


Use the separately-sold protective sheets to protect the touch panel surface and to keep it clean.

Replacing the front panel protective sheet (For GT01 (except GT01R) and GT11)

Follow the steps below to replace the sheet:

1. Peel off the seal from the provided protector sheet and attach it to the unit.

Take out one of the replacement front panel protective sheets and peel off the seal with the shiny side. When attaching the sheet, align the adhesive edges with the front of the GT. Finish by peeling off the thin film attached to the top of the front panel protective sheet.




Replacing the front panel protective sheet (For GT01R, GT02, GT02L, GT03-E, GT12, GT21, GT32, GT32-R and GT32-E)

1. Remove the peel-off film attached to the front panel protective sheet.

2. Attach the front panel protective sheet.

Attach the front sheet to fit the liquid crystal part of GT. At this time, try not to allow the air to get in the attached face. If the air was in, remove the air to be out with fingers. Do not press the front panel hard as it may cause the damage to the touch switch.



3.6.7 About the Waterproof Packing

If the panel is being detached from the GT and then reattached, the waterproof packing should be replaced, in order to assure that the panel remains waterproof (IP65, however, IP67 for GT02, GT03-E, GT12, GT32-R and GT32-E).

Replacing the waterproof packing


1. Remove the currently attached waterproof packing.

Remove the attached waterproof packing from the GT.

2. Attach the provided waterproof packing.

Take out one of the replacement waterproof packing pieces and attach the outer edge as shown in the illustration (do not use the inner edge).

When doing this, fasten it to the front frame, being sure not to twist the waterproof packing. As for the model with a grooved front frame, surely fit the waterproof packing in the groove.



Chapter 4

Connecting with PLC


4.1 Connection with PLC

How to connect with PLC

- · Connecting between one GT and one PLC via 1:1 communication
- Connecting between one GT and multiple PLCs via 1:N communication (PLC multiple connection)
- · Connecting between one PLC and multiple GTs via 1:N communication (GT link)
- · Connecting using the general-purpose serial communication mode
- · As for the 5 V DC-type GT01, power can be supplied with a communication cable only.


4.1.1 PLC Multiple Connection

PLC multiple connection function is a function that enables more than one PLCs to connect with one GT.



4.1.2 GT Link Connection

GT link function is a function that enables more than one GT to connect with one PLC.



Wiring of Power Supply

It takes more than 5 seconds for all GT units to be operable after turning on the power supply of GT. (The time varies according to conditions and the number of connected GT units.)

As for the power supply of GT, it is recommended to use the wiring that enables multiple GT units to be simultaneously turned on.

If the power supplies of multiple GT units cannot be simultaneously turned on after turning on the power supply of devices such as a PLC, an error message will be displayed and it may take some time to make communication to be established.

(The error display disappears when all the GT units become operable.)

4.1.3 Connecting to the PLCs made by Other Companies

For information on the connection with PLCs manufactured by other companies, see the latest GTWIN HELP or our website (http://industrial.panasonic.com/ac/e/dl_center/manual) where you can get the manual.



Reference: < Connection with Other Companies' PLCs Manual ARCT1F449E>

4.1.4 Connecting to a Serial Device

Devices other than PLCs can be connected by using the general-purpose serial communication mode of the GT. Also, PLCs made by other companies which are not put on our website can be used. See our website or the GT series General-purpose serial communication manual.



Reference: <GT Series General-purpose Serial Communication Manual ARCT1F356E>

4.1.5 Electric Supply from PLC (5 V DC-type)

The power can be supplied to the 5V DC-type with the communication cable only. The power supply is not required separately. However, it is available only when it is connected with the TOOL port.

Restriction on the capacity of the power supply depending on the PLC model to be used The number of PLC units that can be expanded is limited.

PLC model	Restrictions when connecting a 5 V DC-type		
FP-X	The number of units which can be expanded depends on the unit type.		
FP0	Maximum of two expansion units *		
FPΣ	Maximum of six expansion units *		
FP2	The method for calculating the number of units that can be expanded is provided in the manual. Follow that formula and keep the GT01's power		
FP2SH	consumption not higher than 200 mA when calculating.		
FP-e/FP0R	There are no particular restrictions.		
FP7	Keep the unit's 24 V power consumption not higher than 100 mA when calculating.		
FX series made by Mitsubishi Electric Co.	The restrictions are equivalent to the restrictions on the programmable display F920 (5 V power supply type) made by Mitsubishi. Use the FX series according to the use conditions for the F920 (5 V power supply type).		

^{*} Expansion is possible with the number of units given above, regardless of the type of unit.

4.2 RS232C Connection

4.2.1 Difference of Terminal blocks Between GT Models

Although the terminal blocks vary according to the GT models, the connection method is the same. The connection diagram for 24 V DC is described with the terminal blocks other than the one for GT01.

24 V DC type other than GT01

GT side (24V DC RS232C)

	Pin name	Signal		
0	+	+24V		
0	-	0V		
0	FG	FG		
0	SD	SD		
0	RD	RD		
0	RS	NC		
0	CS	NC		
0	SG	SG		

24 V DC-type GT01

GT side (GT01, 24V DC RS232C)

	Pin name	Signal
0	+	+24V
0	-	0V
0	NC	NC
0	SD	SD
0	RD	RD
0	NC	NC
0	NC	NC
0	SG	SG

5 V DC-type GT01

GT side (5V DC RS232C)

	Pin name	Signal	
0	+	+5V	
0	-	0V	
0	NC	NC	
0	SD	SD	
0	RD	RD	
0	NC	NC	
0	NC	NC	
0	SG	SG	


5 V DC-type GT02/GT02L

GT side (5V DC RS232C)

	Pin name	Signal
0	+	+5V
0	-	0V
0	FG	FG
0	SD	SD
0	RD	RD
0	RS	NC
0	CS	NC
0	SG	SG

4.2.2 RS232C Connection with PLC Tool Port







Usable models

PLC	PLC communication cable		Programmable	display
FP-X FPΣ FP0/FP0R FP-e FP2/FP2SH	Mini-DIN 5-pin loose-wire cable	AIGT8142	5 V DC type	RS232C type

Connecting to the TOOL port



PLC side	•			5V DC type GT side (5V	GT01 DC RS232C)
Pin No.	Signal	Cable color]	Pin name	Signal name
1	SG	Brown	ام ٥	+	+5V
2	SD	Red	a 70	-	0V
3	RD	Orange		NC	NC
4	-	-	0/0	SD	SD
5	+5V	White	0 0	RD	RD
-	SHELL	Black	0 0	NC	NC
			0	NC	NC
			0	SG	SG
					•






Note: Connecting to the COM port is not available.

- Keep the cable no longer than 3 m.
- In case of connecting to PLC with all expansion slots used, prepare an external 5 V DC power supply for the GT01 due to current consumption limits.
- When using the FP2/FP2SH, check whether or not the power can be supplied from the TOOL port according to the calculation method of the number of expansion units described in the hardware manual.


Connecting with 24 V DC type




Usable models

PLC	PLC comm	PLC communication cable		nmable display
FP-X				
$FP\Sigma$	M: DINE	AIGT8162		
FP0/FP0R	Mini-DIN 5-pin loose-wire cable	AIGT8165	24 V DC	RS232C type
FP-e	100Se-wire cable	AIGT8160		
FP2/FP2SH				


Connecting to the TOOL port





4.2.3 RS232C Connection with FP-X COM Port


Connecting to the COM port of FP-X Communication cassette




Usable models

PLC		PLC communication cable	Programmable display	
	AFPX-COM1			
	AFPX-COM2		5 V DC	
FP-X	AFPX-COM3	Loose-wire cable	24 V DC	RS232C type
	AFPX-COM4		24 V DC	
	AFPX-COM5			

Connecting to the 1- channel type RS232C




Connecting to the 2-channel type RS232C




	To power supply		GT side (24\	/ DC RS2320	2)
		A A	Pin name	Signal	
			+	+24V	
PLC side			-	0V	
Pin name	Signal name	0	FG	FG	
S1	SD	000	SD	SD	
R1	RD	0	RD	RD	
S2	SD	0 0	RS	NC	
R2	RD	0 0	CS	NC	
SG	SG	0	SG	SG	

As for the connection to S2 and R2 for COM2, make the same connection as S1 and S2.


Connecting to the 1-channel type RS485 and 1-channel type RS232C






Connecting to the 1-channel type Ethernet and 1-channel type RS232C


It cannot be connected with Ethernet.





4.2.4 RS232C Connection with FP Σ COM Port


Connecting to the COM port




Usable models


PLC	PLC communication cable	Prograr	nmable display
FPΣ	Loose-wire cable	5 V DC 24 V DC	RS232C type

Connecting to the 1-channel type RS232C





Connecting to the 2-channel type RS232C




	To po	wer supply	GT side (24)	/ DC RS232C)
		A A	Pin name	Signal	
			+	+24V	
PLC side		. —	-	0V	
Pin name	Signal name	0	FG	FG	
S1	SD	000	SD	SD	
R1	RD	0	RD	RD	
S2	SD	0 0	RS	NC	
R2	RD	0 0	CS	NC	
SG	SG	oo	SG	SG	

As for the connection to S2 and R2 for COM2, make the same connection as S1 and S2.

Connecting to the 1-channel type RS485 and 1-channel type RS232C


The connections with either one unit or two units are available.



		To power supply	GT side (24\	/ DC RS232C
		∆ Å	Pin name	Signal
		11-0	+	+24V
PLC side			-	0V
Pin name	Signal	0	FG	FG
S+	+		SD	SD
S-	-		RD	RD
SD	SD		RS	NC
RD	RD	$ $ \circ	CS	NC
SG	SG		SG	SG

4.2.5 RS232C Connection with FP0/FP0R COM Port


Connecting to the COM port




Usable models

PLC	PLC communication cable	Programmable display		
FP0 FP0R	RS232C type	5 V DC 24 V DC	RS232C type	


Connecting to the COM port of FP0/FP0R





4.2.6 RS232C Connection with FP-e COM Port


Connecting to the COM port




Usable models

PLC	PLC communication cable Programmable displa		nable display
FP-e	Loose-wire cable	5 V DC 24 V DC	RS232C type

Connecting to the FP-e (RS232C)




4.2.7 RS232C Connection with FP2/FP2SH COM Port



Usable models

ousie medele						
P	PLC		PLC communication cable		Programmable display	
FP2/FP2CH CPU unit						
FP2 Computer Communication Unit		D-SUB 9-pin				
FP2 Multi Communication		loose-wire cable	AIP81842	5 V DC	RS232C type	
Communication	block	1003e-Wile Cable		24 V DC		
Unit	FP2-CB232					

Connecting to the TOOL port



PLC side	:		To power	GT side (24\	/ DC RS232C)
Pin No.	Signal	Cable color (Dot mark)	supply	Pin name	Signal
1	FG	Brown (Black dot)		+	+24V
2	SD	Brown (Red dot)	Q —	-	0V
3	RD	Yellow (Black dot)	0 0	FG	FG
4	RS	Yellow (Red dot)	07 /0	SD	SD
5	CS	Green (Black dot)	9 9	RD	RD
6	N.C.	-	0 0	RS	NC
7	SG	Green (Red dot)	00	CS	NC
8	N.C.	-	0 ~0	SG	SG
9	ER	-	0		

4.3 RS422 Connection

4.3.1 Difference of Terminal blocks Between GT Models

Although the terminal blocks vary between the 5 V DC type and 24 V DC type, the connection method is the same.

The connection diagram is described with the terminal block for 24 V DC.

24 V DC type

GT side (24V DC RS422/485)

	Pin name	Signal
0	+	+24V
0	-	0V
0	FG	FG
0	+SD	+SD
0	-SD	-SD
0	+RD	+RD
0	-RD	-RD
0	Е	E

5 V DC-type GT01

GT side (5V DC RS422/485)


	Pin name	Signal
0	+	+5V
0	-	0V
0	NC	NC
0	+SD	+SD
0	-SD	-SD
0	+RD	+RD
0	-RD	-RD
0	Е	E

5 V DC-type GT02/GT02L

GT side (5V DC RS422/485)

	Pin name	Signal
0	+	+5V
0	-	0V
0	FG	FG
0	+SD	+SD
0	-SD	-SD
0	+RD	+RD
0	-RD	-RD
0	Е	E


4.3.2 RS422 Connection with FP-X COM Port




Usable models

PLC		PLC communication cable	Programmable display	
FP-X	AFPX-COM3	Loose-wire cable	5 V DC 24 V DC	RS422/RS485 type

Connecting to the FP-X Communication cassette, 1-channel type RS485/RS422





(Rear switch of cassette)

No. 1	OFF
No. 2	OFF
No. 3	OFF
No. 4	OFF


4.3.3 RS422 Connection with FP2/FP2SH COM Port


Connecting to the COM port To power supply GT series


Usable models

PLC		PLC communication cable		Programmable display	
FP2 Multi Communication Unit	Communication block FP2-CB422	D-SUB 9-pin loose-wire cable	AIP81842	5 V DC 24 V DC	RS422/ RS485 type


Connecting to the FP2 Multi Communication Unit (MCU) + Communication block (RS422)








4.3.4 RS422 Connection with C-NET Adapter



Usable models

PLC	PLC communication cable		Programmable display	
FP series	C-NET adapter	AFP8536 AFP8532 AFP15401 AFP15402	5 V DC 24 V DC	RS422/RS485 type

Connection method



Communication settings on the PLC side

Specify the setting to match with the setting for the GT using the tool software at the PLC side.

C-NET adapter setting

Set the termination (TERMINATE) to on.

4.4 RS485 Connection

4.4.1 Difference of Terminal blocks Between GT Models

Although the terminal blocks vary between the 5 V DC type and 24 V DC type, the connection method is the same.

The connection diagram is described with the terminal block for 24 V DC.

24 V DC type

GT side (24V DC RS422/485)

	01 3ide (247 DO 110422						
	Pin name	Signal					
0	+	+24V					
0	-	0V					
0	FG	FG					
0	+SD	+SD					
0	-SD	-SD					
0	+RD	+RD					
0	-RD	-RD					
0	Ш	E					

5 V DC-type GT01

GT side (5V DC RS422/485)

Pin name	Signal			
+	+5V			
-	0V			
NC	NC			
+SD	+SD			
-SD	-SD			
+RD	+RD			
-RD	-RD			
Е	E			
	+ - NC +SD -SD +RD -RD			

5 V DC-type GT02/GT02L


GT side (5V DC RS422/485)

	Pin name	Signal
0	+	+5V
0	- 0V	
0	FG	FG
0	+SD	+SD
0	-SD	-SD
0	+RD	+RD
0	-RD	-RD
0	Е	E

Note) RS485 communication is performed using the RS422 terminal blocks.

4.4.2 RS485 Connection with FP0R COM Port


Connecting to the COM port





Usable models

PLC	PLC communication cable	Programmable display	
FP0R RS485 type	Loose-wire cable	5 V DC 24 V DC	RS422/RS485 type


Connecting to the COM port of FP0R








4.4.3 RS485 Connection with FP-X COM Port



Usable models

PLC		PLC communication cable	Programmable display	
	AFPX-COM3		5 V DC	
FP-X	AFPX-COM4	Loose-wire cable	5 V DC 24 V DC	RS422/RS485 type
	AFPX-COM6		24 V DC	


Connecting to the FP-X Communication cassette, 1-channel type RS485/RS422




.

Connecting to the 1-channel type RS485 and 1-channel type RS422


AFPX-COM4 COM4 RS485 RS232C RS58 RS232C RS58 RS232C



PLC multiple communication



GT Link Function






Connecting to the 2-channel type RS485

AFPX-COM6




1:1 communication




Note) As for the connection to the "+" and "-" for the COM2, make the same connection as the "+" and "-" for the COM1.

PLC multiple communication



Note) As for the connection to the "+" and "-" for the COM2, make the same connection as the "+" and "-" for the COM1.

GT Link Function




Note) As for the connection to the "+" and "-" for the COM2, make the same connection as the "+" and "-" for the COM1.

%

4.4.4 RS485 Connection with FP Σ COM Port


Connecting to the COM port





Usable models

PLC		PLC communication cable	Programmable display	
FPΣ	AFPG803	Lanca videa anhla	5 V DC	DC422/DC495 tupo
FPL	AFPG806 Loose-wire cable	24 V DC	RS422/RS485 type	

Connecting to the 1-channel type RS485











Connecting to the 1-channel type RS485 and 1-channel type RS232C



.

4.4.5 RS485 Connection with FP-e COM Port

Connecting to the COM port




Usable models


PLC		PLC communication cable	Programmable display	
FP-e	RS485 type	Loose-wire cable	5 V DC 24 V DC	RS422/RS485 type

Connecting to the FP-e (RS485)


1:1 communication



PLC multiple communication




4.4.6 RS485Connection with FP2/FP2SH



Usable models

PLC		PLC PLC communication cable		Programmable display	
FP2 Multi Communication Unit	Communication block FP2-CB485	Loose-wire cable	5 V DC 24 V DC	RS422/ RS485 type	


Connecting to the FP2 Multi Communication Unit (MCU) + Communication block (RS485)



.

4.4.7 Precautions When Communicating With RS485

When communication with the RS485, the transmission line for sending and receiving data is the same.



① Time taken until the connected device sends a response after sending a command from the GT:

If a response is sent too quickly, the GT may not be able to receive it. Adjust the time if necessary. For our FP series FP Σ or FP-X, the time can be specified using the SYS1 instruction.


2 Time taken until the GT sends a next command after receiving a response:

If a command is sent to quickly, the connected device may not be able to receive it. The time can be specified in the delay time setting for transmission in the communication parameter of the GTWIN configuration setting.

4.5 Connection With a PLC

4.5.1 Automatic Communication Settings Function

After turning on the power supply, if there is not response from the PLC connected to the GT, the GT switches to the automatic setting mode for the communication conditions. In the automatic setting mode, commands are sent to the PLC while changing the communication conditions in the sequence shown below.



The GT, in automatic setting mode, continues to repeat steps ① to ④ until there is a response from the PLC. While it is repeating these steps, it is in the "Standby" mode under "Configuration" → "Communication Parameters" → "Handle Communication Error" on GTWIN.



Explanation of this function:

- Conditions when the automatic settings mode is in effect
 If communication is attempted the specified number of times and there is no response from the PLC,
 the GT goes into the automatic settings mode. The number of attempts is specified using the "No. of
 Retries" parameter under "GT Configuration" → "Communication Parameters" → "Handle
 Communication Error" on GTWIN.
- Automatically set communication conditions
 In the automatic settings mode, if there is a response from the PLC, subsequent communication is carried out under conditions matching the response. The main unit configuration settings are not updated, however, even if the communication parameters are different from those of the main unit configuration settings.




Note:


- An error response from the PLC is taken as a response, and the GT does not go into the automatic settings mode.
- If the unit is connected to the COM port of the FP0/FP1/FP2/FP2SH/FP-M, communication between the FP device and the PLC will not be possible if the target usage of the RS232C port has not been set to "Computer Link". Always set the setting on the PLC side to match "Computer Link".
- The automatic communication settings function cannot be used for the communication at 230400 bps on the GT01, GT11 or GT21.

4.5.2 Through Function

With the GT series, communication can be set to take place automatically between the COM port of a GT and TOOL port of a PLC in a "through function". When the FP series/FP7 series tool software installed in the computer connected to the GT series as shown below is booted, PLC programs can be edited through the GT series. For using the through function, the settings for the communication between "PC and GT series" and "GT series and our PLC" should be the same. The through function does not require any special settings, and is always in the standby mode.



For USB port type





• Precautions when using the through function

The system should be set up so that the Timeout period in the FP series software (FPWIN) (A) is larger than the waiting time for communication retries of the GT COM port (B), meaning (A) > (B). If the system is set up so that A = B or A < B, the through function will not work properly. When the baud rate of the GT TOOL port is 230400 bps, the through function cannot be used. Communicate at 115200 bps or lower for using the through function.


• For the USB port type, the OS installed in the connected computer must be Windows®2000 or later.

• Restrictions on COM port connections

When connecting the GT01 to the COM port of a PLC, a separate external supply must be provided.

• When using the FP programmer II

An FP Programmer II cannot be connected to the tool port of the GT01. It can be connected to the GT11 and GT21. The FP programmer II cannot be connected to the models which are connected with a USB or Ethernet cable.



Procedure of making communication settings when using the through function


1. Match the communication settings of GT series to those of our PLC.

The setting method of the GT series is as follows.


For details of the setting method of our PLCs, refer to "4.5.3 Communication Settings of PLC using FPWIN GR" or "4.5.4 Communication Settings of PLC using FPWIN GR7".

Make the communication settings using GTWIN.

- 1. Select "File" > "Configuration" > "GT Configuration" from the menu bar.
- 2. Select " Communication Parameters" and make the communication settings.



- 2. Install the USB driver of the GT series to a computer on which the FPWIN GR is used.
- 1. Start "Update Driver Software" from the device manager of the computer, and select the folder where the USB driver is stored.




2. Select "Browse for driver software on your computer" and specify a folder for storing the driver in the "Update Driver Software" dialog box.

[Driver storage folder]

- ·For Windows7 (64-bit)


 \Program Files(x86) \Panasonic-ID SUNX Terminal\GTWIN\GTWIN_USB\x64
- ·For other Windows OS \Program Files\Panasonic-ID SUNX Terminal\GTWIN\GTWIN_USB\x86



For details of "Update Driver Software", refer to "Procedure of Installing USB Driver" of "GTWIN Installation Guide". 3. Set the network type of FPWIN.


When using FPWIN GR

- 1. Select "Option (O)" > "Communication Settings (C)" from the menu bar.
- 2. Set the network type to "USB(GT)".



When using FPWIN GR7


- 1. Select "Online (L)" > "Communication Settings (C)" from the menu bar.
- 2. Set the computer communication port to "USB(GT)".



4.5.3 Communication Settings of PLC using FPWIN GR


Please read below to make PLC communication settings using the FPWIN GR.

1. Select "Option (O)" > "PLC Configuration".




2. Make the communication settings.

Select "Tool Port" setting when connecting to the tool port or "COM Port" setting when connecting to the COM port. Please match the communication format (or transmission format) and baud rate settings to those of the GT.



In addition to the transfer format and baud rate settings, set the communication mode to "Computer Link" when using the COM port.



<Default>

Stop Bit: 1

Comm. Mode: Computer Link

Baud Rate: 9600 bps Char. Bit: 8 bits Parity: Odd


Note) The baud rate can be changed from 9600 bps.

When changing it, it is necessary to make the both baud rates of FP series and GT series be the same.

4.5.4 Communication Settings of PLC using FPWIN GR7


Please read below to make PLC communication settings using the FPWIN GR7.

1. Select "Options (O)" > "FP7 Configuration (C)" > "Built-in SCU".



2. Make the communication settings.

Set the communication settings of the communication port connected to the GT to be the same as those of the GT.



<Default>

Communication Mode: MEWTOCOL-

COM

Baud rate: 9600 bps Data length: 8 bits

Parity: Odd Stop bit: 1 bit

Note) The baud rate can be changed from 9600 bps.

When changing it, it is necessary to make the both baud rates of FP series and GT series be the same.

Chapter 5

Troubleshooting

5.1 What to DO If Something Unusual Occurs (GT01/GT11/GT21)

Problem	Cause	Solution
Screen is blank	1) Power is not on.	Supply the power supply to unit as per specifications.
	(When only lamp and message parts are configured to the base screen) Value of substitute reference device value does not exist in substitute data.	Check the address of the substitute reference device and the device values on the PLC side.
Error code [ER**] appears at the top right of the screen	An error has occurred in communication between the GT and an external device (e.g. PLC).	Refer to <5.3 Troubleshooting Error Codes>.
Screen displays [No Screen data]	There is no base screen data in the GT. (Appears even when GT configuration data exists.)	Transfer base screen data.
Screen displays [Screen No.	Screen settings from the PLC, the GT's switch part or the auto-paging indicate an unregistered screen number.	Create and register screen content or specify the correct screen number.
Error]	When bringing up the keyboard screen during data input, an unregistered keyboard screen number was specified.	Create and register keyboard screen or specify the correct keyboard number.
	GT configuration data and keyboard screen data exist in the GT, but there is no base screen data.	3) Transfer base screen data from GTWIN.
Screen displays [Memory is Full]	The total capacity of transferred base screen data exceeds the 384 Kbyte capacity of the GT.	Delete part of the base screen data so that the capacity doesn't exceed the total capacity. Data capacity can be checked by going to [View (V)]→[Memory Usage Conditions] on GTWIN menu bar. When the data capacity is not over the limit, invalid data could possibly be remaining in the GT. When transferring data, do so after deleting the screen.
An unspecified screen	The screen specification in the PLC screen setting, the GT switch part or the auto-paging is wrong.	Specify the correct screen number.
appeared/th ere is trouble when switching	The startup screen is specified in the GT configuration settings (GTWIN).	Check the start-up screen setting for the GT configuration settings in GTWIN. Delete unnecessary settings and re-transfer configuration data.
screens.	An erroneous device or value is specified in the first word of the basic communication area word device.	Check the device content specified on the PLC side in the first word of the basic communication area. (Do not use the basic communication area with ladder programs.)

Problem	Cause	Solution
Screen	1) No screen number has been written to	1) Specify correct screen number.
doesn't	the screen setting area (the first word	
switch	in the basic communication area word	
	device) from the PLC.	
	2) The screen number to which you are	2) Refer to Reference Manual.
	attempting to switch has already been	
	written from the PLC to the screen	
	setting area (the first word in the basic	
	communication area word device.)	
Screen is	1) The power voltage may be low.	1) Check the capacity of the power supply unit if it is
dim		enough for the GT's power consumption.
	2) The contrast is set too low.	Bring up the system menu and adjust the contrast.
	The backlight brightness is set too	3) Bring up the system menu and adjust the
	dark.	brightness.
	4) The backlight is off due to the	4) Touching any area of the screen lights that area. If a
	[Backlight Auto-off] setting in the	switch part is set on the touched area, the area will
	[Setup] of the GT configuration	not light even if touched. To change the setting,
	settings in GTWIN.	change the content of the backlight auto-off settings.
Backlight	1)The backlight auto-off timer setting is	Change the backlight auto-off timer setting.
goes off too	too short.	
quickly		
Date/time	The PLC's internal calendar timer	1) Adjust by rewriting the value in the PLC's internal
display is	used as a reference is incorrect.	calendar timer.
incorrect		1) 21 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1
Touch panel	1) Valid conditions have been set for the	1) Check that the device status conditions on the PLC
doesn't work	switch part, but those conditions have	side are valid.
Nie za zastie s	not been met.	A) Ohanna tha antiform to [Facility II]
No operating sounds are	1) The [Switch Sounds] setting under	1) Change the setting to [Enabled].
heard when	[Options] in the switch part attributes	
the touch	is set to [Disabled].	2) Change the cetting to [Fachled]
panel is	2)The [Touch Sounds] setting under [Setup] in the GT configuration	2) Change the setting to [Enabled].
pressed.	• • • •	
Nothing	settings in GTWIN is set to [Disabled]. Communication conditions of GT (COM	Verify communication settings of GT and PLC and
happens for	port) and PLC differ.	then make them the same.
about 10	porty and r Lo amor.	then make them the same.
seconds		
after turning		
on power.		

Problem	Cause	Solution
Buzzer sounds	Bit F of the first word in the basic	Set the F bit to OFF on the PLC side. (Do not use the
continuously	communication area bit device is set	basic communication area with ladder programs.)
	to ON.	
Backlight color	Bits A and B, and Bit D, of the first	Perform correct bit operations on the PLC side. (Do not
changes/	word (backlight color setting) in the	use the basic communication area with ladder
flashes	basic communication area bit device	programs.)
	are set to ON. Or, Bits C and D	
	(backlight flashing setting) are set to	
	ON.	
Cannot transfer	1) The screen transfer cable is not	Confirm that the screen transfer cable is correctly
data from	connected.	and firmly connected.
GTWIN	2) The PC and GT COM port are	2) Connect to TOOL port with screen transfer cable.
	connected.	
	3) The TOOL port of the GT has	3) Set the baud rate for the GTWIN communication
	been set to 230400 bps.	condition to 230400 bps before transfer data.
	4) The network type in the	4) Set the network type in the communication settings
	communication settings has been	to "RS232C".
	set to either "Ethernet" or "USB".	
- Screen is blank	An error has occurred in the GT	1) After confirming the safety of the device, etc., turn
(power supply	system.	off the power supply and then turn it on again. The
and		GT CPU will be reset.
substitution		П
settings noted		₹ 7
above do not		2) If 1) produces no change, bring up the system
apply)		menu and initialize the memory (F-ROM), then
- An incorrect		transfer data again from GTWIN to the GT.
screen is		NOTE:
displayed		When doing this, all base screen data, GT setting
(error codes		data, keyboard screen data, and bitmap data will
and erroneous		be lose. Before doing this, make sure all data has
date and time		been backed up.
items noted		П
above do not		7.7
apply)		3) If 2) produces no change, set the operating mode
- Switch doesn't		setting switches 2, 3 and 4 on the rear of the main
work (grid and		unit to ON and reset the power supply.
validity settings		NOTE:
noted above		When doing this, all of the contents will revert to
are correct)		those in effect at the time of shipping, and all of the
- Buzzer sounds		GT memory contents will be cleared. Before doing
continuously		this, make sure all data has been backed up.

The backlight flashes for a while when the F-ROM clear is executed.

Once the F-ROM clear is complete, the buzzer sounds and the message "Memory is cleared" is displayed on the screen.

Set the operation mode setting switches to the state in the normal use after confirming this message, and turn on the power again.

5.2 What to DO If Something Unusual Occurs (GT02/GT02L/GT03-E/GT05/GT12/GT32/GT32-R/GT32-E)

Problem	Cause	Solution
Screen is blank	1) Power is not on.	Supply the power supply to unit as per specifications.
	(When only lamp and message parts are configured to the base screen) Value of substitute reference device value does not exist in substitute data.	Check the address of the substitute reference device and the device values on the PLC side.
Error code [ER****] appears at the top right of the screen	An error has occurred in communication between the GT and an external device (e.g. PLC).	Refer to <troubleshooting codes="" error="">.</troubleshooting>
Screen displays [No Screen data]	There is no base screen data in the GT. (Appears even when GT configuration data exists.)	Transfer base screen data from GTWIN.
Screen displays [Screen No. Error]	Screen settings from the PLC, the GT's switch part or the auto-paging indicate an unregistered screen number.	Create and register screen content or specify the correct screen number.
	When bringing up the keyboard screen during data input, an unregistered keyboard screen number was specified.	Create and register keyboard screen or specify the correct keyboard number.
	GT configuration data and keyboard screen data exist in the GT, but there is no base screen data.	3) Transfer base screen data from GTWIN.
	-	Press [ESC] button to return to the previous screen.
[Memory is Full] screen data exceeds the memory capacity of the GT. capacity doesn't exceed the tol Data capacity can be checked (V)]→[Memory Usage Condition menu bar. When the data capa limit, invalid data could possibly the GT. When transferring data		Delete part of the base screen data so that the capacity doesn't exceed the total capacity. Data capacity can be checked by going to [View (V)]→[Memory Usage Conditions] on GTWIN menu bar. When the data capacity is not over the limit, invalid data could possibly be remaining in the GT. When transferring data, do so after deleting the screen.
An unspecified screen appeared/there is trouble when	The screen specification in the PLC screen setting, the GT switch part or the auto-paging is wrong.	Specify the correct screen number.
switching screens.	The startup screen is specified in the GT configuration settings (GTWIN).	Check the start-up screen setting for the GT configuration settings in GTWIN. Delete unnecessary settings and re-transfer configuration data.
	An erroneous device or value is specified in the first word of the basic communication area word device.	Check the device content specified on the PLC side in the first word of the basic communication area. (Do not use the basic communication area with ladder programs.)
Screen doesn't switch	No screen number has been written to the screen setting area (the first word in the basic communication area word device) from the PLC.	1) Specify correct screen number.
	The screen number to which you are attempting to switch has already been written from the PLC to the screen setting area (the first word in the basic communication area word device.)	2) Refer to Reference Manual.

Problem	Cause	Solution
Screen is dim	1) The power voltage may be low.	Check the capacity of the power supply unit if it is enough for the GT's power consumption.
	2) The contrast is set too low.	2) Bring up the system menu and adjust the contrast.
	The backlight is off due to the [Backlight Auto-off] setting in the [Setup] of the GT configuration settings in GTWIN.	3) Touching any area of the screen lights that area. If a switch part is set on the touched area, the area will not light even if touched. To change the setting, change the content of the backlight auto-off settings.
Backlight goes off too quickly	1)The backlight auto-off timer setting is too short.	Change the backlight auto-off timer setting.
Date/time display is	The GT's internal clock used as a reference is incorrect.	1) Adjust the clock from the system menu.
incorrect (when using the	2) No battery has been inserted.	2) Purchase a battery and install it.
GT's internal clock)	3) The battery has run down.	3) Replace the battery.
Date/time display is incorrect (when using the PLC's internal calendar timer)	The PLC's internal calendar timer used as a reference is incorrect.	Adjust by rewriting the value in the PLC's internal calendar timer.
Hold PLC Device data	1) No battery has been inserted.	1) Purchase a battery and install it.
content isn't saved	2) The battery has run down.	2) Replace the battery.
Date/time display is incorrect	The PLC's internal calendar timer used as a reference is incorrect.	Adjust by rewriting the value in the PLC's internal calendar timer.
Touch panel doesn't work	Valid conditions have been set for the switch part, but those conditions have not been met.	Check that the device status conditions on the PLC side are valid.
No operating sounds are heard when the	The [Switch Sounds] setting under [Options] in the switch part attributes is set to [Disabled].	1) Change the setting to [Enabled].
touch panel is pressed. (Except GT02L)	2)The [Touch Sounds] setting under [Setup] in the GT configuration settings in GTWIN is set to [Disabled].	2) Change the setting to [Enabled].
Nothing happens for about 10 seconds after turning on power.	Communication conditions of GT (COM port) and PLC differ.	Verify communication settings of GT and PLC and then make them the same.

Problem	Cause	Solution
Buzzer sounds	Bit F of the first word in the basic Set the F bit to OFF on the PLC side. (Do not us	
continuously	communication area bit device is set to ON.	basic communication area with ladder programs.)
Backlight color changes/ flashes	Bits A and B, and Bit D, of the first word (backlight color setting) in the basic communication area bit device are set to ON. Or, Bits C and D (backlight flashing setting) are set to ON.	Perform correct bit operations on the PLC side. (Do not use the basic communication area with ladder programs.)
Cannot transfer data from	The USB or LAN cable (GT32T1) is not connected.	Confirm that the screen transfer cable is correctly and firmly connected.
GTWIN	The PC and GT COM. port are connected.	Connect the USB cable or LAN cable (GT32T1) correctly.
	The network type in the communication settings has been set to "RS232C".	Set the network type in the communication settings to "Ethernet" for using a LAN cable. Set the network type to "USB" for using a USB cable.
- Screen is blank (power supply and substitution settings noted	An error has occurred in the GT system.	After confirming the safety of the device, etc., turn off the power supply and then turn it on again. The GT CPU will be reset.
above do not apply) - An incorrect screen is displayed (error codes and erroneous date and time items noted above do not		2) If 1) produces no change, bring up the system menu and initialize the memory (F-ROM), then transfer data again from GTWIN to the GT. NOTE: When doing this, all base screen data, GT setting data, keyboard screen data, and bitmap data will be lost. Before doing this, make sure all data has been backed up.
apply) - Switch doesn't work (grid and validity settings noted above are correct) - Buzzer sounds continuously		3) If 2) produces no change, set the operating mode setting switches 2, 3 and 4 on the rear of the main unit to ON and reset the power supply. NOTE: When doing this, all of the contents will revert to those in effect at the time of shipping, and all of the GT memory contents will be cleared. Before doing this, make sure all data has been backed up.
No sound is output.	1) The speaker is not connected.	1) Connect an audio output equipment (speaker with a built-in \$\phi 3.5-mini plug amplifier).
	2) The setting for using sound is not on.	Set the sound setting of the GTWIN configuration settings to be on.

The backlight flashes for a while when the F-ROM clear is executed.

Once the F-ROM clear is complete, the buzzer sounds and the message "Memory is cleared" is displayed on the screen.

Set the operation mode setting switches to the state in the normal use after confirming this message, and turn on the power again.

Operation security function

Message	Cause	Solution
"Incorrect password." Is	An unregistered password was	Enter the registered password.
displayed on the login	entered.	
screen.		
"Incorrect password." Is	An incorrect password was entered in	Enter the registered password
displayed on the	the Current password field.	correctly.
password change screen.		
"Please verify your	The entered New password and	Enter the same password in
password again." Is	Confirm password are different.	the New password and
displayed on the		Confirm password fields.
password change screen.		
"Use another password."	The password that has been already	Enter an unregistered new
Is displayed on the	registered is tried to be registered.	password.
password change screen.		
"Password setting	There are items that are not entered.	Enter all items.
incomplete." Is displayed		
on the password change		
screen.		
"Your password cannot	Your password was tried to be	Your password cannot be
be deleted." Is displayed	deleted.	deleted. If you want to delete it,
on the password		delete from the "Operation
management screen.		security password edit" on
		GTWIN.
"Your level cannot be	Your level was tried to be changed.	Your level cannot be changed.
changed" is displayed on		If you want to change it,
the password		change from the "Operation
management screen.		security password edit" on
		GTWIN.

When using the SD memory card.


Data may be erased or the SD memory card may be damaged during the operation. Take measures for the situations as below.

Problem	Measures	
	Transmitting GT configuration setting file using the logging function clears the information on the SRAM.	
Data in SRAM	Save all the data remained in the log before transmission.	
(Record area for	When data cannot be saved in the SD memory card, the data beginning with the	
logging) is lost.	chronologically oldest data will be overwritten if the record area for logging is full.	
	Make the setting of the notice device for the case that the SD card free space is	
	less than the specified size.	
SD memory card is	Stop the logging of data.	
damaged and data	Eject the SD memory card after turning on the setting for stopping the trigger	
cannot be read	occurrence for all logging files in the record area control.	
because SD	(Activate the setting for stopping the trigger occurrence with switch parts, etc.)	
memory card was	Set not to save in the SD memory card.	
ejected during save.	Turn on the control device for stopping write to the SD memory card, and then	
J	eject the card.	
	A UPS (Uninterruptible power source) is used. When using a UPS, the power is	
	supplied to the PLC and GT both from the UPS, and the signal for logging	
	stop/file creation is sent to the GT from the PLC using the power failure alarm	
	signal that is input into the PLC as a trigger. (See figure below.) A ① Occurrence of power outage	
SD memory card is	() Occurrence of power outage	
damaged by power	Power supply backup	
discontinuity due to	③ Power outage detection signal ON	
power failure and	PLC GT	
data cannot be read		
	Power supply	
	Logging stops	

5.3 Error Codes and How to Handle Them

5.3.1 About Error Codes

When an error occurs in the GT series, an error code displays at the top right of the screen. There are two types of error codes, GT series error codes and PLC error codes.



5.3.2 GT Series Error Codes

The following error codes are displayed when there is an error in the GT.

For GT01, GT11 and GT21

Code No.	Content	Cause and solution
ERFF	Time up error No response from the PLC.	 The PLC connection cable is disconnected. Check the connection cable to make sure it is connected. There is a temporary error due to noise, etc. Re-supply power to the PLC and GT.
ER21	Data error A data error occurred during communication.	 An error exists in the communication condition settings. Check the PLC and GT baud rate and transfer format. There is a temporary error due to noise, etc. Re-supply power to the PLC and GT.
ER22	Overrun error The GT cannot receive data.	The reception buffer in the GT is overflowing. There could be an error in the PLC Re-supply power to the PLC and GT.

Code No.	Content	Cause and solution
**00FF	Time up error	The PLC connection cable is disconnected. Check the connection cable to make sure it is connected. There is a temporary error due to noise, etc. Re-supply power to the PLC and GT.
**0100	Keyboard screen data parts digit error	Check if the digit of the data parts on the keyboard screen has been set correctly.
**0101	Alarm history error	When updating the alarm history display is stopped, alarm history data displayed on the GT's screen has been updated within the memory. Once the stop of display update is cancelled, new data is displayed.
**0102	True Type font file transfer error	Screen data is not transferred correctly. Re-transfer after deleting all data.
**0500	Tool setting error	The device that cannot be used is specified for the data. Check if the used device is correct. (e.g. the word device is set in the bit area.)
**1000	SD memory card not inserted	The SD memory card is not inserted to the SD memory card slot properly. Check the SD memory card slot.
**1001	SD memory card writing error	Data cannot be written to the SD memory card. Check whether the SD memory card is not write-protected.

Code No.	Content	Cause and solution
**1002	SD memory card memory full	Data cannot be written as the memory of the SD memory card has been exhausted. Delete some data in the SD memory card or prepare a new SD memory card.
**1003	SD memory card reading error	The data in the SD memory card cannot be read. Check whether the saved data in the SD memory card is not damaged with a PC.
**1004	SD memory card data error	The data loaded from a SD memory card does not match the GT type. Read the data in the SD memory card with GTWIN, and check whether it is not damaged.
**1005	SD memory card saved file name error	The file name to be saved to the SD memory card from the GT is not specified properly. Specify the file name properly.
**1006	SD memory card recognition error	The SD memory card cannot be recognized. Check the SD memory card used.
**1020	PLC model unmatch error	Check if the PLC program for transfer matches the destination PLC.
**1021	PLC model unsupported error	The selected PLC model is not supported. Confirm the PLC model.
**1022	Password protection error	 (1) Incorrect passwords were input three times or more. Input the correct password after turning the power supply off and then on again. (2) The upload protection has been set for the PLC. (3) The number of digits was changed when setting a new password with the FP monitor function. Cancel the password setting first to change the number of digits.
**1023	Master memory installation error	A master memory is installed in the PLC (FP-X).Programs cannot be transferred to the PLC with the master memory from a SD memory card.
**1024	Program memory shortage	Program memory shortage in the destination PLC. Decrease the program size using the PLC tool.
**1025	General-purpose memory shortage	General-purpose memory shortage in the destination PLC.
**1027	Remote mode error	The PLC (FP2/FP2SH) is set to the RUN mode. Change to the REMOTE mode or PROG. mode.
**102D	Forced operation error	Check if a device that cannot be forcibly operated in the PROG. mode has been forcibly turned on or off.
**1040		A SD memory card is not inserted. Check the SD memory card slot.
**1041	The record area for	Data cannot be written into the SD memory card. Check whether the SD memory card is not write-protected.
**1042	logging was overwritten.	As the memory of the SD memory card has been exhausted. Delete some data in the SD memory card or prepare a new SD memory card.
**1044		The setting to stop writing to SD memory card has been set. Cancel the writing stop setting.
**1043	SD memory card writing error	The setting to stop writing to SD memory card has been set. Cancel the writing stop setting.
**1045	The record area for logging cannot be reserved in the SRAM.	Transfer all data.
* * 10A0	FROM write error	The firmware file loaded from a SD card is damaged. Recreate the file in the SD card.
* * 1100	Ethernet IP address setting error	The IP address for Ethernet is not specified correctly. Check the IP address for the GT.

* * 1101	Ethernet subnet mask setting error	The subnet mask for Ethernet is not specified correctly. Check the subnet mask for the GT.
**1102	Ethernet default gateway setting error	The default gateway for Ethernet is not specified correctly. Check the default gateway for the GT.
* * 1103	Ethernet port number setting error	The port number for Ethernet is not specified correctly. Check the port number error for the GT.

Code No.	Content	Cause and solution
**1060	Index register value error	The device value for index modifier is out of the setting range. Check the setting value.
**1080	Start time device value error	The value at the start of the line graph function is out of the setting range. Check the setting value.
**2000	Connected GT designation area error The bit corresponding to the connected GT in the connected GT designation area.	The bit in the connected GT designation area corresponding to the station number of the connected GT is not on. Check the connected GT designation area.
20FF	Token error There is a GT unresponsive to the token.	 When the error code is indicated for a certain period of time after the power supply turned on.: 1. The timings for turning on multiple GT units are different. Arrange the wiring that enables the power supplies to be simultaneously turned on. 2. The screen displays for all GT units have not completed. The error code disappears when the screen displays for all GT units have completed. 3. The settings for the startup screen display vary. Make the same setting for all the connected GT units. When the error code is always indicated: 1. There is an unconnected or faulty GT. Check if there is a GT indicating [20FF]. Reconnect the GT, or turn off the bit in the connected GT designation area. 2. The communication parameters are not specified correctly. Check the baud rate and transmission format for the GT. 3. The same station number is used for more than one GT units. Check the station number setting of the connected GT units. 4. Another GT is reading a SD card. The indication disappears when reading the SD card has completed.
**F000	User's memory error	The memory for saving screen data may be damaged. Please contact us.

5.3.3 When Connected to a FP Series PLC

Error codes which are sent from the PLC are listed in the table below. For details, refer to the table of MEWTOCOL-COM communication errors in PLC user's manuals.

For GT01, GT11 and GT21

Code No.	Content	Cause and solution
ER21	Data error A data error occurred during communication.	 There is an error in the communication condition settings. Check the PLC and GT baud rate and transfer format. There is a temporary error due to noise, etc. Re-supply power to the PLC and GT.
ER22	Overrun error The PLC isn't receiving data.	The CPU unit's reception buffer is overflowing. There could be an error in the PLC. Re-supply power to the PLC and GT.
ER40	BCC error A data error occurred during communication.	1) There is a temporary error due to noise, etc. Re-supply power to the PLC and GT. 2) There is an error in the CPU unit. Re-supply power to the PLC and GT.
ER41	Format error The PLC has been sent a command that doesn't match the protocol.	1) There is a temporary error due to noise, etc. Re-supply power to the PLC and GT. 2) There is an error in the CPU unit. Re-supply power to the PLC and GT.
ER42	NOT support error The GT has sent a non-supported command to the PLC.	1) There is a temporary error due to noise, etc. Re-supply power to the PLC and GT. 2) There is an error in the CPU unit. Re-supply power to the PLC and GT.
ER53	BUSY error The PLC is currently processing another command.	A large amount of data is being communicated with another RS232C port on the PLC. Wait until the error is gone.
ER60	Parameter error	The specified parameter does not exist, or it cannot be used.
ER61	Data run error There is an error in the register or relay number.	A register or relay number which doesn't exist in the PLC was specified during screen creation using GTWIN. Correct the output device being used with the part, or the transfer of clock data to an external device.

For GT02, GT02L, GT03-E, GT05, GT12, GT32, GT32-R and GT32-E

Code No. Content		Cause and solution	
Code No.			
ER0021	Data error	1) There is an error in the communication condition settings. Check	
	A data error	the PLC and GT baud rate and transfer format.	
	occurred during	2) There is a temporary error due to noise, etc. Re-supply power to	
	communication.	the PLC and GT.	
	Overrun error	The CPU unit's reception buffer is overflowing.	
ER0022	The PLC isn't	There could be an error in the PLC.	
	receiving data.	Re-supply power to the PLC and GT.	
	BCC error	1) There is a temporary error due to noise, etc.	
ER0040	A data error	Re-supply power to the PLC and GT.	
	occurred during	2) There is an error in the CPU unit. Re-supply power to the PLC	
	communication.	and GT.	
	Format error	1) There is a temporary error due to noise, etc.	
	The PLC has been	Re-supply power to the PLC and GT.	
ER0041	sent a command	2) There is an error in the CPU unit. Re-supply power to the PLC	
	that doesn't match	and GT.	
	the protocol.	and of .	
	NOT support error	1) There is a temporary error due to noise, etc.	
	The GT has sent a	Re-supply power to the PLC and GT.	
ER0042	non-supported	2) There is an error in the CPU unit. Re-supply power to the PLC	
	command to the	and GT.	
	PLC.	4.14 61.1	
	BUSY error		
	The PLC is	A large amount of data is being communicated with another	
ER0053	currently	RS232C port on the PLC.	
	processing another	Wait until the error is gone.	
	command.		
ER0060			
	Parameter error	The specified parameter does not exist, or it cannot be used.	
	Doto rup orror	A register or relev number which decen't evict in the DLC was	
	Data run error There is an error in	A register or relay number which doesn't exist in the PLC was	
ER0061		specified during screen creation using GTWIN.	
	the register or	Correct the output device being used with the part, or the transfer	
	relay number.	of clock data to an external device.	

5.3.4 When Connected to a PLC (FX Series) Made by Mitsubishi Electric Corporation

For GT01, GT11 and GT21

Code No.	Content	Cause and solution
ERFF	Time up error There is no response from the PLC.	PLC connection cable is disconnected. Check the wiring of the connection cable and check for disconnection. It is a temporary error caused by noise, etc. Turn on the power supplies for PLC or GT again.
ER10	Data error A data error occurred during communication	Check for errors in the communication conditions settings.
ER12	Overrun error The GT cannot receive data.	PLC runaway might be the problem.
ER61	PLC error A NAK error has been returned from the PLC.	Verify the PLC settings.

1 01 0102, 0	01 0102, 01022, 0100 E, 0100, 0112, 0102, 0102 R and 0102 E		
Code No.	Content	Cause and solution	
ERFFFE	NAK error A NAK error has been returned from the PLC.	Verify the PLC settings.	

5.3.5 When Connected to a PLC Made by Omron Corporation

For GT01, GT11 and GT21

Code No.	Content	Cause and solution
ER00	Time up error There is no response from the PLC.	1) PLC connection cable is disconnected. Check the wiring of the connection cable and check for disconnection. 2) It is a temporary error caused by noise, etc. Turn on the power supplies for PLC or GT again.
ER01	Cannot be executed due to operation mode. (The PLC received the command that cannot be executed in the operation mode.)	Change the mode of the PLC from the operation mode to the monitor mode.
ER10	Data error A data error occurred during communication	Check for errors in the communication conditions settings.
ER12	Overrun error The GT cannot receive data.	PLC runaway might be the problem.
ER15	Numerical data error Designated read/write area is wrong.	Verify whether or not the reference device used with the basic communication area and each part is a readable and writable area.

- Error codes other than these are based on Omron PLC error codes.
- Be sure to used the PLC in monitor mode. Otherwise, communication will not work properly.

Code No.	Content	Cause and solution
ER0001	Cannot be executed due to operation mode. (The PLC received the command that cannot be executed in the operation mode.)	Change the mode of the PLC from the operation mode to the monitor mode.
ER0010	Data error A data error occurred during communication	Check for errors in the communication conditions settings.
ER0012	Overrun error The GT cannot receive data.	PLC runaway might be the problem.
ER0015	Numerical data error Designated read/write area is wrong.	Verify whether or not the reference device used with the basic communication area and each part is a readable and writable area.

- Error codes other than these are based on Omron PLC error codes.
- Be sure to used the PLC in monitor mode. Otherwise, communication will not work properly.

5.3.6 When Connected to Modbus

For GT01, GT11 and GT21

Code No.	Content	Cause and solution
ERFF	Time up error There is no response from the PLC.	 PLC connection cable is disconnected. Check the wiring of the connection cable and check for disconnection. It is a temporary error caused by noise, etc. Turn on the power supplies for PLC or GT again.
ERFE	Response error There is an abnormal response returned from the external device.	Check the data to be returned from the external device.

For GT02, GT02L, GT03-E, GT05, GT12, GT32, GT32-R and GT32-E

Code No.	Content	Cause and solution
**0001	Time up error There is no response from the PLC.	1) PLC connection cable is disconnected. Check the wiring of the connection cable and check for disconnection. 2) It is a temporary error caused by noise, etc. Turn on the power supplies for PLC or GT again.
**ERFE	Response error There is an abnormal response returned from the external device.	Check the data to be returned from the external device.

5.3.7 When Connected to a PLC Made by Toshiba Machine Co., Ltd.

Code No.	Content	Cause and solution
ERFFFE	Parameter error	The specified parameter does not exist, or it cannot be used.

5.3.8 When Performing General-purpose Serial Communication

For GT01, GT11 and GT21

Error code	Error name	Measures
ER00	BCC error	The value of BCC may be incorrect. Check if there is no calculation mistake.
ER01	Format error	A command format may be incorrect. Check if it is correct.
ER02	NOT supported error	A command used is not supported with the version of the GT. Upgrade the version of the GT, or use another command.
ER03	Address error	The address specified does not exist in the GT. Check the address of the transmitted command.
ER04	Receive buffer overflow	The sent command exceeds the receivable number of bytes. Check the number of bytes of the sent command.
ER05	Requested overflow	The sent readout command exceeds the number of bytes that can send back. Check the number of the read words.
ER06	Data error	The communication condition for the GT may be unmatched with the condition for a destination device. Check the communication conditions.
ER07	Data write inhibit error	A command for the address that writing is not available was sent. Check the address of the sent command.

Error code	Error name	Measures
**0000	BCC error	The value of BCC may be incorrect. Check if there is no calculation mistake.
**0001	Format error	A command format may be incorrect. Check if it is correct.
**0002	NOT supported error	A command used is not supported with the version of the GT. Upgrade the version of the GT, or use another command.
**0003	Address error	The address specified does not exist in the GT. Check the address of the transmitted command.
**0004	Receive buffer overflow	The sent command exceeds the receivable number of bytes. Check the number of bytes of the sent command.
**0005	Requested overflow	The sent readout command exceeds the number of bytes that can send back. Check the number of the read words.
**0006	Data error	The communication condition for the GT may be unmatched with the condition for a destination device. Check the communication conditions.
**0007	Data write inhibit error	A command for the address that writing is not available was sent. Check the address of the sent command.

Chapter 6

Specifications

6.1 GT01

6.1.1 General Specifications

	Specifications			
ltem	AIGT0030B AIGT0030H AIGT0130B AIGT0130H AIGT0230B AIGT0230H	AIGT0032B AIGT0032H AIGT0132B AIGT0132H AIGT0232B AIGT0232H	AIGT0030B1 AIGT0030H1 AIGT0130B1 AIGT0130H1 AIGT0230B1 AIGT0230H1	AIGT0032B1 AIGT0032H1 AIGT0132B1 AIGT0132H1 AIGT0232B1 AIGT0232H1
Rated voltage	24 V DC		5 V DC	
Operating voltage range	21.6 to 26.4 V DC		4.5 to 5.5 V DC	
Power consumption	2 W or less (80 mA or less)		1W or less (200 mA or less)	1.1 W or less (220 mA or less)
Ambient temperature	0 to +50 °C			
Ambient humidity	20 to 85% RH (at 25 °C), non-condensing			
Storage temperature	-20 to +60 °C			
Storage humidity	10 to 85% RH (at 25 °C), non-condensing			
Breakdown voltage	Between [power supply terminals] and [case] 500 V AC for 1 minute, Cutoff current 10mA (at default setting)			
Insulation resistance	Between [power supply terminals] and [case] 100 M Ω or more, 500 V DC, measured with megohmmeter (at default setting)			
Vibration resistance	10 to 55 Hz (1-minute cycle) Amplitude: 0.75 mm, 10 min on 3 axes			
Shock resistance	98 m/s ² or more, 4 times on 3 axes			
EMC Directive applicable	EMC Directive: EN61000-6-2, EN61000-6-4 Not applicable			
Noise immunity	1000 V [P-P] or more, Pulse width 50 ns, 1µs between power supply terminals (based on in-house measurements) Note2)			
Protective construction	IP65 (Initial value, evaluated by us) Dustproof and drip-proof from front panel only (packing used on panel contact surface) Note3)			
Weight	Approx. 160 g			

Note1) When supplying the power from the TOOL port of a PLC (CPU unit), confirm the PLC restrictions such as the power supply capacity before use.

Note3) When reattaching, replace waterproof packing.

Note2) When using our exclusive cable (24 V DC) and the ferrite core attached to the cable (5 V DC).

6.1.2 Performance Specifications (GT01)

Item		Specifications			
		AIGT0030B1	AIGT0130B1	AIGT0230B1	
		AIGT0030H1	AIGT0130H1	AIGT0230H1	
		AIGT0030B	AIGT0130B	AIGT0230B	
		AIGT0030H	AIGT0130H	AIGT0230H	
		AIGT0032B1	AIGT0132B1	AIGT0232B1	
		AIGT0032H1	AIGT0132H1	AIGT0232H1	
		AIGT0032B	AIGT0132B	AIGT0232B	
		AIGT0032H	AIGT0132H	AIGT0232H	
	Display device	STN monochrome LCD			
	Resolution	128 (W) x 64 (H) dots			
	Displayable area	70.38 (W) x 35.18 (H) mm			
	Backlight	3-color LED backlight	1-color LED backlight	3-color LED backlight	
Display		(green, orange, red)	(white)	(white, pink, red)	
	Backlight	Backlight brightness can be adjusted on the menu screen or GTWIN			
	brightness	configuration settings.			
	brightiness	(There are some minor variations in the backlight brightness.)			
	Contrast	Can be adjusted on the menu screen or GTWIN configuration settings.			
	Touch switch Analog touch switch (resistive film type)				
Touch switches	Touch switch operation	0.5 N or less			
	Life	1 million times or more (at 25 °C) Note1)			
Memory	F-ROM	Screen data (base, keyboard), Flow display data: 384 kbytes Note2)			

Note1) The touch position may shift due to aging variation. If the touch position has shifted greatly, please adjust it.

6.1.3 Function Specifications (GT01)

(Double or True Type (VIN): 1/4 width (8 x 8), half width (16 x 8), full width (16 x 16) quadruple in height and width) (GTWIN): 10 to 64 dots R): 10 to 64 dots canese, Korean, German, French, Italian, Spanish, Simplified
True Type (GTWIN): 10 to 64 dots R): 10 to 64 dots
1 -	R): 10 to 64 dots
\\/indaus /[
vvindows (F	panese, Korean, German, French, Italian, Spanish, Simplified
Character types English, Jap	,,,,,,,
Chinese, Ti	aditional Chinese characters, Turkish, Russian and Vietnamese can
be displaye	d.
Number of 160 screen	S Note1)
registerable screens	
Registerable screen Base scree	n: No. 0 to 3FF
number Keyboard s	creen: No. 0 to 7
Graphics Straight line	es, continuous straight lines, squares, circles, ovals, arcs, elliptic
arcs, fan sh	apes, elliptic fan shapes, beveled squares
Types of parts Switch	
Function sv	vitch
Lamp	
Message	
Data	
Bar graph	
Clock Note2)	
Line graph	
Keyboard	
	ssage, lamp, switch)
Main functions Note3) Recipe	
Flow displa	y
Write device	е
Multi langua	age exchange
Through function Connecting	a computer to TOOL port and our PLC to COM port enables the
communica	tion between the PLC and the computer.
Copy function *5 The screen	data can be copied by connecting the main units with a cable.
GTWIN ver. Ver. 2.30 o	later

Note1) Maximum allowable number varies depending on registered contents.

Note2) A clock part can be indicated by referring to external clock data. Clock function is not equipped in GT01.

Note3) It depends on the version of GT.

6.1.4 Interface Specifications (GT01)

Interface for connecting PLC/External devices

- COM port

		Specifications			
ltem		AIGT0030B1/AIGT0030H1 AIGT0030B/AIGT0030H AIGT0130B1/AIGT0130H1 AIGT0130B/AIGT0130H AIGT0230B1/AIGT0230H1 AIGT0230B/AIG0230H	AIGT0032B1 AIGT0032H1 AIGT0132B1 AIGT0132H1 AIGT0232B1 AIGT0232H1 5 VDC	AIGT0032B AIGT0032H AIGT0132B AIGT0132H AIGT0232B AIGT0232H 24 VDC	
Communication standard		Conforms to RS232C	Conforms to RS422		
Communication	tanaara	(Non insulation type)	type) (Non insulation type)		
Communication	Baud rate (bit/s)	9600, 19200, 38400, 57600, 115200 bps			
condition with	Data length (bit)	7, 8			
external devices	Parity	None, Odd, Even			
external devices	Stop bit (bit)	1			
Transmission distance (Total length)		Max. 15 m (Baud rate: 19,200 bit/s)	Max. 30 m (Baud rate: 115,200 bit/s)	Max. 500 m (Baud rate: 115,200 bit/s)	
Protocol		- MEWTOCOL (Protocol for PANASONIC PLC: FP series) - General-purpose serial (PANASONIC dedicated protocol) - Other companies' PLC protocols (For the details, refer to the latest GTWIN HELP.)			
Connector		Connector terminal base (8-pin) Note1) 2) 3)			

Note1) The (+) and (-) terminals are the power supply terminals for driving the main unit.

Note2) Regarding power supply voltage, please pay due consideration to the cable length so that the applied voltage is within the operation voltage range.

Note3) When supplying power from a power supply separate from the PLC, make sure the power cable is no longer than 10 m. (5 V DC type only)

Interface for transferring screen data

- TOOL port

- 100L port			
Item		Specifications	
Communication standard		Conforms to RS232C (Non insulation type)	
Conditions for communications with GTWIN	Baud rate (bit/s)	9600, 19200, 115200, 230400 bps Note1) 2)	
	Data length (bit)	8	
	Parity	None, Odd, Even	
	Stop bit (bit)	1	
Protocol		GT dedicated protocol	
Connector		Mini-DIN (5-pin)	

Note1) The baud rate of 230400 bps is available when the USB/RS232C conversion cable is used.

Note2) When the baud rate is set to 230400 bps, the connection using the GTWIN automatic communication setting function is not possible. Set the GTWIN communication setting to 230400 bps, and then transfer data.

6.2 GT02

6.2.1 General Specifications (GT02)

liam	Specifications		
Item	24 V DC type	5 V DC	
Rated voltage	24 V DC	5 V DC	
Operating voltage range	21.6 to 26.4 V DC	4.5 to 5.5 V DC	
Power consumption	1.9 W or less (80 mA or less) 1W or less (200 mA or less) Note1)		
Ambient temperature	0 to +50 °C		
Ambient humidity	20 to 85% RH (at 25 °C), non-condensing		
Storage temperature	-20 to +60 °C		
Storage humidity	10 to 85% RH (at 25 °C), non-condensing		
Breakdown voltage	Between [power supply terminals] and [case] 500 V AC for 1 minute, Cutoff current 10mA (at default setting)		
Insulation resistance	Between [power supply terminals] and [case] 100 M Ω or more, 500 V DC, measured with megohmmeter (at default setting)		
Vibration resistance	5 to 8.4 Hz half amplitude 3.5 mm, 8.4 to 150 Hz acceleration 9.8 m/s ² , 10 sweeps each in X, Y and Z directions (1 octave/min)		
Shock resistance	147 m/s ² , 3 times on 3 axes		
EC Directive applicable	EN61131-2 (EMC Directive)		
Noise immunity	1000 V [P-P] or more, Pulse width 50 ns, 1μs between power supply terminals (based on in-house measurements) Note2)		
Protective construction	IP67 (Initial value, evaluated by us) Dustproof and drip-proof from front panel only (packing used on panel contact surface) Note3)		
Weight	Approx. 170 g		

Note1) When supplying the power from the TOOL port of a PLC (CPU unit), confirm the PLC restrictions such as the power supply capacity before use.

Note2) When using our exclusive cable.

Note3) When reattaching, replace waterproof packing.

6.2.2 Performance Specifications (GT02)

Item		Specifications			
		GT02M	GT02G		
	Display device	STN monochrome LCD			
	Resolution	240 (W) x 96 (H) dots	240 (W) x 96 (H) dots		
	Displayable	88.5 (W) x 35.4 (H) mm			
	area				
Display	Backlight	3-color LED backlight (white, pink,	3-color LED backlight (green,		
Display	Dackiigiit	red)	orange, red)		
	Backlight	Backlight brightness can be adjusted	d on the menu screen or GTWIN		
	brightness	configuration settings.			
	brightricos	(There are some minor variations in	, , , , , , , , , , , , , , , , , , ,		
	Contrast	Contrast can be adjusted on the me	nu screen.		
	Touch switch	Analog touch switch (resistive film type)			
Touch switches	Touch switch	0.8 N or less			
SWILCITES	operation				
Life 1 million times or more (at 25 °C) Note1)		,			
	F-ROM	Screen data (base, keyboard, login), Flow display data, FP monitor			
		screen data: 2048 kbytes Note2)			
		Recipe data: 64 k bytes			
Memory		Write device data: 64 kbytes	(07.511.4.)		
		Alarm history + Line graph sampling (27.5 kbytes)			
	SRAM Note2)	Logging data of Logging function (64 kbytes)			
		Hold GT Device (2048 + 255 words)			
		Hold PLC Device (24 words)			
		Built-in clock data			
	Backup	Alarm history data			
Battery		Line graph sampling data Logging data of Logging function			
Note3)		Internal device hold data			
	Life				
	Life	Hold PLC Device data Approx. 5 years (at 25 °C)			

- Note1) The touch position may shift due to aging variation. If the touch position has shifted greatly, please adjust it.
- Note2) It is available for GT02M2/GT02G2 only. A battery is necessary for SRAM backup.

 The unused part of 27 kbytes for Alarm history and line graph sampling can be used for the logging function.
- Note3) It is available for GT02M2/GT02G2 only. Please purchase a battery separately.

 The battery life is the value when no power at all is supplied. The actual lifetime may be shorter according to the condition of use.

6.2.3 Function Specifications (GT02)

Item	Specifications
Displayable fonts	Fixed (GTWIN): 1/4 width (8 x 8), half width (16 x 8), full width (16 x 16)
	(Double, quadruple or octuple in height and width)
	True Type (GTWIN): 10 to 96 dots
	Windows (R): 10 to 96 dots
Character types	English, Japanese, Korean, German, French, Italian, Spanish, Simplified
	Chinese, Traditional Chinese characters, Turkish, Russian and Vietnamese can
	be displayed.
Number of	250 screens Note1)
registerable screens	
Registerable screen	Base screen: No. 0 to 3FF
number	Keyboard screen: No. 0 to 7
	Login screen: No. 0 to F
Graphics	Straight lines, continuous straight lines, squares, circles, ovals, arcs, elliptic
	arcs, fan shapes, elliptic fan shapes, beveled squares
Types of parts	Switch
	Function switch
	Lamp
	Message
	Data
	Bar graph
	Clock Note2) 3)
	Line graph
	Alarm list
	Keyboard
	Custom(message, lamp, switch)
Main functions Note4)	Recipe
	SD recipe Note5),
	Flow display
	Write device
	Multi language exchange
	Operation security
	GT link
	PLC multiple connection
	Data logging Note5)
	FP monitor
Through function	Connecting a computer to USB port and our PLC to COM port enables the
	communication between the PLC and the computer.
Copy function Note5)	Screen data can be copied with a SD memory card.
GTWIN ver.	Ver. 2.A0 or later
	vable number varies depending on registered contents

Note1) Maximum allowable number varies depending on registered contents.

Note2) External clock data can be referred and displayed.

Note3) Accuracy of the GT internal clock is ±180 seconds per month.

Note4) It depends on the version of GT.

Note5) It is available for GT02M2 and GT02G2 only.

6.2.4 Interface Specifications (GT02)

Interface for connecting PLC/External devices

- COM port

ltem		Specifications	
	tem	RS232C type	RS422/RS485 type
Communication	standard	Conforms to RS232C	Conforms to RS422
		(Non insulation type)	(Non insulation type)
Communication	Baud rate (bit/s)	9600, 19200, 38400, 57600, 115	5200 bps
condition with	Data length (bit)	7, 8	
external	Parity	None, Odd, Even	
devices	Stop bit (bit)	1	
Transmission dis	tance	Max. 15 m	Max. 500 m
(Total length)		(Baud rate: 19200 bit/s)	(Baud rate: 115200 bit/s)
Terminal resistar	nce value	_	120 Ω
Protocol		- MEWTOCOL (Protocol for PANASONIC PLC: FP series)	
		- MEWTOCOL7 (Protocol for PANASONIC PLC FP7 series)	
		- General-purpose serial (PANASONIC dedicated protocol)	
		- Protocol for other companies' PLCs	
		(For the details, refer to the latest GTWIN HELP.)	
Connector		Connector terminal base (8-pin) Note1) 2) 3)	

Note1) It is internally isolated from the input power supply side (between +24V and 0V).

Note3) Regarding power supply voltage, please pay due consideration to the cable length so that the applied voltage is within the operation voltage range.

Interface for transferring screen data

- TOOL port

Item	Specifications
Communication standard	USB1.1
Connector shape Note1)	USB MiniB type 5pin (Male)
Trasmission distance	Max. 5 m
No. of connected unit with PC	1 unit

Note1) Take care of handling of the connector not to add an excessive static electricity on the metal part of the connector.

SD memory card slot (For GT02M2/GT02G2 only)

Item	Specifications	
Support media	SD memory card, SDHC memory card Note1)	
Supported format standard	Conforms to SD standard Note2)	

Note1) The manufacturer name that the operation check has done: Panasonic Corporation

Note3) The SD access lamp turns on while accessing the SD memory card.

Note2) The (+) and (-) terminals are the power supply terminals for driving the main unit.

Note2) Please format with a format software for SD memory cards.

6.3 GT02L

6.3.1 General Specifications (GT02L)

Item Specifications		
Rated voltage	5 V DC	
Operating voltage range 4.5 to 5.5 V DC		
Power consumption	1W or less (200 mA or less) Note1)	
Ambient temperature	0 to +50 °C	
Ambient humidity	20 to 85% RH (at 25 °C), non-condensing	
Storage temperature	-20 to +60 °C	
Storage humidity	10 to 85% RH (at 25 °C), non-condensing	
Drookdown voltage	Between [power supply terminals] and [case]	
Breakdown voltage	500 V AC for 1 minute, Cutoff current 10mA (at default setting)	
	Between [power supply terminals] and [case]	
Insulation resistance	100 $M\Omega$ or more, 500 V DC, measured with megohmmeter (at default	
	setting)	
	5 to 8.4 Hz half amplitude 3.5 mm,	
Vibration resistance	8.4 to 150 Hz acceleration 9.8 m/s ² ,	
	10 sweeps each in X, Y and Z directions (1 octave/min)	
Shock resistance	147 m/s ² , 3 times on 3 axes	
EC Directive applicable EN61131-2 (EMC Directive)		
Noise immunity	1000 V [P-P] or more, Pulse width 50 ns, 1μs between power supply	
Noise immunity	terminals (based on in-house measurements) Note2)	
	IP65 (Initial value, evaluated by us)	
Protective construction	Dustproof and drip-proof from front panel only (packing used on panel	
	contact surface) Note3)	
Weight	Approx. 150 g	

Note1) When supplying the power from the TOOL port of a PLC (CPU unit), confirm the PLC restrictions such as the power supply capacity before use.

Note2) When using our exclusive cable.

Note3) When reattaching, replace waterproof packing.

6.3.2 Performance Specifications (GT02L)

Item		Specifications	
	Display device	STN monochrome LCD	
	Resolution	160 (W) x 64 (H) dots	
	Displayable	88.0 (W) x 35.2 (H) mm	
	area		
Display	Backlight	LED backlight (white)	
	Backlight	Backlight brightness can be adjusted on the menu screen or GTWIN configuration settings.	
	brightness	(There are some minor variations in the backlight brightness.)	
	Contrast	Contrast can be adjusted on the menu screen.	
	Touch switch	Analog touch switch (resistive film type)	
Touch switches	Touch switch operation	0.8 N or less	
	Life	1 million times or more (at 25 °C) Note1)	
	F-ROM	Screen data (base, keyboard, login), Flow display data, FP monitor	
Memory		screen data: 640 kbytes	
		Recipe data: 64 k bytes	
		Write device data: 64 kbytes	

Note1) The touch position may shift due to aging variation. If the touch position has shifted greatly, please adjust it.

6.3.3 Function Specifications (GT02L)

Item	Specifications
Displayable fonts	Fixed (GTWIN): 1/4 width (8 x 8), half width (16 x 8), full width (16 x 16)
	(Double, quadruple or octuple in height and width)
	True Type (GTWIN): 10 to 64 dots
	Windows (R): 10 to 64 dots
Character types	English, Japanese, Korean, German, French, Italian, Spanish, Simplified
	Chinese, Traditional Chinese characters, Turkish, Russian and Vietnamese can
	be displayed.
Number of	80 screens Note1)
registerable screens	
Registerable screen	Base screen: No. 0 to 3FF
number	Keyboard screen: No. 0 to 7
	Login screen: No. 0 to F
Graphics	Straight lines, continuous straight lines, squares, circles, ovals, arcs, elliptic
	arcs, fan shapes, elliptic fan shapes, beveled squares
Types of parts	Switch
	Function switch
	Lamp
	Message
	Data
	Bar graph
	Clock Note2)
	Line graph
	Alarm list
	Keyboard
	Custom(message, lamp, switch)
Main functions Note3)	Recipe
	Flow display
	Write device
	Multi language exchange
	Operation security
	GT link
	PLC multiple connection
	FP monitor
Through function	Connecting a computer to USB port and our PLC to COM port enables the
	communication between the PLC and the computer.
GTWIN ver.	Ver. 2.B0 or later

Note1) Maximum allowable number varies depending on registered contents.

Note2) External clock data can be referred and displayed.

Note3) It depends on the version of GT.

6.3.4 Interface Specifications (GT02L)

Interface for connecting PLC/External devices

- COM port

ltem		Specifications	
	tem	RS232C type	RS422/RS485 type
Communication	standard	Conforms to RS232C	Conforms to RS422
		(Non insulation type)	(Non insulation type)
Communication	Baud rate (bit/s)	9600, 19200, 38400, 57600, 115	5200 bps
condition with	Data length (bit)	7, 8	
external	Parity	None, Odd, Even	
devices	Stop bit (bit)	1	
Transmission dis	tance	Max. 15 m	Max. 500 m
(Total length)		(Baud rate: 19200 bit/s)	(Baud rate: 115200 bit/s)
Terminal resistar	nce value	_	120 Ω
Protocol		- MEWTOCOL (Protocol for PANASONIC PLC: FP series)	
		- MEWTOCOL7 (Protocol for PANASONIC PLC: FP7 series)	
		- General-purpose serial (PANASONIC dedicated protocol)	
		- Protocol for other companies' PLCs	
		(For the details, refer to the latest GTWIN HELP.)	
Connector		Connector terminal base (8-pin) Note1) 2) 3)	

- Note1) The (+) and (-) terminals are the power supply terminals for driving the main unit.
- Note2) Regarding power supply voltage, please pay due consideration to the cable length so that the applied voltage is within the operation voltage range.
- Note3) When tightening the terminal block requires a flat-blade screwdriver with a blade size of 0.4 x 2.5 or special screwdriver (part No.: AFP0806). Set the tightening torque between 0.22 Nm to 0.25 Nm.

Applicable wire	Size	Nominal cross-sectional area
Applicable wire	AWG#28 to 16	0.08 to 1.25mm ²

Interface for transferring screen data

- USB port

Item	Specifications
Communication standard	USB1.1
Connector shape Note1)	USB MiniB type 5pin (Male)
Trasmission distance	Max. 5 m
No. of connected unit with PC	1 unit

Note1) Take care of handling of the connector not to add an excessive static electricity on the metal part of the connector.

6.4 GT03-E

6.4.1 General Specifications (GT03-E)

11	Specifications		
Item	GT03M-E	GT03T-E	
Rated voltage	24 V DC		
Operating voltage range	21.6 to 26.4 V DC		
Power consumption	1.9 W or less (80 mA or less)	3.1 W or less (130 mA or less)	
Ambient temperature	-20 to +60 °C Note1)		
Ambient humidity	20 to 85% RH (at 25 °C), non-conder	nsing	
Storage temperature	-20 to +60 °C		
Storage humidity	10 to 95% RH (at 25 °C), non-conder	nsing	
Breakdown voltage	Between [power supply terminals] an 500 V AC for 1 minute, Cutoff current		
Insulation resistance (Operating voltage: 500 V DC)	Between [power supply terminals] and [case] 100 M Ω or more (at default setting)		
Vibration resistance	resistance Conforms to JISB3502 and IEC61131-2. 5 to 8.4 Hz half amplitude 3.5 mm 8.4 to 150 Hz, Acceleration 9.8 m/s² 10 sweeps each in X, Y and Z directions (1 octave/min)		
Conforms to JISB3502 and IEC61131-2. Shock resistance 147 m/s ² 3 times on 3 axes		1-2.	
EU Directive applicable EN61131-2 (EMC Directive)			
Noise immunity 1000 V [P-P] or more, Pulse width 50 ns, 1µs between power supply terminals (based on in-house measurements) Note2)			
Electrostatic discharge	arge 6 kV		
resistance	(Contact discharge, IEC61000-4-2 Level 3)		
Protective construction	IP67 (Initial value, evaluated by us) Dustproof and drip-proof from front panel only (packing used on panel contact surface) Note3)		
Weight	Approx. 170 g		

Note1) When it is installed in horizontal orientation (installed to make the liquid crystal face be topside), installed upright in vertical orientation or when using a battery, the usable range is -20 to +55 °C. Note2) When using our exclusive cable.

Note3) When reattaching, replace waterproof packing.

6.4.2 Performance Specifications (GT03-E)

ltem -		Specifications		
		GT03M-E	GT03T-E	
	Display device	TFT monochrome LCD	TFT color LCD	
	Resolution	320 (W) x 240 (H) dots		
Diaplay	Displayable area	70.6 (W) x 52.9 (H) mm		
Display Note1)	Backlight	1-color LED backlight (white)		
	Backlight brightness	Can be adjusted on the menu screen, GTWIN configuration settings or PLC. (There are some minor variations in the backlight brightness.)		
	Touch switch	Analog touch switch (resistive film t		
Touch switches	Touch switch operation	0.8 N or less		
	Life	1 million times or more (at 25 °C) No	ote2)	
	F-ROM	Screen data (base, keyboard, login), Flow display data, FP monitor screen data: 6144 kbytes	Screen data (base, keyboard, login), Flow display data, FP monitor screen data: 12288 kbytes	
		Recipe data: 64 k bytes		
Memory	SRAM Note3)	Write device data: 64 kbytes	Alarm history + Line graph sampling (27.5 kbytes) Logging data of Logging function (64 kbytes) Hold GT Device (2048 + 255 words) Hold PLC Device (24 words)	
Battery Note4) 5)	Backup	-	Built-in clock data Alarm history data Line graph sampling data Logging data of Logging function Internal device hold data Hold PLC Device data	
	Life	-	Approx. 3 years (at 25 °C)	

Note1) On the LCD panel, bright spots (points always lit) or black spots (points always unlit) may appear, or the uneven brightness, flickers or crosstalk (appearance of unintended shades in the area no graphic or part is arranged) may occur depending on the operating conditions. Note that these phenomena are resulted from the basic characteristics of LCD panel not defects or failures of the product.

Note2) The touch position may shift due to aging variation. If the touch position has shifted greatly, please adjust it.

- Note3) A battery is necessary for SRAM backup.
- Note4) Please purchase a battery separately.

The battery life is the value when no power at all is supplied. The actual lifetime may be shorter according to the condition of use.

Note5) The usable range for using a battery is -20 to +55 °C.

6.4.3 Function Specifications (GT03-E)

	Specifi	ications
Item	GT03M-E	GT03T-E
Displayable fonts	Fixed (GTWIN): 1/4 width (8 x 8), half w (Double, quadruple or of True Type (GTWIN): 10 to 240 dots Windows (R): 10 to 240 dots	idth (16 x 8), full width (16 x 16) octuple in height and width)
Character types	English, Japanese, Korean, German, Fr Chinese, Traditional Chinese characters be displayed.	rench, Italian, Spanish, Simplified s, Turkish, Russian and Vietnamese can
Number of registerable screens	Approx. 230 screens	Approx. 180 screens
Registerable screen number	Base screen: No. 0 to 3FF Keyboard screen: No. 0 to 7 Login screen: No. 0 to F	<u> </u>
Graphics	Straight lines, continuous straight lines, arcs, fan shapes, elliptic fan shapes, be	
Types of parts	Switch Function switch Lamp Message Data Bar graph Clock Note2) Note3) Line graph Alarm list Keyboard Custom(message, lamp, switch)	Switch Function switch Lamp Message Data Bar graph Clock Note2) Note3) Line graph Alarm list Alarm history Note5) Keyboard Custom(message, lamp, switch)
Main functions Note4)	Recipe Flow display Write device Multi language exchange Operation security GT link PLC multiple connection	Recipe SD recipe Note5) Flow display Write device Multi language exchange Operation security GT link PLC multiple connection Logging function Note5)
Through function	Connecting a computer to USB port and our PLC to COM port enables the communication between the PLC and the computer.	
Copy function	-	Screen data can be copied with a SD memory card.
GTWIN ver.	Ver. 2.E1 or later	

Note1) Maximum allowable number varies depending on registered contents.

Note4) It depends on the version of GT.

Note2) External clock data can be referred and displayed.

Note3) Accuracy of the GT internal clock is ± 90 seconds per month (at 25°C). Periodically set the clock to the right time for the system in which clock error is a problem. (GT03T-E only)

6.4.4 Interface Specifications (GT03-E)

Interface for connecting PLC/External devices

- COM port

		Specifi	cations
Ite	em	AIG03MQ03DE	AIG03MQ05DE
		AIG03TQ13DE	AIG03TQ15DE
Communication	standard	Conforms to RS232C (Non	Conforms to RS422 (Non
		insulation type)	insulation type)
Communication	Baud rate (bit/s)	9600, 19200, 38400, 57600, 11520	00 bps
condition with	Data length (bit)	7, 8	
external	Parity	None, Odd, Even	
devices	Stop bit (bit)	1	
Transmission di	stance	Max. 15 m	Max. 500 m
(Total length)		(Baud rate: 19200 bit/s)	(Baud rate: 115200 bit/s)
Protocol		- MEWTOCOL (Protocol for our PLC: FP series)	
		- MEWTOCOL7 (Protocol for our PLC: FP7 series)	
		- General-purpose serial (PANASONIC dedicated protocol)	
		- Other companies' PLC protocols (For the details, refer to the latest	
		GTWIN HELP.)	
Connector		Connector terminal base (8-pin) Note1) 2) 3)	

- Note1) The (+) and (-) terminals are the power supply terminals for driving the main unit.
- Note2) Regarding power supply voltage, please pay due consideration to the cable length so that the applied voltage is within the operation voltage range.

Note3) When tightening the terminal block requires a flat-blade screwdriver with a blade size of 0.4 x 2.5 or special screwdriver (part No.: AFP0806). The tightening torque should be 0.22 to 0.3 N⋅m.

Applicable wire	Size	Nominal cross-sectional area	Rated temperature
Applicable wire	AWG#28 to 16	0.08 to 1.25mm2	60 °C

Interface for transferring screen data

- USB port

Item	Specifications
	USB1.1
Connector shape Note1)	TYPE-B
Trasmission distance	USB MiniB type 5pin (Male)
No. of connected unit with PC	1 unit

Note1) Take care of handling of the connector not to add an excessive static electricity on the metal part of the connector.

SD memory card slot

Item	Specifications
Support media	SD memory card, SDHC memory card Note1)
Supported format standard	Conforms to SD standard Note2)

Note1) The manufacturer name that the operation check has done: Panasonic Corporation Check the usable temperature range of a SD memory card to be used before use.

Note2) Please format with a format software for SD memory cards.

6.5 GT05

6.5.1 General Specifications

Itama	Specifications		
Item	GT05S	GT05M/GT05G	
Rated voltage	24 V DC		
Operating voltage range	21.6 to 26.4 V DC		
Power consumption	3.6 W or less (150 mA or less)	2.4 W or less (100 mA or less)	
Insulation method of power supply part	Transformer insulation		
Ambient temperature	0 to +50 °C		
Ambient humidity	20 to 85% RH (at 25 °C), non-conden	nsing	
Storage temperature	-20 to +60 °C		
Storage humidity	10 to 85% RH (at 25 °C), non-condensing		
Breakdown voltage Note1)	Between [power supply terminals] and [case] 500 V AC for 1 minute, Cutoff current 10mA (at default setting)		
Insulation resistance	Between [power supply terminals] and [case] 100 M Ω or more, 500 V DC, measured with megohmmeter (at default setting)		
Vibration resistance	10 to 55 Hz (1-minute cycle) Amplitude: 0.75 mm, 10 min on 3 axes		
Shock resistance	98 m/s ² or more, 4 times on 3 axes		
EC Directive applicable	EN61131-2 (EMC Directive)		
Noise immunity	1000 V [P-P] or more, Pulse width 50 ns, 1µs between power supply terminals (based on in-house measurements) Note2)		
Protective construction	IP65 (Initial value, evaluated by us) Dustproof and drip-proof from front panel only (packing used on panel contact surface) Note3)		
Weight			

Note1) Not isolated between the USB port, COM. port and the internal digital circuit.

Note2) When using our exclusive cable.

Note3) When reattaching, replace waterproof packing.

6.5.2 Performance Specifications (GT05)

Item		Specifications		
		GT05S	GT05M	GT05G
Display device		4096-color TFT color LCD TFT monochrome LCD		
	Resolution	320 (W) x 240 (H) dots		
	Displayable area	70.3 (W) x 52.7 (H) mm 70.6 (W) x 52.9 (H) mm		
	Backlight		3-color LED	3-color LED
Display		1-color LED backlight (white)	backlight	backlight (green,
			(white, pink, red)	orange, red)
	Backlight brightness	Backlight brightness can be adjusted on the menu screen or GTWIN configuration settings. (There are some minor variations in the backlight brightness.)		
	Touch switch	Analog touch switch (resistive fi		<u>g</u>
Touch switches	Touch switch operation	0.8 N or less	. ,	
	Life	1 million times or more (at 25 °C) Note1)		
	F-ROM	Screen data (base, keyboard, login), Flow display data, FP monitor screen data: 12288 kbytes	Screen data (base Flow display data, data: 2048 kbytes	
Memory		Recipe data: 64 k bytes Write device data: 64 kbytes		
SRAM Note2)		Alarm history + Line graph sampling (27.5 kbytes) Logging data of Logging function (64 kbytes) Hold GT Device (2048 + 255 words) Hold PLC Device (24 words)		
Battery Note3)	Backup	Built-in clock data Alarm history data Line graph sampling data Logging data of Logging functio Internal device hold data Hold PLC Device data	n	
	Life	Approx. 3 years (at 25 °C)	Approx. 5 years	(at 25 °C)

Note1) The touch position may shift due to aging variation. If the touch position has shifted greatly, please adjust it.

Note2) A battery is necessary for SRAM backup.

The unused part of 27 kbytes for Alarm history and line graph sampling can be used for the logging function.

Note3) Please purchase a battery separately.

The battery life is the value when no power at all is supplied. The actual lifetime may be shorter according to the condition of use.

6.5.3 Function Specifications (GT05)

	Specifi	ications	
Item	GT05S	GT05M/GT05G	
Displayable fonts	Fixed (GTWIN): 1/4 width (8 x 8), half width (16 x 8), full width (16 x 16)		
		octuple in height and width)	
	True Type (GTWIN): 10 to 240 dots		
	Windows (R): 10 to 240 dots		
Character types	English, Japanese, Korean, German, Fr	ench, Italian, Spanish, Simplified	
	Chinese, Traditional Chinese characters	s, Turkish, Russian and Vietnamese can	
	be displayed.		
Number of	Approx. 180 screens Note1)	Approx. 240 screens Note1)	
registerable screens			
Registerable screen	Base screen: No. 0 to 3FF		
number	Keyboard screen: No. 0 to 7		
	Login screen: No. 0 to F		
Graphics	Straight lines, continuous straight lines,	squares, circles, ovals, arcs, elliptic	
	arcs, fan shapes, elliptic fan shapes, be	veled squares	
Types of parts	Switch		
	Function switch		
	Lamp		
	Message		
	Data		
	Bar graph		
	Clock Note2) 3)		
	Line graph		
	Alarm list		
	Keyboard		
	Custom(message, lamp, switch)		
Main functions Note4)	Recipe		
	SD recipe		
	Flow display		
	Write device		
	Multi language exchange		
	Operation security		
	GT link		
	PLC multiple connection		
	Data logging		
	FP monitor		
Through function	Connecting a computer to USB port and	· · · · · · · · · · · · · · · · · · ·	
	communication between the PLC and the	•	
Copy function	Screen data can be copied with a SD m	emory card.	
GTWIN ver.	Ver. 2.90 or later		
NI (4) NA : II	vable number varies depending on registe		

Note1) Maximum allowable number varies depending on registered contents.

Note2) External clock data can be referred and displayed.

Note3) Accuracy of the GT internal clock is ±180 seconds per month.

Note4) It depends on the version of GT.

6.5.4 Interface Specifications (GT05)

Interface for connecting PLC/External devices

- COM port

_		Specific	cations	
lt	em	AIG05MQ02D/AIG05MQ03D AIG05GQ02D/AIG05GQ03D AIG05SQ02D/AIG05SQ03D	AIG05MQ04D/AIG05MQ05D AIG05GQ04D/AIG05GQ05D AIG05SQ04D/AIG05SQ05D	
Communication	standard	Conforms to RS232C (Non insulation type) Note1)	Conforms to RS422 (Non insulation type) Note1)	
Communication	Baud rate (bit/s)	9600, 19200, 38400, 57600, 11520	0 bps	
condition with	Data length (bit)	7, 8		
external	Parity	None, Odd, Even		
devices	Stop bit (bit)	1		
Transmission di	stance	Max. 15 m	Max. 500 m	
(Total length)		(Baud rate: 19200 bit/s)	(Baud rate: 115200 bit/s)	
Protocol		- MEWTOCOL (Protocol for PANASONIC PLC: FP series)		
		- MEWTOCOL7 (Protocol for PANASONIC PLC: FP7 series)		
		- General-purpose serial (PANASONIC dedicated protocol)		
		- Other companies' PLC protocols (For the details, refer to the latest		
		GTWIN HELP.)		
Connector		Connector terminal base (8-pin) Note2) 3)		

- Note1) It is internally isolated from the input power supply side (between +24V and 0V).
- Note2) The (+) and (-) terminals are the power supply terminals for driving the main unit.
- Note3) Regarding power supply voltage, please pay due consideration to the cable length so that the applied voltage is within the operation voltage range.

Interface for transferring screen data

- USB port

Item	Specifications
Communication standard	USB1.1
Connector shape Note1)	TYPE-B
Trasmission distance	Max. 5 m
No. of connected unit with PC	1 unit

Note1) Take care of handling of the connector not to add an excessive static electricity on the metal part of the connector.

SD memory card slot

Item	Specifications
Support media	SD memory card, SDHC memory card Note1)
Supported format standard	Conforms to SD standard Note2)

Note1) The manufacturer name that the operation check has done: Panasonic Corporation Usable capacity of a SD memory card varies according to the version of GT firmware.

Note2) Please format with a format software for SD memory cards.

Note3) The SD access lamp turns on while accessing the SD memory card.

6.6 GT11

6.6.1 General Specifications (GT11)

Item	Specifications	
Rated voltage	24 V DC	
Operating voltage range	21.6 to 26.4 V DC	
Power consumption	2.4 W or less (100 mA or less) Note1)	
Ambient temperature	0 to +50 °C Note2)	
Ambient humidity	20 to 85% RH (at 25 °C), non-condensing	
Storage temperature	-20 to +60 °C	
Storage humidity	10 to 85% RH (at 25 °C), non-condensing	
Prookdown voltage	Between [power supply terminals] and [case]	
Breakdown voltage	500 V AC for 1 minute, Cutoff current 10mA (at default setting)	
	Between [power supply terminals] and [case]	
Insulation resistance	100 M Ω or more, 500 V DC, measured with megohmmeter (at default	
	setting)	
	10 to 55 Hz (1-minute cycle)	
Vibration resistance	Amplitude: 0.75 mm,	
	10 min on 3 axes	
Shock resistance	98 m/s ² or more,	
Chock resistance	4 times on 3 axes	
EC Directive applicable	EMC Directive: EN61000-6-2, EN61000-6-4	
Noise immunity	1000 V [P-P] or more, Pulse width 50 ns, 1µs between power supply	
Noise immunity	terminals (based on in-house measurements) Note3)	
Protective construction	IP65 (Initial value, evaluated by us)	
	Dustproof and drip-proof from front panel only (packing used on panel	
	contact surface) Note4)	
Weight	Approx. 230 g	

Note1) When connecting the FP programmer II to the TOOL port, it is 150 mA or less.

Note2) When connecting the FP programmer II or C-NET adapter to the TOOL port, the usable range is 0 to +45 $^{\circ}$ C.

Note3) When using our exclusive cable.

Note4) When reattaching, replace waterproof packing.

6.6.2 Performance Specifications (GT11)

Item		Specifications	
		AIGT2030B/AIGT2030H	AIGT2130B/AIGT2130H
		AIGT2032B/AIGT2032H	AIGT2132B/AIGT2132H
	Display device	STN monochrome LCD	
	Resolution	240 (W) x 96 (H) dots	
	Displayable area	96.0 (W) x 35.4 (H) mm	
Display	Backlight	3-color LED backlight (green, orange, red)	1-color LED backlight (white)
	Backlight	Can be set on the menu screen or	GTWIN configuration settings.
	brightness	(There are some minor variations in	the backlight brightness.)
	Contrast	Can be adjusted on the menu scree	en or GTWIN configuration settings.
	Touch switch	Analog touch switch (resistive film type)	
Touch	Touch switch	0.5 N or less	
switches	operation		
	Life	1 million times or more (at 25 °C) Note1)	
	F-ROM	Screen data (base, keyboard), Flow Write device data: 64 kbytes	v display data: 1408 kbytes
Memory		Alarm history + Line graph sampling (27.5 kbytes)	
	SRAM Note2)	Hold GT Device (2048 + 255 words)	
		Hold PLC Device (24 words)	
		Built-in clock data	
		Alarm history data	
Batterv	Backup	Line graph sampling data	
Note3)		Internal device hold data	
		Hold PLC Device data	
	Life	Approx. 2 years (at 25 °C)	

Note1) The touch position may shift due to aging variation. If the touch position has shifted greatly, please adjust it.

The battery life is the value when no power at all is supplied. The actual lifetime may be shorter according to the condition of use.

Note2) A battery is necessary for SRAM backup.

Note3) Please purchase a battery separately.

6.6.3 Function Specifications (GT11)

Item	Specifications
Displayable fonts	Fixed (GTWIN): 1/4 width (8 x 8), half width (16 x 8), full width (16 x 16)
	(Double or quadruple in height and width)
	True Type (GTWIN): 10 to 96 dots
	Windows (R): 10 to 96 dots
Character types	English, Japanese, Korean, German, French, Italian, Spanish, Simplified
	Chinese, Traditional Chinese characters, Turkish, Russian and Vietnamese can
	be displayed.
Number of	250 screens Note1)
registerable screens	
Registerable screen	Base screen: No. 0 to 3FF
number	Keyboard screen: No. 0 to 7
Graphics	Straight lines, continuous straight lines, squares, circles, ovals, arcs, elliptic
	arcs, fan shapes, elliptic fan shapes, beveled squares
Types of parts	Switch
	Function switch
	Lamp
	Message
	Data
	Bar graph
	Clock Note2) 3)
	Line graph
	Alarm list
	Alarm history
	Keyboard
	Custom(message, lamp, switch)
Main functions Note4)	Recipe
	Flow display
	Write device
	Multi language exchange
Through function	Connecting a computer to TOOL port and our PLC to COM port enables the
	communication between the PLC and the computer.
Copy function *5	The screen data can be copied by connecting the main units with a cable.
GTWIN ver.	Ver. 2.60 or later

Note1) Maximum allowable number varies depending on registered contents.

Note2) A clock part can be indicated by referring to external clock data.

Note3) Accuracy of the GT internal clock is ±100 seconds per month.

Note4) It depends on the version of GT.

6.6.4 Interface Specifications (GT11)

Interface for connecting PLC/External devices

- COM port

_		Specifi	cations
Ito	em	AIGT2030B/AIGT2030H AIGT2130B/AIGT2130H	AIGT2032B/AIGT2032H AIGT2132B/AIGT2132H
Communication	standard	Conforms to RS232C	Conforms to RS422
		(Non insulation type)	(Non insulation type)
Communication	Baud rate (bit/s)	9600, 19200, 38400, 57600, 11520	0 bps
condition with	Data length (bit)	7, 8	
external	Parity	None, Odd, Even	
devices	Stop bit (bit)	1	
Transmission di	stance	Max. 15 m	Max. 500 m
(Total length)		(Baud rate: 19200 bit/s)	(Baud rate: 115200 bit/s)
Protocol		- MEWTOCOL (Protocol for PANAS	SONIC PLC: FP series)
		- General-purpose serial (PANASC	NIC dedicated protocol)
		 Other companies' PLC protocols (GTWIN HELP.) 	(For the details, refer to the latest
Connector		Connector terminal base (8-pin) Note	e1) 2)

Note1) The (+) and (-) terminals are the power supply terminals for driving the main unit.

Note2) Regarding power supply voltage, please pay due consideration to the cable length so that the applied voltage is within the operation voltage range.

Interface for transferring screen data

- TOOL port

Item		Specifications
Communication standard		Conforms to RS232C (Non insulation type)
Can ditiona for	Baud rate (bit/s)	9600, 19200, 115200, 230400 bps Note1) 2)
Conditions for communications	Data length (bit)	8
with GTWIN	Parity	None, Odd, Even
WILLIGITATION	Stop bit (bit)	1
Protocol		GT dedicated protocol
Connector		Mini-DIN (5-pin)

Note1) The baud rate of 230400 bps is available when the USB/RS232C conversion cable is used.

Note2) When the baud rate is set to 230400 bps, the connection using the GTWIN automatic communication setting function is not possible. Set the GTWIN communication setting to 230400 bps, and then transfer data.

6.7 GT12

6.7.1 General Specifications (GT12)

Item	Specifications
Rated voltage	24 V DC
Operating voltage range	21.6 to 26.4 V DC
Power consumption	1.7 W or less (70 mA or less)
Insulation method of power supply part	Transformer insulation Note1)
Ambient temperature	0 to +50 °C
Ambient humidity	20 to 85% RH (at 25 °C), non-condensing
Storage temperature	-20 to +60 °C
Storage humidity	10 to 85% RH (at 25 °C), non-condensing
Breakdown voltage Note1)	Between [power supply terminals (+ and – terminals)] and [function earth terminal] 500 V AC for 1 minute, Cutoff current 10mA (in initial status)
Insulation resistance Note1)	Between [power supply terminals (+ and – terminals)] and [function earth terminal] 100 M Ω or more, 500 V DC, measured with megohmmeter (in initial status)
Vibration resistance	5 to 9 Hz amplitude 3.5 mm, 9 to 150 Hz acceleration 9.8 m/s ² , 10 sweeps each in X, Y and Z directions (1 octave/min)
Shock resistance	147 m/s ² , 3 times on 3 axes
EC Directive applicable	EMC Directive: EN61131-2
Noise immunity	1000 V [P-P] or more, Pulse width 50 ns, 1µs between power supply terminals (based on in-house measurements) Note2)
Protective construction	IP67 (Initial value, evaluated by us) Dustproof and waterproof from front panel only (packing used on panel contact surface) Note3)
Weight	Approx. 240 g

Note1) Not isolated between the USB port, COM. port and the internal digital circuit.

Note2) When using our exclusive cable.

Note3) When installing the unit again, replace the water-proof packing.

6.7.2 Performance Specifications (GT12)

Item		Specifications		
		GT12M	GT12G	
	Display device	STN monochrome LCD		
	Resolution	320 (W) x 120 (H) dots		
	Displayable	108.78 (W) x 40.78 (H) mm		
	area			
	Gradation	2 gradation/8 gradation (Selectable wi	ith GTWIN.)	
Display	Backlight	3-color LED backlight	3-color LED backlight	
	Backlight	(white, pink, red)	(green, orange, red)	
	Backlight	Backlight brightness can be adjusted	on the menu screen or GTWIN	
	brightness	configuration settings.		
		(There are some minor variations in the	ne backlight brightness.)	
	Contrast	Contrast can be adjusted on the menu	Contrast can be adjusted on the menu screen.	
	Touch switch	Analog touch switch (resistive film type)		
Touch	Touch switch	0.8 N or less		
switches	operation			
	Life	1 million times or more (at 25 °C) Note1)		
	F-ROM	Screen data (base, keyboard, login), F	Flow display data, FP monitor	
		screen data: 2048 kbytes		
		Recipe data: 64 k bytes		
Memory		Write device data: 64 kbytes	27.511.4	
	SRAM Note2)	Alarm history + Line graph sampling (
		Logging data of Logging function (64 kbytes)		
		Hold GT Device (2048 + 255 words)		
		Hold PLC Device (24 words)		
		Built-in clock data		
		Alarm history data		
Dotton	Backup	Line graph sampling data		
Battery Note3)	·	Logging data of Logging function Internal device hold data		
		Hold PLC Device data		
	Life			
	LIIE	Approx. 5 years (at 25 °C)		

Note1) The touch position may shift due to aging variation. If the touch position has shifted greatly, please adjust it.

Note2) A battery is necessary for SRAM backup.

The unused part of 27 kbytes for Alarm history and line graph sampling can be used for the logging function.

Note3) Please purchase a battery separately.

The battery life is the value when no power at all is supplied. The actual lifetime may be shorter according to the condition of use.

6.7.3 Function Specifications (GT12)

Item	Specifications
Displayable fonts	Fixed (GTWIN): 1/4 width (8 x 8), half width (16 x 8), full width (16 x 16)
	(Double, quadruple or octuple in height and width)
	True Type (GTWIN): 10 to 120 dots
	Windows (R): 10 to 120 dots
Character types	English, Japanese, Korean, German, French, Italian, Spanish, Simplified
·	Chinese, Traditional Chinese characters, Turkish, Russian and Vietnamese can
	be displayed.
Number of	2 gradation:250 screens 8 gradation:200screens Note1)
registerable screens	
Registerable screen	Base screen: No. 0 to 3FF
number	Keyboard screen: No. 0 to 7
	Login screen: No. 0 to F
Graphics	Straight lines, continuous straight lines, squares, circles, ovals, arcs, elliptic
	arcs, fan shapes, elliptic fan shapes, beveled squares
Types of parts	Switch
	Function switch
	Lamp
	Message
	Data
	Bar graph
	Clock Note2) 3)
	Line graph
	Alarm list
	Keyboard
N O	Custom(message, lamp, switch)
Main functions Note4)	Recipe
	SD recipe Note5)
	Flow display
	Write device
	Multi language exchange
	Operation security
	GT link
	PLC multiple connection
	Data logging Note5)
	FP monitor
Through function	Connecting a computer to USB port and our PLC to COM port enables the
- Notos	communication between the PLC and the computer.
Copy function Note5)	Screen data can be copied with a SD memory card.
GTWIN ver.	Ver. 2.97 or later

Note1) Maximum allowable number varies depending on registered contents.

Note2) External clock data can be referred and displayed.

Note3) Accuracy of the GT internal clock is ±180 seconds per month.

Note4) It depends on the version of GT.

Note5) It is available for GT12M1 and GT12G1 only.

6.7.4 Interface Specifications (GT12)

Interface for connecting PLC/External devices

- COM port

		Specifications		
		AIG12*Q02D	AIG12*Q04D	
14		AIG12*Q03D	AIG12*Q05D	
It	em	AIG12*Q12D	AIG12*Q14D	
		AIG12*Q13D	AIG12*Q15D	
		RS232C type	RS422/RS485 type	
Communication	standard	Conforms to RS232C	Conforms to RS422	
		(Non insulation type) Note1)	(Non insulation type) Note1)	
Communication	Baud rate (bit/s)	9600, 19200, 38400, 57600, 11520	0 bps	
condition with	Data length (bit)	7, 8		
external	Parity	None, Odd, Even		
devices	Stop bit (bit)	1		
Transmission di	stance	Max. 15 m	Max. 500 m	
(Total length)		(Baud rate: 19200 bit/s)	(Baud rate: 115200 bit/s)	
Protocol		- MEWTOCOL (Protocol for PANAS	SONIC PLC: FP series)	
		- MEWTOCOL7 (Protocol for PANA	ASONIC PLC: FP7 series)	
		- General-purpose serial (PANASO	NIC dedicated protocol)	
		- Other companies' PLC protocols ((For the details, refer to the latest	
		GTWIN HELP.)		
Connector		Connector terminal base (8-pin) Note	e2) 3)	

Note1) It is internally isolated from the input power supply side (between +24V and 0V).

Note2) The (+) and (-) terminals are the power supply terminals for driving the main unit.

Note3) Regarding power supply voltage, please pay due consideration to the cable length so that the applied voltage is within the operation voltage range.

Interface for transferring screen data

- USB port

Item	Specifications
Communication standard	USB1.1
Connector shape Note1)	USB MiniB type 5pin (Male)
Trasmission distance	Max. 5 m
No. of connected unit with PC	1 unit

Note1) Take care of handling of the connector not to add an excessive static electricity on the metal part of the connector.

SD memory card slot (For GT12M1/GT12G1 only)

Item	Specifications
Support media	SD memory card , SDHC memory card Note1)
Supported format standard	Conforms to SD standard Note2)

Note1) The manufacturer name that the operation check has done: Panasonic Corporation Usable capacity of a SD memory card varies according to the version of GT firmware.

Note2) Please format with a format software for SD memory cards.

Note3) The SD access lamp turns on while accessing the SD memory card.

6.8 GT21

6.8.1 General Specifications (GT21)

Item	Specifications
Rated voltage	24 V DC
Operating voltage range	21.6 to 26.4 V DC
Power consumption	4.8 W or less (200 mA or less)
Ambient temperature	0 to +50 °C Note1)
Ambient humidity	20 to 85% RH (at 25 °C), non-condensing
Storage temperature	-20 to +60 °C
Storage humidity	10 to 85% RH (at 25 °C), non-condensing
Breakdown voltage	Between [power supply terminals] and [case] 500 V AC for 1 minute, Cutoff current 10mA (at default setting)
Insulation resistance	Between [power supply terminals] and [case] 100 M Ω or more, 500 V DC, measured with megohmmeter (at default setting)
Vibration resistance	10 to 55 Hz (1-minute cycle) Amplitude: 0.75 mm, 10 min on 3 axes
Shock resistance	98 m/s ² or more, 4 times on 3 axes
EC Directive applicable	EMC Directive: EN61000-6-2, EN61000-6-4
Noise immunity	1000 V [P-P] or more, Pulse width 50 ns, 1μs between power supply terminals (based on in-house measurements) Note2)
Protective construction	IP65 (Initial value, evaluated by us) Dustproof and drip-proof from front panel only (packing used on panel contact surface) Note3)
Weight	Approx. 230 g

Note1) When it is installed in a horizontal orientation (installed to make the liquid crystal face be topside) or when the FP programmer II or C-NET adapter is connected to the TOOL port, the usable range is 0 to +45 °C.

Note2) When using our exclusive cable.

Note3) When reattaching, replace waterproof packing.

6.8.2 Performance Specifications (GT21)

	Item	Specifications	
	Display device	256-color STN color LCD	
	Resolution	320 (W) x 240 (H) dots	
	Displayable area	98.0 (W) x 74.0 (H) mm	
Display	Backlight	1-color LED backlight (white)	
Display	Backlight brightness	Can be set on the menu screen or GTWIN configuration settings. (There are some minor variations in the backlight brightness.)	
	Contrast	Can be adjusted on the menu screen or GTWIN configuration settings.	
	Touch switch	Analog touch switch (resistive film type)	
Touch switches	Touch switch operation	0.8 N or less	
	Life	1 million times or more (at 25 °C) Note1)	
	F-ROM	Screen data (base, keyboard), Flow display data: 6656 kbytes Write device data: 64 kbytes	
Memory	SRAM Note2)	Alarm history + Line graph sampling (27.5 kbytes) Hold GT Device (2048 + 255 words) Hold PLC Device (24 words)	
Battery Note3)	Backup	Built-in clock data Alarm history data Line graph sampling data Internal device hold data Hold PLC Device data	
	Life	Approx. 2 years (at 25 °C)	

Note1) The touch position may shift due to aging variation. If the touch position has shifted greatly, please adjust it.

The battery life is the value when no power at all is supplied. The actual lifetime may be shorter according to the condition of use.

Note2) A battery is necessary for SRAM backup.

Note3) Please purchase a battery separately.

6.8.3 Function Specifications (GT21)

Item	Specifications
Displayable fonts	Fixed (GTWIN): 1/4 width (8 x 8), half width (16 x 8), full width (16 x 16)
	(Double or quadruple in height and width)
	True Type (GTWIN): 10 to 240 dots
	Windows (R): 10 to 240 dots
Character types	English, Japanese, Korean, German, French, Italian, Spanish, Simplified
	Chinese, Traditional Chinese characters, Turkish, Russian and Vietnamese can
	be displayed.
Number of	250 screens Note1)
registerable screens	
Registerable screen	Base screen: No. 0 to 3FF
number	Keyboard screen: No. 0 to 7
Graphics	Straight lines, continuous straight lines, squares, circles, ovals, arcs, elliptic
	arcs, fan shapes, elliptic fan shapes, beveled squares
Types of parts	Switch
	Function switch
	Lamp
	Message
	Data
	Bar graph
	Clock Note2) 3)
	Line graph
	Alarm list
	Alarm history
	Keyboard
Note (I)	Custom(message, lamp, switch)
Main functions Note4)	Recipe
	Flow display
	Write device
	Multi language exchange
Through function	Connecting a computer to TOOL port and our PLC to COM port enables the
	communication between the PLC and the computer.
Copy function *5	The screen data can be copied by connecting the main units with a cable.
GTWIN ver.	Ver. 2.70 or later

Note1) Maximum allowable number varies depending on registered contents.

Note2) A clock part can be indicated by referring to external clock data.

Note3) Accuracy of the GT internal clock is ±180 seconds per month.

Note4) It depends on the version of GT.

6.8.4 Interface Specifications (GT21)

Interface for connecting PLC/External devices

- COM port

ltem		Specifications		
10	em	AIGT2230B/AIGT2230H	AIGT2232B/AIGT2232H	
Communication	standard	Conforms to RS232C	Conforms to RS422	
		(Non insulation type)	(Non insulation type)	
Communication	Baud rate (bit/s)	9600, 19200, 38400, 57600, 11520	0 bps	
condition with	Data length (bit)	7, 8		
external	Parity	None, Odd, Even		
devices	Stop bit (bit)	1		
Transmission distance		Max. 15 m	Max. 500 m	
(Total length)		(Baud rate: 19200 bit/s)	(Baud rate: 115200 bit/s)	
Protocol		- MEWTOCOL (Protocol for PANASONIC PLC: FP series)		
		- General-purpose serial (PANASONIC dedicated protocol)		
		- Other companies' PLC protocols (For the details, refer to the latest		
		GTWIN HELP.)		
Connector		Connector terminal base (8-pin) Note1) 2)		

Note1) The (+) and (-) terminals are the power supply terminals for driving the main unit.

Note2) Regarding power supply voltage, please pay due consideration to the cable length so that the applied voltage is within the operation voltage range.

Interface for transferring screen data

- TOOL port

Item		Specifications
Communication s	tandard	Conforms to RS232C (Non insulation type)
Conditions for	Baud rate (bit/s)	9600, 19200, 115200, 230400 bps Note1) 2)
Conditions for communications	Data length (bit)	8
with GTWIN	Parity	None, Odd, Even
Willi GTVVIIV	Stop bit (bit)	1
Protocol		GT dedicated protocol
Connector		Mini-DIN (5-pin)

Note1) The baud rate of 230400 bps is available when the USB/RS232C conversion cable is used.

Note2) When the baud rate is set to 230400 bps, the connection using the GTWIN automatic communication setting function is not possible. Set the GTWIN communication setting to 230400 bps, and then transfer data.

6.9 GT32

6.9.1 General Specifications (GT32)

Itama	Specifications			
Item	GT32M	GT32T0	GT32T1	
Rated voltage	24 V DC			
Operating voltage range	21.6 to 26.4 V DC			
Power consumption	10 W or less (410 mA	or less)	12 W or less (500 mA or less)	
Insulation method of	Transformer insulatio	n		
power supply part		II .		
Ambient temperature	0 to +50 °C Note1)			
Ambient humidity	20 to 85% RH (at 25	°C), non-condensing		
Storage temperature	-20 to +60 °C			
Storage humidity	10 to 85% RH (at 25	°C), non-condensing		
Breakdown voltage Note2)	Between [power supply terminals] and [case]			
Breakdown voltage	500 V AC for 1 minute, Cutoff current 10mA (at default setting)			
Insulation resistance	Between [power supply terminals] and [case]			
Note2)	100 M Ω or more, 500 V DC, measured with megohmmeter (at default			
	setting)			
Vibration resistance			75 mm, 10 min on 3 axes	
Shock resistance	98 m/s ² , 4 times on 3	axes		
EC Directive applicable	EN61131-2 (EMC Dir	ective)		
Noise immunity	1000 V [P-P] or more, Pulse width 50 ns, 1µs between power supply			
Noise immunity	terminals (based on in-house measurements) Note3)			
	IP65 (Initial value, evaluated by us)			
Protective construction	Dustproof and drip-proof from front panel only (packing used on panel contact surface)			
Weight	Approx. 500 g	Approx. 470 g	Approx. 480 g	

Note1) When it is installed in a horizontal orientation (installed to make the liquid crystal face be topside), the usable range is 0 to +40 °C.

Note2) Not isolated between the USB port, COM port, Ethernet port (GT32T1 only) and the internal digital circuit.

Note3) When using our exclusive cable.

Note4) When reattaching, replace waterproof packing.

6.9.2 Performance Specifications (GT32)

Item		Specifications			
		GT32M	GT32T0	GT32T1	
	Display device	Blue-white STN monochrome LCD	4096-color TFT	color LCD	
	Resolution	320 (W) x 240 (H) dots			
	Displayable area	113.2 (W) x 86.4 (H) mm	110.8 (W) x 83.	6 (H) mm	
Display	Backlight	CFL backlight			
	LCD life	75000 hours (at 25 °C) Note4)	50000 hours (at	t 25 °C) Note4)	
	Contrast	Can be adjusted on the menu screen.	None		
	Touch switch	Analog touch switch (resistive film type	oe)		
Touch switches	Touch switch operation	0.8 N or less			
	Life	1 million times or more (at 25 °C) Note	1)		
		Connecting a computer to Ethernet p	ort or USB port a	nd our PLC to	
Through f	unction	COM port enables the communication between the PLC and the computer. Note6)			
Memory	F-ROM	Screen data (base, keyboard, login), Flow display data, FP monitor screen data: 2048 kbytes	Screen data (ba login), Flow disp Sound function, screen data: 12 Note5)	olay data, FP monitor	
		Recipe data: 64 k bytes Write device data: 64 kbytes			
	SRAM Note2)	Alarm history + Line graph sampling (27.5 kbytes) Logging data of Logging function (64 kbytes) Hold GT Device (2048 + 255 words) Hold PLC Device (24 words)			
Battery Note3)	Backup	Built-in clock data Alarm history data Line graph sampling data Logging data of Logging function Internal device hold data Hold PLC Device data			
	Life	Approx. 5 years (at 25 °C)	Approx. 3 years	s (at 25 °C)	

- Note1) The touch position may shift due to aging variation. If the touch position has shifted greatly, please adjust it.
- Note2) A battery is necessary for SRAM backup.
 - The unused part of 27 kbytes for Alarm history and line graph sampling can be used for the logging function.
- Note3) Please purchase a battery separately.
 - The battery life is the value when no power at all is supplied. The actual lifetime may be shorter according to the condition of use.
- Note4) The backlight life varies depending on the usage environment such as temperature, humidity or operating voltage.
 - Especially, if it is used at low temperatures, the life will be extremely short.
- Note5) The sound output function is available for GT32T1 only.
- Note6) An Ethernet port is available for GT32T1 only.

6.9.3 Function Specifications (GT32)

Displayable fonts Fixed (GTWIN): 1/4 width (8 x 8), half width (16 x 8), full width (16 x 16) (Double, quadruple or octuple in height and width) True Type (GTWIN): 10 to 240 dots Windows (R): 10 to 240 dots Windows (R): 10 to 240 dots Character types English, Japanese, Korean, German, French, Italian, Spanish, Simplified Chinese, Traditional Chinese characters, Turkish, Russian and Vietnamese of displayed. Number of chinese, Traditional Chinese characters, Turkish, Russian and Vietnamese of displayed. Number of Registerable screens Registerable screens Registerable screen Base screen: No. 0 to 3FF Keyboard screen: No. 0 to 7 Login screen: No. 0 to 7 Login screen: No. 0 to 7 Straight lines, continuous straight lines, squares, circles, ovals, arcs, elliptic arcs, fan shapes, elliptic fan shapes, beveled squares Types of parts Switch Function switch Lamp Message Data Bar graph Clock Note2/3) Line graph Alarm list Keyboard Custom(message, lamp, switch) Main functions Notee) Recipe SD recipe Flow display Write device Multi language exchange Sound output Note(4) Operation security GT link PLC multiple connection Data logging FP monitor Through function Connecting a computer to Ethernet port or USB port and our PLC to COM pc enables the communication between the PLC and the computer. (This functions)	lie	Specifi	cations	
Displayable fonts Fixed (GTWIN): 1/4 width (8 x 8), half width (16 x 8), full width (16 x 16) (Double, quadruple or octuple in height and width) True Type (GTWIN): 10 to 240 dots Windows (R): 10 to 240 dots Windows (R): 10 to 240 dots Character types	Item	GT32M	GT32T0/GT32T1	
Chinese, Traditional Chinese characters, Turkish, Russian and Vietnamese of be displayed. Number of registerable screens Registerable screen Registerable screen Base screen: No. 0 to 3FF Keyboard screen: No. 0 to 7 Login screen: No. 0 to 7 Straight lines, continuous straight lines, squares, circles, ovals, arcs, elliptic arcs, fan shapes, elliptic fan shapes, beveled squares Types of parts Switch Function switch Lamp Message Data Bar graph Clock Note2 3) Line graph Alarm list Keyboard Custom(message, lamp, switch) Main functions Note6) Recipe SD recipe Flow display Write device Multi language exchange Sound output Note4) Operation security GT link PLC multiple connection Data logging FP monitor Through function Connecting a computer to Ethernet port or USB port and our PLC to COM poenables the communication between the PLC and the computer. (This function	Displayable fonts	(Double, quadruple or of True Type (GTWIN): 10 to 240 dots	dth (16 x 8), full width (16 x 16)	
Registerable screens Registerable screen Registerable screen No. 0 to 3FF Keyboard screen: No. 0 to 7 Login screen: No. 0 to F Graphics Straight lines, continuous straight lines, squares, circles, ovals, arcs, elliptic arcs, fan shapes, elliptic fan shapes, beveled squares Types of parts Switch Function switch Lamp Message Data Bar graph Clock Note(2) 3) Line graph Alarm list Keyboard Custom(message, lamp, switch) Main functions Recipe SD recipe Flow display Write device Multi language exchange Sound output Note(4) Operation security GT link PLC multiple connection Data logging FP monitor Through function Connecting a computer to Ethernet port or USB port and our PLC to COM poenables the communication between the PLC and the computer. (This function	Character types	Chinese, Traditional Chinese characters		
Registerable screen number Base screen: No. 0 to 3FF Keyboard screen: No. 0 to 7 Login screen: No. 0 to F Graphics Straight lines, continuous straight lines, squares, circles, ovals, arcs, elliptic arcs, fan shapes, elliptic fan shapes, beveled squares Types of parts Switch Function switch Lamp Message Data Bar graph Clock Note2) 3) Line graph Alarm list Keyboard Custom(message, lamp, switch) Main functions Note6) Recipe SD recipe Flow display Write device Multi language exchange Sound output Note4) Operation security GT link PLC multiple connection Data logging FP monitor Through function Connecting a computer to Ethernet port or USB port and our PLC to COM poenables the communication between the PLC and the computer. (This function		Approx. 240 screens Note1)	Approx. 180 screens Note1)	
arcs, fan shapes, elliptic fan shapes, beveled squares Switch Function switch Lamp Message Data Bar graph Clock Note2) 3) Line graph Alarm list Keyboard Custom(message, lamp, switch) Main functions Note6) Recipe SD recipe Flow display Write device Multi language exchange Sound output Note4) Operation security GT link PLC multiple connection Data logging FP monitor Through function Connecting a computer to Ethernet port or USB port and our PLC to COM poenables the communication between the PLC and the computer. (This function	Registerable screen	Keyboard screen: No. 0 to 7		
Function switch Lamp Message Data Bar graph Clock Note2) 3) Line graph Alarm list Keyboard Custom(message, lamp, switch) Main functions Note6) Recipe SD recipe Flow display Write device Multi language exchange Sound output Note4) Operation security GT link PLC multiple connection Data logging FP monitor Through function Connecting a computer to Ethernet port or USB port and our PLC to COM poenables the communication between the PLC and the computer. (This function	Graphics			
SD recipe Flow display Write device Multi language exchange Sound output Note4) Operation security GT link PLC multiple connection Data logging FP monitor Through function Connecting a computer to Ethernet port or USB port and our PLC to COM poenables the communication between the PLC and the computer. (This function		Function switch Lamp Message Data Bar graph Clock Note2) 3) Line graph Alarm list Keyboard Custom(message, lamp, switch)		
enables the communication between the PLC and the computer. (This function	Main functions Note(s)	SD recipe Flow display Write device Multi language exchange Sound output Note4) Operation security GT link PLC multiple connection Data logging		
is not available for PLCs manufactured by other companies.) Notes	Through function	Connecting a computer to Ethernet port enables the communication between the	PLC and the computer. (This function	
Copy function Screen data can be copied with a SD memory card.	Copy function			
GTWIN ver. Ver. 2.80 or later	• •	·		

Note1) Maximum allowable number varies depending on registered contents.

Note2) External clock data can be referred and displayed.

Note3) Accuracy of the GT internal clock is ±180 seconds per month.

Note4) The sound output function is available for GT32T1 only.

Note5) An Ethernet port is available for GT32T1 only.

Note6) It depends on the version of GT.

6.9.4 Interface Specifications (GT32)

Interface for connecting PLC/External devices

- COM port

		Specifications		
Ita	em	AIG32MQ02D/AIG32MQ03D AIG32TQ02D/AIG32TQ03D AIG32TQ12D/AIG32TQ13D	AIG32MQ04D/AIG32MQ05D AIG32TQ04D/AIG32TQ05D AIG32TQ14D/AIG32TQ15D	
Communication	standard	Conforms to RS232C (Non insulation type) Note1)	Conforms to RS422 (Non insulation type) Note1)	
Communication	Baud rate (bit/s)	9600, 19200, 38400, 57600, 11520	0 bps	
condition with	Data length (bit)	7, 8		
external	Parity	None, Odd, Even		
devices	Stop bit (bit)	1		
Transmission distance		Max. 15 m	Max. 500 m	
(Total length)		(Baud rate: 19200 bit/s)	(Baud rate: 115200 bit/s)	
Protocol		- MEWTOCOL (Protocol for PANASONIC PLC: FP series)		
		- MEWTOCOL7 (Protocol for PANASONIC PLC: FP7 series)		
		- General-purpose serial (PANASONIC dedicated protocol)		
		- Other companies' PLC protocols	(For the details, refer to the latest	
		GTWIN HELP.)		
Connector		Connector terminal base (8-pin) Note2) 3)		

- Note1) It is internally isolated from the input power supply side (between +24V and 0V).
- Note2) The (+) and (-) terminals are the power supply terminals for driving the main unit.
- Note3) Regarding power supply voltage, please pay due consideration to the cable length so that the applied voltage is within the operation voltage range.

Interface for transferring screen data

- USB port

Item	Specifications
Communication standard	USB1.1
Connector shape Note1)	TYPE-B
Trasmission distance	Max. 5 m
No. of connected unit with PC	1 unit

Note1) Take care of handling of the connector not to add an excessive static electricity on the metal part of the connector.

Note2) Screens can be transferred in one third less time via the Ethernet port.

(The speed varies depending on screen contents.)

Ethernet port (GT32T1 only)

Item	Specifications	
item	GT32T1	
Communication standard	IEEE802.8u/100BASE-TX IEEE802.3/10BASE-T Note1)	
Connector shape	Plug-in phone jack Note2)	
Transmission distance	Max. 100 m	
Applicable cable	UTP cable (Unshielded wire) Category 5 Note3)	
Auto MDI-X	Supported	
SPEED lamp	Light on: During 100BASE-TX communication	
SPEED IAITIP	Blinking: During 10BASE-TX communication	
LINK/ACT lamp	Light on: When linked	
LINNACTIANIP	Blinking: During data reception.	

- Note1) Data processing in the main unit is carried out with the serial communication of 115.2 kbps.
- Note2) Take care of handling of the connector not to add an excessive static electricity on the metal part of the connector.
- Note3) Do not use a STP cable (shielded wire).
- Note4) Ethernet is a trademark of Xerox Corporation, USA.
- Note5) Simultaneous communication with the USB port is not achievable.

SD memory card slot

Item	Specifications
Support media	SD memory card, SDHC memory card Note1)
Supported format standard	Conforms to SD standard Note2)

Note1) The manufacturer name that the operation check has done: Panasonic Corporation Usable capacity of a SD memory card varies according to the version of GT firmware.

Note2) Please format with a format software for SD memory cards.

Note3) The SD access lamp turns on while accessing the SD memory card.

6.9.5 Sound Output Specifications (GT32T1 Only)

Item	Specifications	
item	GT32T1	
File format	WAV format (PCM format, sampling 8 KHz, 16 bits monaural)	
Max. sound data capacity	512 kbytes (Approx. 30 seconds)	
Max. registered No. of sound data	128	
Sound output voltage	2 Vp-p	
Output terminal	φ3.5 stereo mini jack	
Connecting amplifier	Input impedance 10 k Ω or more	

6.10 GT32-R

6.10.1 General Specifications (GT32-R)

ltom	Specifications	
Item	GT32M-R	GT32T-R
Rated voltage	24 V DC	
Operating voltage range	21.6 to 26.4 V DC	
Power consumption	4.8 W or less (200 mA or less)	7.2 W or less (300 mA or less)
Insulation method of	Transformer insulation	
power supply part		
Ambient temperature	0 to +50 °C	
Ambient humidity	20 to 85% RH (at 25 °C), non-condensing	
Storage temperature	-20 to +60 °C	
Storage humidity	10 to 85% RH (at 25 °C), non-condensing	
Breakdown voltage Note1)	Between [power supply terminals] and [case]	
breakdown voitage	500 V AC for 1 minute, Cutoff current 10mA (at default setting)	
	Between [power supply terminals] and [case]	
Insulation resistance	100 M Ω or more, 500 V DC, measured with megohmmeter (at default	
	setting)	
	5 to 8.4 Hz half amplitude 3.5 mm	
Vibration resistance	8.4 to 150 Hz acceleration 9.8 m/s2,	
	10 sweeps each in X, Y and Z directions (1 octave/min)	
Shock resistance	147 m/s ² , 4 times on 3 axes	
EC Directive applicable	EN61131-2 (EMC Directive)	
Noise immunity	1000 V [P-P] or more, Pulse width 50 ns, 1μs between power supply	
	terminals (based on in-house measurements) Note2)	
Electrostatic discharge	6kV	
resistance	(Contact Discharge, EN61000-4-2 Level 3)	
Protective construction	IP67 (Initial value, evaluated by us)	
	Dustproof and drip-proof from front panel only (packing used on panel	
	contact surface)	
Weight	Approx. 470 g	

Note1) Not isolated between the USB port, COM port and the internal digital circuit.

Note2) When using our exclusive cable.

Note3) When reattaching, replace waterproof packing.

6.10.2 Performance Specifications (GT32-R)

Item		Specifications	
		GT32M-R	GT32T-R
Display Note1)	Display device	TFT monochrome LCD	TFT color LCD
	Resolution	320 (W) x 240 (H) dots	
	Displayable area	115.2 (W) x 86.4 (H) mm	
	Backlight	1-color LED backlight (white)	
	Contrast	Can be adjusted on the menu screen, GTWIN configuration settings or PLC. (There are some minor variations in the backlight brightness.)	
	Touch switch	Analog touch switch (resistive film t	type)
Touch switches	Touch switch operation	0.8 N or less	
	Life	1 million times or more (at 25 °C) Note2)	
Memory	F-ROM	Screen data (base, keyboard, login), Flow display data, FP monitor screen data: 12288 kbytes Recipe data: 64 k bytes Write device data: 64 kbytes	
	SRAM Note3)	Alarm history + Line graph sampling (27.5 kbytes) Logging data of Logging function (64 kbytes) Hold GT Device (2048 + 255 words) Hold PLC Device (24 words)	
Battery Note4)	Backup	Built-in clock data Alarm history data Line graph sampling data Logging data of Logging function Internal device hold data Hold PLC Device data	
	Life	Approx. 3 years (at 25 °C)	

- Note1) On the LCD panel, bright spots (points always lit) or black spots (points always unlit) may appear, or the uneven brightness, flickers or crosstalk (appearance of unintended shades in the area no graphic or part is arranged) may occur depending on the operating conditions. Note that these phenomena are resulted from the basic characteristics of LCD panel not defects or failures of the product.
- Note2) The touch position may shift due to aging variation. If the touch position has shifted greatly, please adjust it.
- Note3) A battery is necessary for SRAM backup.
 - The unused part of 27 kbytes for Alarm history and line graph sampling can be used for the logging function.
- Note4) Please purchase a battery separately.
 - The battery life is the value when no power at all is supplied. The actual lifetime may be shorter according to the condition of use.

6.10.3 Function Specifications (GT32-R)

lt a ma	Specifications		
Item	GT32M-R	GT32T-R	
Displayable fonts	Fixed (GTWIN): 1/4 width (8 x 8), half wi	dth (16 x 8), full width (16 x 16)	
	(Double, quadruple or octuple in height and width)		
	True Type (GTWIN): 10 to 240 dots		
	Windows (R): 10 to 240 dots		
Character types	English, Japanese, Korean, German, French, Italian, Spanish, Simplified		
	Chinese, Traditional Chinese characters, Turkish, Russian and Vietnamese ca		
	be displayed.		
Number of	Approx. 180 screens Note1)		
registerable screens			
Registerable screen	Base screen: No. 0 to 3FF		
number	Keyboard screen: No. 0 to 7		
	Login screen: No. 0 to F		
Graphics	Straight lines, continuous straight lines, squares, circles, ovals, arcs, elliptic		
	arcs, fan shapes, elliptic fan shapes, bev	eled squares	
Types of parts	Switch		
	Function switch		
	Lamp		
	Message		
	Data		
	Bar graph		
	Clock Note2) 3)		
	Line graph		
	Alarm list		
	Keyboard		
Note (I)	Custom(message, lamp, switch)		
Main functions Note4)	Recipe		
	SD recipe		
	Flow display		
	Write device		
	Multi language exchange		
	Operation security		
	GT link		
	PLC multiple connection		
	Data logging		
<u> </u>	FP monitor		
Through function	Connecting a computer to USB port and	•	
	communication between the PLC and th		
Copy function	Screen data can be copied with a SD memory card.		
GTWIN ver.	Ver. 2.C0 or later		

Note1) Maximum allowable number varies depending on registered contents.

Note4) It depends on the version of GT.

Note2) External clock data can be referred and displayed.

Note3) Accuracy of the GT internal clock is ± 90 seconds per month (at 25 °C). Periodically set the clock to the right time for the system in which clock error is a problem.

6.10.4 Interface Specifications (GT32-R)

Interface for connecting PLC/External devices

- COM port

Item		Specifications	
		AIG32MQ02DR / AIG32MQ03DR AIG32TQ02DR / AIG32TQ03DR	AIG32MQ04DR / AIG32MQ05DR AIG32TQ04DR / AIG32TQ05DR
Communication standard		Conforms to RS232C	Conforms to RS422
		(Non insulation type) Note1)	(Non insulation type) Note1)
Communication	Baud rate (bit/s)	9600, 19200, 38400, 57600, 115200 bps	
condition with	Data length (bit)	7, 8	
external	Parity	None, Odd, Even	
devices	Stop bit (bit)	1	
Transmission distance		Max. 15 m	Max. 500 m
(Total length)		(Baud rate: 19200 bit/s)	(Baud rate: 115200 bit/s)
Protocol		- MEWTOCOL (Protocol for PANASONIC PLC: FP series)	
		- MEWTOCOL7 (Protocol for PANA	ASONIC PLC: FP7 series)
		- General-purpose serial (PANASO	NIC dedicated protocol)
		- Other companies' PLC protocols ((For the details, refer to the latest
		GTWIN HELP.)	
Connector		Connector terminal base (8-pin) Note2) 3)	

Note1) It is internally isolated from the input power supply side (between +24V and 0V).

Note2) The (+) and (-) terminals are the power supply terminals for driving the main unit.

Note3) Regarding power supply voltage, please pay due consideration to the cable length so that the applied voltage is within the operation voltage range.

Interface for transferring screen data

- USB port

OOD POIL	
Item	Specifications
Communication standard	USB1.1
Connector shape Note1)	TYPE-B
Trasmission distance	Max. 5 m
No. of connected unit with PC	1 unit

Note1) Take care of handling of the connector not to add an excessive static electricity on the metal part of the connector.

SD memory card slot

Item	Specifications	
Support media Note1)	SD memory card, SDHC memory card	
	(The manufacturer name that the operation check has done:	
	Panasonic Corporation)	
Supported format standard	Conforms to SD standard	
	(Please format with a format software for SD memory cards.)	

Note1) Check the usable temperature range of a SD memory card to be used before use.

6.11 GT32-E

6.11.1 General Specifications (GT32-E)

11	Specifi	cations						
Item	GT32M-E	GT32T-E						
Rated voltage	24 V DC							
Operating voltage range	21.6 to 26.4 V DC							
Power consumption	4.8 W or less (200 mA or less) 7.2 W or less (300 mA or less)							
Insulation method of	Transformer insulation							
power supply part								
Ambient temperature	-20 to +60 °C Note1)							
Ambient humidity	10 to 90% RH (at 25 °C), non-conder	nsing						
Storage temperature	-20 to +60 °C							
Storage humidity	10 to 90% RH (at 25 °C), non-conder	nsing						
Breakdown voltage Note2)	Between [power supply terminals] and [case] 500 V AC for 1 minute, Cutoff current 10mA (at default setting)							
Insulation resistance	Between [power supply terminals] and [case] 100 M Ω or more, 500 V DC, measured with megohmmeter (at default setting)							
	5 to 8.4 Hz half amplitude 3.5 mm							
Vibration resistance	8.4 to 150 Hz acceleration 9.8 m/s2,							
	10 sweeps each in X, Y and Z directions (1 octave/min)							
Shock resistance	147 m/s ² , 4 times on 3 axes							
EC Directive applicable	EN61131-2 (EMC Directive)							
Noise immunity	1000 V [P-P] or more, Pulse width 50 ns, 1μs between power supply							
Noise initiality	terminals (based on in-house measurements) Note3)							
Electrostatic discharge	6kV							
resistance	(Contact Discharge, EN61000-4-2 Level 3)							
	IP67 (Initial value, evaluated by us)							
Protective construction	Dustproof and drip-proof from front panel only (packing used on panel							
	contact surface) Note4)							
Weight	Approx. 470 g							

Note1) When it is installed in horizontal orientation (installed to make the liquid crystal face be topside), installed upright in vertical orientation or when using a battery, the usable range is -20 to +55 °C.

Note2) Not isolated between the USB port, COM port and the internal digital circuit.

Note3) When using our exclusive cable.

Note4) When reattaching, replace waterproof packing.

6.11.2 Performance Specifications (GT32-E)

	Item	Specifi	cations				
		GT32M-E	GT32T-E				
	Display device	TFT monochrome LCD TFT color LCD					
	Resolution	320 (W) x 240 (H) dots					
Display	Displayable area	115.2 (W) x 86.4 (H) mm					
Note1)	Backlight	1-color LED backlight (white)					
	Contrast	Can be adjusted on the menu scree or PLC. (There are some minor var	•				
	Touch switch	Analog touch switch (resistive film to	type)				
Touch switches	Touch switch operation	0.8 N or less					
	Life	1 million times or more (at 25 °C) Note2)					
Memory	F-ROM	Screen data (base, keyboard, login), Flow display data, FP monitor screen data: 12288 kbytes Recipe data: 64 k bytes Write device data: 64 kbytes					
	SRAM Note3)	Alarm history + Line graph sampling (27.5 kbytes) Logging data of Logging function (64 kbytes) Hold GT Device (2048 + 255 words) Hold PLC Device (24 words)					
Battery Note4)	Backup	Built-in clock data Alarm history data Line graph sampling data Logging data of Logging function Internal device hold data Hold PLC Device data					
	Life	Approx. 3 years (at 25 °C)					

- Note1) On the LCD panel, bright spots (points always lit) or black spots (points always unlit) may appear, or the uneven brightness, flickers or crosstalk (appearance of unintended shades in the area no graphic or part is arranged) may occur depending on the operating conditions. Note that these phenomena are resulted from the basic characteristics of LCD panel not defects or failures of the product.
- Note2) The touch position may shift due to aging variation. If the touch position has shifted greatly, please adjust it.
- Note3) A battery is necessary for SRAM backup.
 - The unused part of 27 kbytes for Alarm history and line graph sampling can be used for the logging function.
- Note4) Please purchase a battery separately.
 - The battery life is the value when no power at all is supplied. The actual lifetime may be shorter according to the condition of use.

6.11.3 Function Specifications (GT32-E)

	Specifications					
Item	GT32M-E	GT32T-E				
Displayable fonts	Fixed (GTWIN): 1/4 width (8 x 8), half wi					
	1	octuple in height and width)				
	True Type (GTWIN): 10 to 240 dots					
	Windows (R): 10 to 240 dots					
Character types	ench, Italian, Spanish, Simplified					
	Chinese, Traditional Chinese characters	, Turkish, Russian and Vietnamese can				
	be displayed.					
Number of	Approx. 180 screens Note1)					
registerable screens						
Registerable screen	Base screen: No. 0 to 3FF					
number	Keyboard screen: No. 0 to 7					
	Login screen: No. 0 to F					
Graphics	Straight lines, continuous straight lines,					
	arcs, fan shapes, elliptic fan shapes, bev	/eled squares				
Types of parts	Switch					
	Function switch					
	Lamp					
	Message					
	Data					
	Bar graph					
	Clock Note2) 3)					
	Line graph					
	Alarm list					
	Keyboard					
Note 4)	Custom(message, lamp, switch)					
Main functions Note4)	Recipe					
	SD recipe					
	Flow display					
	Write device					
	Multi language exchange					
	Operation security					
	GT link					
	PLC multiple connection					
	Data logging					
	FP monitor					
Through function	Connecting a computer to USB port and	•				
	communication between the PLC and th					
Copy function	Screen data can be copied with a SD me	emory card.				
GTWIN ver.	Ver. 2.C0 or later					

Note1) Maximum allowable number varies depending on registered contents.

Note2) External clock data can be referred and displayed.

Note3) Accuracy of the GT internal clock is ± 90 seconds per month (at 25 °C). Periodically set the clock to the right time for the system in which clock error is a problem.

Note4) It depends on the version of GT.

6.11.4 Interface Specifications (GT32-E)

Interface for connecting PLC/External devices

- COM port

		Specifications					
It	em	AIG32MQ03DE	AIG32MQ05DE				
		AIG32TQ03DE	AIG32TQ05DE				
Communication	standard	Conforms to RS232C Conforms to RS422					
		(Non insulation type) Note1)	(Non insulation type) Note1)				
Communication	Baud rate (bit/s)	9600, 19200, 38400, 57600, 11520	0 bps				
condition with	Data length (bit)	7, 8					
external	Parity	None, Odd, Even					
devices	Stop bit (bit)	1					
Transmission di	stance	Max. 15 m	Max. 500 m				
(Total length)		(Baud rate: 19200 bit/s) (Baud rate: 115200 bit/s)					
Protocol		- MEWTOCOL (Protocol for PANASONIC PLC: FP series)					
		- MEWTOCOL7 (Protocol for PANASONIC PLC: FP7 series)					
		- General-purpose serial (PANASONIC dedicated protocol)					
		- Other companies' PLC protocols (For the details, refer to the latest					
		GTWIN HELP.)					
Connector		Connector terminal base (8-pin) Note2) 3)					

Note1) It is internally isolated from the input power supply side (between +24V and 0V).

Note2) The (+) and (-) terminals are the power supply terminals for driving the main unit.

Note3) Regarding power supply voltage, please pay due consideration to the cable length so that the applied voltage is within the operation voltage range.

Interface for transferring screen data

- USB port

Item	Specifications
Communication standard	USB1.1
Connector shape Note1)	TYPE-B
Trasmission distance	Max. 5 m
No. of connected unit with PC	1 unit

Note1) Take care of handling of the connector not to add an excessive static electricity on the metal part of the connector.

SD memory card slot

, , , , , , , , , , , , , , , , , , , ,	
Item	Specifications
Support media Note1)	SD memory card, SDHC memory card
	(The manufacturer name that the operation check has done:
	Panasonic Corporation)
Supported format standard	Conforms to SD standard
	(Please format with a format software for SD memory cards.)


Note1) Check the usable temperature range of a SD memory card to be used before use.

Chapter 7


Dimensions and Other Documentation


7.1 Dimensions

7.1.1 GT01/GT01R




Installation dimensions







7.1.2 GT02





Installation dimensions








7.1.3 GT02L















Installation dimensions







7.1.4 GT03M-E








Installation dimensions





Panel cutout dimensions




(Unit: mm)


7.1.5 GT03T-E








Installation dimensions





Panel cutout dimensions




(Unit: mm)

7.1.6 GT05







(Back view)




(Unit: mm)

Installation dimensions








7.1.7 GT11




Installation dimensions









Installation dimensions







7.1.9 GT21




Installation dimensions






7.1.10 GT32


GT32M




Back view




GT32T0




GT32T1





Installation dimensions






7.1.11 GT32-R / GT32-E









(Unit: mm)

Installation dimensions




Panel cutout dimensions



7-12


7.2 Cable Specifications

7.2.1 AIGT8142




(Note) For GT01, the brown wire is connected to the GND terminal of the programmable display.

7.2.2 AIGT8152




(Note) The orange wire is connected to the -RD and E (terminal resistance) terminals.


7.2.3 AIGT8160/AIGT8162/AIGT8165/AIGT8192



7.2.4 AIGT8175



7.2.5 AIP81842



(Note) For GT01, the brown wire is connected to the GND terminal of the programmable display.

7.3 BIN/HEX/BCD Code Correspondence Table

Decimal	Hexadecimal	Bin	ary	Bir	nary Cod	led Decin	nal		
0	0000	00000000	00000000	0000	0000	0000			
1	0001	00000000	0000001	0000	0000	0000 0001			
2	0002	00000000	00000010	0000	0000	0000	0010		
3	0003	00000000	00000011	0000	0000	0000	0011		
4	0004	00000000	00000000 00000100 0000 00				0100		
5	0005	00000000	00000101	0000	0000	0000	0101		
6	0006	00000000	00000110	0000	0000	0000	0110		
7	0007	00000000	00000111	0000	0000	0000	0111		
8	8000	00000000	00001000	0000	0000	0000	1000		
9	0009	00000000	00001001	0000	0000	0000	1001		
10	000A	00000000	00001010	0000	0000	0001	0000		
11	000B	00000000	00001011	0000	0000	0001	0001		
12	000C	00000000	00001100	0000	0000	0001	0010		
13	000D	00000000	00001101	0000	0000	0001	0011		
14	000E	00000000	00001110	0000	0000	0001	0100		
15	000F	00000000	00001111	0000	0000	0001	0101		
16	0010	00000000	00010000	0000	0000	0001	0110		
17	0011	00000000	00010001	0000	0000	0001	0111		
18	0012	00000000	00010010	0000	0000	0001	1000		
19	0013	00000000	00010011	0000	0000	0001	1001		
20	0014	00000000	00010100	0000	0000	0010	0000		
21	0015	00000000 00010101		0000	0000	0010	0001		
22	0016	00000000	00010110	0000	0000	0010	0010		
23	0017	00000000	00010111	0000	0000	0010	0011		
24	0018	00000000	00011000	0000	0000	0010	0100		
25	0019	00000000	00011001	0000	0000	0010	0101		
26	001A	00000000	00011010	0000	0000	0010	0110		
27	001B	00000000	00011011	0000	0000	0010	0111		
28	001C	00000000	00011100	0000	0000	0010	1000		
29	001D	00000000	00011101	0000	0000	0010	1001		
30	001E	00000000	00011110	0000	0000	0011	0000		
31	001F	00000000	00011111	0000	0000	0011	0001		
63	003F	00000000	00111111	0000	0000	0110	0011		
255	00FF	00000000	11111111	0000	0010	0101	0101		
9999	270F	00100111	00001111	1001	1001	1001	1001		

7.4 ASCII Code Table

									Tr.							
							-	b 7				4				
							-	b 6	0	0	0	0	1	1	1	1
							-	b 5	0	0	1	1	0	0	1	1
						b 4	0	1	0	1	0	1	0	1		
b 7	b6	b 5	b4	b 3	b ₂	bı	bo	R	0	1	2	3	4	5	6	7
				0	0	0	0	0	NUL	DEL	SPACE	0	@	P	,	p
				0	0	0	1	1	SOH	DC1	!	1	A	Q	a	q
				0	0	1	0	2	STX	DC_2	"	2	В	R	b	r
				0	0	1	1	3	ETX	DC3	#	3	C	S	С	s
				0	1	0	0	4	EOT	DC4	\$	4	D	Т	d	t
				0	1	0	1	5	ENQ	NAK	%	5	E	U	e	u
				0	1	1	0	6	ACK	SYN	&	6	F	V	f	v
				0	1	1	1	7	BEL	ETB	Ĭ.	7	G	W	g	w
				1	0	0	0	8	BS	CAN	(8	Н	X	h	х
				1	0	0	1	9	НТ	EM)	9	I	Y	i	у
				1	0	1	0	A	LF	SUB	*	:	J	Z	j	z
				1	0	1	1	В	VT	ESC	+	;	K	[k	{
				1	1	0	0	С	FF	FS	,	<	L	¥	1	
				1	1	0	1	D	CR	GS	-	=1	M]	m	}
				1	1	1	0	E	so	RS		>	N	۸	n	~
				1	1	1	1	F	SI	US	1.	?	О	1=	o	DEL

Record of changes

Date	Desceiption of changes
Jul.2010	First edition
Dec.2010	Second edition
Apr.2011	Third edition
Aug.2011	Forth edition - Added new model GT32-E - Error correction
Dec.2011	Fifth edition -Added vertical type display function (GT05/GT32/GT32-E) -Added device change function
Jul.2013	Sixth edition - Added new models GT03-E (Monochrome and Color types)
Nov.2013	Seventh edition
Sep.2014	Eighth edition - Added new model GT32-R
Mar.2016	Ninth edition -Added the description of through functionError correction
	Jul.2010 Dec.2010 Apr.2011 Aug.2011 Dec.2011 Jul.2013 Nov.2013 Sep.2014

Please contact Panasonic Industrial Devices SUNX Co., Ltd.

Overseas Sales Division (Head Office): 2431-1 Ushiyama-cho, Kasugai-shi, Aichi, 486-0901, Japan

■ Telephone: +81-568-33-7861 ■ Facsimile: +81-568-33-8591 panasonic.net/id/pidsx/global

About our sale network, please visit our website.