## **DATASHEET - M22-I1MGE-SAL**

Part no. Catalog No.

No.



Surface mounting enclosure, metal, yellow, 1 mounting location

M22-I1MGE-SAL 118456 Alternate Catalog M22-I1MGE-SALQ



# **Delivery program**

| Basic function accessories |      | Surface mounting enclosure  |
|----------------------------|------|---|
| Housing                    |      | Metal   |
|                            |      | With high-grade steel screws  |
| Number of locations        | Qty. | 1   |
| Cable entry knockouts      |      |   |
| Cable entry                |      |   |
| Degree of Protection       |      | IP66, IP67, IP69  |
| Colour                     |      |   |
|                            |      |   |
| RAL Value                  |      | RAL 1004  |
| Connection to SmartWire-DT |      | no  |
| For use with               |      | 1 x Ø 22.5  |
| For use with               |      | (Illuminated) pushbuttons<br>(Illuminated) selector switches<br>Key-operated pushbuttons<br>Indicator light<br>controlled stop/emergency-stop buttons with yellow label |

### **Technical data**

#### General

Degree of Protection

## **Design verification as per IEC/EN 61439**

| IEC/EN 61439 design verification   |  |
|--|--|
| 10.2 Strength of materials and parts   |  |
| 10.2.2 Corrosion resistance  | Meets the product standard's requirements.                         |
| 10.2.3.1 Verification of thermal stability of enclosures   | Meets the product standard's requirements.                         |
| 10.2.3.2 Verification of resistance of insulating materials to normal heat   | Meets the product standard's requirements.                         |
| 10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects | Meets the product standard's requirements.                         |
| 10.2.4 Resistance to ultra-violet (UV) radiation   | Please enquire   |
| 10.2.5 Lifting   | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.2.6 Mechanical impact   | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.2.7 Inscriptions  | Meets the product standard's requirements.                         |
| 10.3 Degree of protection of ASSEMBLIES  | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.4 Clearances and creepage distances   | Meets the product standard's requirements.                         |
| 10.5 Protection against electric shock   | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.6 Incorporation of switching devices and components   | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.7 Internal electrical circuits and connections  | Is the panel builder's responsibility.                             |
| 10.8 Connections for external conductors   | Is the panel builder's responsibility.                             |
| 10.9 Insulation properties   |  |
| 10.9.2 Power-frequency electric strength   | Is the panel builder's responsibility.                             |
| 10.9.3 Impulse withstand voltage   | Is the panel builder's responsibility.                             |
| 10.9.4 Testing of enclosures made of insulating material   | Is the panel builder's responsibility.                             |

IP66, IP67, IP69

| 10.10 Temperature rise              | The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. |
|-------------------------------------|--|
| 10.11 Short-circuit rating          | Is the panel builder's responsibility. The specifications for the switchgear must be observed.                                   |
| 10.12 Electromagnetic compatibility | Is the panel builder's responsibility. The specifications for the switchgear must be observed.                                   |
| 10.13 Mechanical function           | The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.                         |

## **Technical data ETIM 7.0**

Low-voltage industrial components (EG000017) / Enclosure for control circuit devices (EC000200)

| Electric engineering, automation, process control engineering / Low-voltage switch technology / Command and alarm device / Housing for command and alarm devices (ecl@ss10.0.1-27-37-12-05 [AKF023014]) |   |    |                          |  |
|---|---|----|--------------------------|--|
| Number of command positions   |   |    | 1                        |  |
| Construction type housing   |   |    | Surface mounting housing |  |
| Material housing  |   |    | Aluminium                |  |
| Material quality housing  |   |    | Other                    |  |
| Diameter openings   | r | nm | 22.5                     |  |
| Colour housing cover  |   |    | Yellow                   |  |
| Degree of protection (IP)   |   |    | IP67/IP69K               |  |
| Degree of protection (NEMA)   |   |    | 4X                       |  |
| Width   | m | nm | 67                       |  |
| Height  | m | nm | 84                       |  |
| Depth   | m | nm | 79                       |  |