

A P P R O V A L S ®

## Certificate of Approval

## Certificate No.:

## SAA-180377-EA

Certificate Holder:

## Zhejiang CHINT Electrics Co., Ltd No. 1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing, Zhejiang Province, 325606 P.R. China

Class Description: Product Description: Brand Name: Model No.:

Markings:

Standard:

Conditions:

Approval Mark:

Date of Expiry:

Date First Registered:

Residual Current Device RCBO CHNT NB1L

Un=220V~, 230V~, 240V~ (1P+N) 50/60Hz In=1, 2, 3, 4, 6, 10, 13, 16, 20, 25A, B- & C-type IΔn=30mA, Type A IΔm=2000A Icn=Ics=6000A

Un=220V~, 230V~, 240V~ (2P) 50/60Hz In=6, 10, 13,16, 20, 25, 32, 40A, B- & C-type IΔn=30mA Type A IΔm=2000A Icn=10000A Ics=7500A

AS/NZS 61009.1:2015 Nil

SAA-180377-EA or RCM

7 February 2018 7 February 2023

For and on Behalf of SAA Approvals Pty Ltd

SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to: www.saaapprovals.com.au





Issued: 08-02-18 180377/1a Markings amended