



C-0115

Ref. Certif. No.

SE-86303

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Residual current operated circuit-breaker with integral overcurrent protection for household and similar uses (RCBO's)

Name and address of the applicant

Zhejiang Chint Electrics Co., Ltd.
No.1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing, Zhejiang Province, 325603
CHINA

Name and address of the manufacturer

Same as applicant

Name and address of the factory

Note: When more than one factory, please report on page 2

Same as applicant

Ratings and principal characteristics

U_n= 220, 230, 240V~(2P)
I_n= 6, 10, 13, 16, 20, 25, 32, 40A, B- & C-type
I_{Δn}= 0,03A, type-A
I_{cn}= 10000A, I_{cs}= 7500A, Energy limiting class 3

Trademark (if any)



Customer's Testing Facility (CTF) Stage used

-

Model / Type Ref.

NB1L

Additional information (if necessary may also be reported on page 2)

-

A sample of the product was tested and found to be in conformity with

IEC 61009-1:2010+A1+A2
IEC 61009-2-1:1991

As shown in the Test Report Ref. No. which forms part of this Certificate

170101371SHA-002

This CB Test Certificate is issued by the National Certification Body

Intertek Semko AB
Box 1103
SE-164 22 Kista, Sweden
Int +46 8 750 00 00



Signature:

Bo Berglöf

Date: 15 March 2017