



Ref. Certif. No.

SE-101898**IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME****CB TEST CERTIFICATE**

Product

Circuit-breakers for overcurrent protection for household and similar installations (CBOs)

Name and address of the applicant

Zhejiang Chint Electrics Co., Ltd.
No.1 Chint Road, Chint Industrial Zone, North Baixiang, Yueqing,
Zhejiang Province, P.R.China. 325603

Name and address of the manufacturer

Same as applicant

Name and address of the factory

Note: When more than one factory, please report on page 2

Same as applicant

Ratings and principal characteristics

Un= 240/415V~, 125VDC(1P); 415V~, 250VDC(2P);
In= 1, 2, 3, 4, 6, 10, 13, 16, 20, 25, 32, 40, 50, 63A;
Icn= 10000A, Ics= 7500A, B- and C- type

Trademark (if any)

Customer's Testing Facility (CTF) Stage used

-

Model / Type Ref.

NB1-63

Additional information (if necessary may also be reported on page 2)

-

A sample of the product was tested and found to be in conformity with

IEC 60898-1:2015+A1
IEC 60898-2:2016

As shown in the Test Report Ref. No. which forms part of this Certificate

200302891SHA-001, 200302891SHA-002, 200302891SHA-003,
200302891SHA-004

This CB Test Certificate is issued by the National Certification Body

Intertek Semko AB
Torshamnsgatan 43
Box 1103
SE-164 22 Kista, Sweden

Signature:

Date: 29 July, 2020

Leif Söderlund