

ATTESTATION OF CONFORMITY

Issued to: Zhejiang Chint Electrics Co., Ltd.
No. 1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing,
325603 Zhejiang, China

For the product: Type B residual current operated circuit-breakers (RCCBs)

Trade name: CHINT

Type/Model: NL210

Ratings: 1P+N, 3P+N
Ue = 230 / 240 Vac for 1P+N, 400 / 415 Vac for 3P+N, 50 Hz
In = 25, 40, 63 A
IΔn = 0,03, 0,1, 0,3 A, type B, without time-delay
Inc = IΔc = 10 kA, IΔm = Im: 500 A and 10 In whichever is greater

Manufactured by: Zhejiang Chint Electrics Co., Ltd.
No. 1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing,
325603 Zhejiang, China

Subject: Type Test

Requirements: EN 61008-1:2012, EN 61008-1:2012/A1:2014, EN 61008-1:2012/A2:2014,
EN 61008-1:2012/A11:2015, EN 61008-1:2012/A12:2017, EN 61008-2-1:1994,
EN 61008-2-1:1994/A11:1998, EN 62423:2012, IEC 61008-1:2010, A1:2012,
A2:2013, IEC 61008-2-1:1990, IEC 62423:2009

Remark: This Attestation replaces AoC no. 3316862.01A issued on 2019-12-04 and
3314339.01A issued 2018-09-17.

This Attestation is granted on account of an examination by DEKRA, the results of which are laid down in a confidential file no 3316987.50 issued on 2020-03-16.

This Attestation implies that the examined types are in accordance with the standards designated under the Low voltage directive (LVD) 2014/35/EU.

The examination has been carried out on one single specimen or several specimens of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

The CE marking may be affixed on the product if all relevant and effective EC directives are complied with.

Wenzhou, Zhejiang, 30 March 2020

Number: 3316987.01A

DEKRA Testing Services (Zhejiang) Co., L td.

Certification Manager Ms J Guo

© Integral publication of this attestation and adjoining reports is allowed



DEKRA Testing Services (Zhejiang) Co., L td.

No. 5. Changjiang Road, Great Bridge Industrial Park, North Baixiang,, 325603 Wenzhou, Zhejiang, China
T +86 57762 868000 F +86 57762 919889 www.dekra-product-safety.com