## SIEMENS

## Data sheet

## 3UF7122-1AA01-0



Current/voltage measuring module for dry-running protection of centrifugal pumps in hazardous areas; set current 10 ... 115 A, voltage measurement up to 690 V, width 55 mm, straight-through transformer

| product brand name  | SIRIUS  |  |  |
|---|---|--|--|
| product designation   | Current/voltage measuring module                                |  |  |
| General technical data  |   |  |  |
| product function  |   |  |  |
| <ul> <li>current measurement</li> </ul>   | Yes   |  |  |
| <ul> <li>voltage measurement</li> </ul>   | Yes   |  |  |
| <ul> <li>active power measurement</li> </ul>  | Yes   |  |  |
| <ul> <li>power measurement</li> </ul>   | Yes   |  |  |
| <ul> <li>frequency measurement</li> </ul>   | Yes   |  |  |
| <ul> <li>active power monitoring for pump dry-run according to<br/>Ignition protection type Ex b</li> </ul> | Yes   |  |  |
| measuring procedure for current measurement   | TRMS  |  |  |
| current measuring range extension with external current<br>transformers                                     | No  |  |  |
| measuring procedure for voltage measurement   | TRMS  |  |  |
| measurable supply voltage between the line conductors at<br>AC maximum rated value                          | 690 V   |  |  |
| line conductors and neutral conductors internal resistance for voltage measurement                          | RC-based voltage divider  |  |  |
| product component   |   |  |  |
| input for thermistor connection   | No  |  |  |
| consumed active power   | 0.5 W   |  |  |
| insulation voltage  |   |  |  |
| <ul> <li>with degree of pollution 3 at AC rated value</li> </ul>  | 690 V   |  |  |
| for wires of main circuit according to IEC 60947-1 rated     value  | 6 kV  |  |  |
| surge voltage resistance rated value  | 6 000 V   |  |  |
| protection class IP   | IP20  |  |  |
| shock resistance according to IEC 60068-2-27  | 15g / 11 ms; with basic unit snapped on                         |  |  |
| vibration resistance  | 1-6 Hz / 15 mm; 6-500 Hz / 2 g; with basic unit snapped on: 1g  |  |  |
| Substance Prohibitance (Date)   | 05/28/2009  |  |  |
| certificate of suitability  |   |  |  |
| • IECEx   | Yes; IECEx PTB 18.0004X   |  |  |
| <ul> <li>according to ATEX directive 2014/34/EU</li> </ul>  | BVS 06 ATEX F001, PTB 18 ATEX 5003 X                            |  |  |
| according to UKCA   | ITS21UKEX0464, ITS21UKEX0455X                                   |  |  |
| explosion device group and category according to ATEX<br>directive 2014/34/EU                               | II (2) G, II (2 ) D, I (M2) / I (1G/M2), II (1/2) G, II (1G/2D) |  |  |
| Electromagnetic compatibility   |   |  |  |
| EMC emitted interference according to IEC 60947-1   | class A   |  |  |
| EMC immunity according to IEC 60947-1   | corresponds to degree of severity 3                             |  |  |
| conducted interference  |   |  |  |
| <ul> <li>due to burst according to IEC 61000-4-4</li> </ul>   | 2 kV  |  |  |


| A due to conductor parth surge appording to IEC 61000 4 F  | 2 10/  |
|--|--|
| <ul> <li>due to conductor-earth surge according to IEC 61000-4-5</li> <li>due to conductor-conductor surge according to IEC</li> </ul> | 2 kV<br>1 kV   |
| 61000-4-5  |  |
| field-based interference according to IEC 61000-4-3  | 10 V/m   |
| Inputs/ Outputs  |  |
| number of outputs as contact-affected switching element  | 0  |
| Protective and monitoring functions  |  |
| product function   |  |
| <ul> <li>power factor monitoring</li> </ul>  | Yes  |
| <ul> <li>ground-fault monitoring</li> </ul>  | Yes  |
| voltage detection  | Yes  |
| trip class   | CLASS 5E   |
| product function   | Ver  |
| <ul> <li>current detection</li> <li>overload protection</li> </ul>   | Yes  |
| Precision  |  |
|  |  |
| <ul> <li>measuring precision</li> <li>of frequency measurement</li> </ul>  | +/- 1.5 %, 7.5 A 230 A, 0.85 x 110 V 1.1 x 690 V (line-to-line voltages), cos  |
|  | phi (0.51), 50/60 Hz, 25 °C  |
| <ul> <li>for current measurement 1</li> </ul>  | +/- 1.5 %, in range 7.5 A 230 A, in range 0.85 x 110 V 1.1 x 690 V (line-to-line voltages), 50/60 Hz, 25 $^\circ C$  |
| <ul> <li>for current measurement 2</li> </ul>  | +/- 3%, in range 230 A 920 A, in range 0.85 x 110 V 1.1 x 690 V (line-to-line voltages), 50/60 Hz, 25 $^\circ\text{C}$   |
| <ul> <li>for voltage measurement 1</li> </ul>  | +/- 1.5 %, in range 0.85 x 110 V 1.1 x 690 V (line-to-line voltages), 50/60 Hz, 25 $^\circ\text{C}$  |
| • at cos phi-measurement 1   | +/- 1.5 %, 7.5 A 230 A, 0.85 x 110 V 1.1 x 690 V (line-to-line voltages), cos phi (0.51), 50/60 Hz, 25 °C  |
| at cos phi-measurement 2   | +/- 5%, 230 A 920 A, 0.85 x 110 V 1.1 x 690 V (line-to-line voltages), cos-<br>phi (0.51), 50/60 Hz, 25 °C   |
| • at active power measurement 1  | +/- 5%, 15 A 400 A, 0.85 x 110 V 1.1 x 690 V (line-to-line voltages), cos-<br>phi (0.51), 50/60 Hz, 25 °C  |
| at active power measurement 2  | +/- 10%, 230 A 920 A, 0.85 x 110 V 1.1 x 690 V (line-to-line voltages), cos-<br>phi (0.51), 50/60 Hz, 25 °C  |
| at energy measurement 1  | +/- 5%, 7.5 A 230 A, 0.85 x 110 V 1.1 x 690 V (line-to-line voltages), cos-<br>phi (0.51), 50/60 Hz, 25 °C   |
| <ul><li> at energy measurement 2</li><li> at apparent power measurement 1</li></ul>  | +/- 10%, 230 A 920 A, 0.85 x 110 V 1.1 x 690 V (line-to-line voltages), cos-<br>phi (0.51), 50/60 Hz, 25 °C<br>+/- 3%, 7.5 A 230 A, 0.85 x 110 V 1.1 x 690 V (line-to-line voltages), cos- |
| at apparent power measurement 2  | phi (0.51), 50/60 Hz, 25 °C<br>+/- 5 %, 230 A 920 A, 0.85 x 110 V 1.1 x 690 V (line-to-line voltages), cos   |
| accuracy of ground-fault monitoring  | phi (0.51), 50/60 Hz, 25 °C<br>In the range 30 % 120 %/Is: +/- 10 % (Class CI-A), in range 15 % 30 % le:   |
|  | +/- 25 % (Class CI-B), both values acc. to IEC 60947-1 Annex T   |
| temperature drift per °C   | 0.01 %/°C; Reference temperature: 25°C   |
| measured variable frequency  | 45 65 Hz   |
| Installation/ mounting/ dimensions   |  |
| mounting position  | any  |
| fastening method   | screw and snap-on mounting   |
| height<br>width  | 94 mm<br>55 mm   |
| depth  | 91 mm  |
| required spacing   |  |
| • top  | 30 mm  |
| • bottom   | 30 mm  |
| ● left   | 0 mm   |
| • right  | 0 mm   |
| diameter of inlet opening  | 14 mm  |
| diameter of inlet opening for current measurement  | 14 mm  |
| Connections/ Terminals   |  |
| type of electrical connection at the measurement inputs for voltage  | screw-type terminals   |
| type of connectable conductor cross-sections at the measurement inputs for voltage   |  |
| <ul><li>finely stranded with core end processing</li><li>solid</li></ul>   | 1x (0.25 2.5 mm²), 2x (0.25 1.0 mm²)<br>1x (0.25 2.5 mm²), 2x (0.25 1.0 mm²)   |


| <ul> <li>for AWG cables solid</li> </ul>  | 1x (24 14), 2x (24 18)   |  |  |  |
|---|--|--|--|--|
| at AWG cables solid   | 1x (20 14), 2x (20 16)   |  |  |  |
| tightening torque at the measurement inputs for voltage                                 | 0.5 0.6 N·m  |  |  |  |
| tightening torque [lbf·in] at the measurement inputs for                                | 4.4 5.3 lbf-in   |  |  |  |
| voltage   |  |  |  |  |
| Ambient conditions  |  |  |  |  |
| installation altitude at height above sea level   |  |  |  |  |
| • 1 maximum   | 2 000 m  |  |  |  |
| • 2 maximum   | 3 000 m; max. +50 °C (no protective separation)  |  |  |  |
| • 3 maximum   | 4 000 m; max. +40 °C (no protective separation)  |  |  |  |
| ambient temperature   |  |  |  |  |
| during operation  | -25 +60 °C   |  |  |  |
| during storage  | -40 +80 °C   |  |  |  |
| during transport  | -40 +80 °C   |  |  |  |
| environmental category  |  |  |  |  |
| <ul> <li>during operation according to IEC 60721</li> </ul>                             | 3K6 (no formation of ice, no condensation, relative humidity 10 95%), 3C3 (no salt mist), 3S2 (sand must not get into the devices), 3M6  |  |  |  |
| during storage according to IEC 60721   | 1K6 (no condensation, relative humidity 10 95%), 1C2 (no salt mist), 1S2 (sand must not get into the devices), 1M4   |  |  |  |
| <ul> <li>during transport according to IEC 60721</li> </ul>                             | 2K2, 2C1, 2S1, 2M2   |  |  |  |
| relative humidity during operation  | 10 95 %  |  |  |  |
| Short-circuit protection  |  |  |  |  |
| product function short circuit protection   | No   |  |  |  |
| Galvanic isolation  |  |  |  |  |
| (electrically) protective separation according to IEC 60947-1                           | All circuits with protective separation (double creepage paths and clearances), the information in the "Protective Separation" test report, No. A0258, must be observed (link see further information) |  |  |  |
| Main circuit  |  |  |  |  |
| number of poles for main current circuit  | 3  |  |  |  |
| adjustable current response value current of the current-<br>dependent overload release | 10 115 A   |  |  |  |
| operating voltage   |  |  |  |  |
| • at AC   |  |  |  |  |
| — at 50 Hz rated value  | 110 690 V  |  |  |  |
| — at 60 Hz rated value  | 110 690 V  |  |  |  |
| operating frequency rated value   | 50 60 Hz   |  |  |  |
| Control circuit/ Control  |  |  |  |  |
| type of voltage   | AC   |  |  |  |
| inrush current maximum  | 1 150 A; 10 x lo   |  |  |  |
| Certificates/ approvals   |  |  |  |  |
| General Product Approval  | EMC  |  |  |  |
| <u>Confirmation</u>   |  |  |  |  |
|   |  |  |  |  |
| CSA CCC   | UL — — — — — — — — — — — — — — — — — — —   |  |  |  |
| For use in hazardous locations  | Declaration of Con-<br>formity   |  |  |  |
|   |  |  |  |  |
| IECEX (Ex)  | Explosion Protection<br>Certificate  |  |  |  |
| IECEx ATEX ATEX   | IECEx  |  |  |  |
| Declaration of Con-<br>formity Test Certificates  | Marine / Shipping  |  |  |  |
|   |  |  |  |  |
| EG-Konf.  | ertific- Special Test Certific-<br>ate Lloyds<br>ABS Lloyds  |  |  |  |
|   |  |  |  |  |


Subject to change without notice © Copyright Siemens

| Marine / Shipping   |  | other        |          |  |  |  |
|---|--|--------------|----------|--|--|--|
| RMRS RMRS   | DNV-GL                                       | Confirmation | Profibus |  |  |  |
| Further information   |  |              |          |  |  |  |
| Siemens has decided to exit the Russian market (see here).  |  |              |          |  |  |  |
| https://press.siemens.com/global/en/pressrelease/siemens-wind-down-russian-business<br>Siemens is working on the renewal of the current EAC certificates.<br>Please contact your local Siemens office on the status of validity of the EAC certification if you intend to import or offer to supply these products to an<br>EAC relevant market (other than the sanctioned EAEU member states Russia or Belarus).<br>Information on the packaging<br>https://support.industry.siemens.com/cs/ww/en/view/109813875 |  |              |          |  |  |  |
| Information- and Downloadcenter (Catalogs, Brochures,)  |  |              |          |  |  |  |
| https://www.siemens.com/ic10<br>Industry Mall (Online ordering system)<br>https://mall.industry.siemens.com/mall/en/en/Catalog/product?mlfb=3UF7122-1AA01-0   |  |              |          |  |  |  |
| Cax online generator  |  |              |          |  |  |  |
| http://support.automation.siemens.com/WW/CAXorder/default.aspx?lang=en&mlfb=3UF7122-1AA01-0<br>Service&Support (Manuals, Certificates, Characteristics, FAQs,)<br>https://support.industry.siemens.com/cs/ww/en/ps/3UF7122-1AA01-0  |  |              |          |  |  |  |
| Image database (product images, 2D dimension drawings, 3D models, device circuit diagrams, EPLAN macros,)<br>http://www.automation.siemens.com/bilddb/cax_de.aspx?mlfb=3UF7122-1AA01-0⟨=en  |  |              |          |  |  |  |
| Test report No. A0258, j  | Test report No. A0258, protective separation |              |          |  |  |  |

https://support.industry.siemens.com/cs/ww/en/view/109748152







last modified:

7/15/2022 🖸