CERTIFICATE OF COMPLIANCE

Certificate Number	20170601-E13288
Report Reference	E13288-20160926
Issue Date	2017-JUNE-01
Issued to:	TYCO ELECTRONICS CORP 2901 FULLING MILL RD MIDDLETOWN PA 17057-3170
This is to certify that representative samples of	WIRE CONNECTORS AND SOLDERING LUGS USL/CNL - Listed splicing wire connectors Cat. Nos. 2213600-1, 2213600-2, 2213600-3, 2213600-4, 2213600-5, 2213600-6, 2213600-8 and 1-2213600-0. Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.
Standard(s) for Safety:	UL486C - Standard for Splicing Wire Connectors CSA C22.2 No. 188-13 - Standard for Splicing Wire Connectors
Additional Information:	See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.

Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at http://ul.com/aboutul/locations/

DESCRIPTION

PRODUCT COVERED:

USL/CNL - Listed splicing wire connectors Cat. Nos. 2213600-1, 2213600-2, 2213600-3, 2213600-4, 2213600-5, 2213600-6, **2213600-7, 2213600-8, 2213600-9** and 1-2213600-0.

GENERAL CHARACTER AND USE:

The devices described in this Report are of the following type.

Type of Wiring Termination - Insulation displacement

The insulating covers described in this Report are molded from a Recognized Component plastic (QMFZ2) in two pieces with latches or other means.

WIRE RANGE:

Cat. No.	AWG Copper Run	AWG Copper Tap	ILL. No.
2213600-1, 2213600-4	12-14	14-16	1
2213600-2, 2213600-5	12-14	16-18	
2213600-3, 2213600-6	14-16	16-18	
2213600-8, 1-2213600-0	16-18	16-18	
2213600-7, 2213600-9	**12-14**	**12-14**	

TECHNICAL CONSIDERATIONS (NOT FOR FIELD REPRESENTATIVE USE):

Products designated USR have been investigated using requirements contained in the Standard UL 486C.

Products designated CNR have been investigated using requirements contained in CSA C22.2 No. 188 – 13.

Created by UL Document Assembler 2019-06-14 14:14:42 -05:00

RATINGS:

Connector Temperature - 105°C

Insulation Temperature - 105°C

Voltage - 600 V maximum

Flammability - V-2

MARKING:

1. Connector marked with Listee or trademark, catalog number, wire range, and CU9.

2. Connector, unit container or information sheet marked with:

a. CU9
b. Solid, Sol, Stranded, Str
c. complete or partial list of wire combinations
* d. 600 V maximum building wiring

3. Information sheet marked with:

a. Installation instructions.

4. The cover is marked with manufacturer's name, catalog number, voltage rating, insulation temperature rating.

Created by UL Document Assembler 2019-06-14 14:14:42 -05:00