

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Surge Protective Device

Name and address of the applicant

Schneider Electric Industries SAS
31 rue Pierre Mendès, Eybens F-38050 Grenoble Cedex 9
France

Name and address of the manufacturer

Schneider Electric Industries SAS
31 rue Pierre Mendès, Eybens F-38050 Grenoble Cedex 9
France

Name and address of the factory

Schneider Shanghai Low Voltage Terminal Apparatus Co., Ltd.
1319 Pingan Road, Minhang District, Shanghai
China

Note: When more than one factory, please report on page 2

☐ Additional information on page 2

Ratings and principal characteristics

Test class II/Type 2, IP20
Uc: 340 V(L-N) / 260 V~ (N-PE)
In: 20 kA (iPF K 65), In: 15 kA (iPF K 40, iPF K 40r, Dom PF 40, Domae SPD), In: 5 kA (iPF K 20)
Imax: 65 kA (iPF K 65), Imax: 40 kA (iPF K 40, iPF K 40r, Dom PF 40, Domae SPD), Imax: 20 kA (iPF K 20)
Up: 1.5 kV (iPF K 65, iPF K 40, iPF K 40r, Dom PF 40), Up: 1.1 kV(L-N) / 1.5 kV(N-PE) (iPF K 20)

Trademark / Brand (if any)



Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

iPF K 65 3P+N (A9L15586); iPF K 40 3P+N (A9L15688); iPF K 40 3P (A9L15582); iPF K 40 1P+N (A9L15687); iPF K 40 1P (A9L15686); iPF K 40r 3P+N (A9L15641); iPF K 20 3P+N (A9L15693); iPF K 20 3P (A9L15597); iPF K 20 1P+N (A9L15692); iPF K 20 1P (A9L15691); Dom PF 40 3P+N (16373); Dom PF 40 3P (16374); Dom PF 40 1P+N (16375); Dom PF 40 1P (16376); Domae SPD 3P+N (DOML01740); Domae SPD 3P (DOML01340); Domae SPD 1P+N (DOML01640); Domae SPD 1P (DOML01140).

Additional information (if necessary may also be reported on page 2)

This certificate replaces NL-35447/M1 dated on 2020-03-05 due to technical modification.

☐ Additional information on page 2

A sample of the product was tested and found to be in conformity with

IEC 61643-11:2011

National differences:

EU Group Differences

As shown in the Test Report Ref. No. which forms part of this Certificate

3163891.50, 3163891.51, 3163891.52, 6063628.50 and 6152219.50

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051
Arnhem, 6825 MJ
Netherlands



Date: 2023-03-27

Signature: Kate Xu